

Article

Real-Time Demand Side Management Algorithm Using Stochastic Optimization

Moses Amoasi Acquah¹, Kodaira Daisuke¹ and Sekyung Han*

¹Department of Electrical Engineering, Kyungpook National University, 80 Daehak-ro, Sangyeok-dong, Buk-gu, Daegu 41566, Korea; amoasiacquah@gmail.com, daisuke.kodaira03@gmail.com

* Correspondence: sekyung.han@gmail.com or skhan@knu.ac.kr; Tel.: +81-10-2179-0612

Abstract: A Demand-side management technique are deployed along with battery energy-storage systems (BESSs) to lower the electricity cost by mitigating the peak load of a building. Most of the existing methods rely on manual operation of the BESS, or even an elaborate building energy-management system resorting to a deterministic method that is susceptible to unforeseen growth in demand. In this study we propose a real-time optimal operating strategy for BESS based on density demand forecast and stochastic optimization. This method takes into consideration uncertainties in demand when accounting for an optimal BESS schedule, making it robust compared to the deterministic case. The proposed method is verified and tested against existing algorithms. Data obtained from a real site in South Korea is used for verification and testing. The results show that the proposed method is effective, even for the cases where the forecasted demand deviates from the observed demand.

Keywords: demand-side management, peak demand control, dynamic-interval density forecast, stochastic optimization, dimension reduction, battery energy-storage system (BESS)

1. Introduction

Uneven energy consumption degrades power quality and translates into high energy cost. Therefore, grid operators put much effort toward reducing peak demand through various methods, such as financial incentives. This objective is known as demand-side management (DSM)[1]. DSM is deployed on the consumer side, as well, to mitigate the peak, thereby lowering the electricity cost. Recently, building energy-management systems (BEMS) have been widely deployed for DSM along with a battery energy-storage system (BESS). In many cases, however, the operation of the BESS is determined manually. Even for an elaborate BESS, the operation strategy is intuitively designed and mostly relies on a deterministic method.

In [2], the authors suggested a typical deterministic approach. A peaking interval is foretold empirically, and the BESS is charged to its full capacity prior to this interval. The BESS is then evenly discharged during the defined period. The wider the peaking interval, the higher is the probability of covering all possible peak occurrences. However, the performance of the peak cut would be less effective as the interval becomes wider due to the energy limit of the BESS. A narrow peaking interval has a high probability of missing the peak, but the discharge effect of the BESS is much denser, and thus, the peak can be cut more deeply as long as the actual peak falls within the foretold interval. In both cases, however, the peak cut performance is generally poor because the interval is fixed as that determined during the offline analysis.

Another prevalent method used by industrial energy consumers is to monitor demand and discharge BESS at its full rate when a peak occurs. The advantage of this method is that the discharge interval can be dynamically adjusted depending on the monitored demand value. Nevertheless, this method could lead to an unintended result, as the amount of discharge energy might often be more than necessary, causing an early depletion of the BESS. To tackle this problem, it is important to

know with some certainty when the peak will occur as well as its value. A demand forecast can alleviate this problem,[3]–[7].

Research has shown that BESS can effectively restrict the power demand from exceeding the predetermined value and suppress the voltage imbalance factor within the recommended value [8]–[10]. The research in [11] aims to reduce the electricity cost based on time-of-use (TOU) charges and peak power demand charges as issued by grid companies. The BESS is developed to reduce the peak demand and, consequently, the electricity bill for customers. With the use of BESS, the stress of utility companies can be reduced during high peak power demands.

The above works use a deterministic approach to DSM [7], [11]–[15]. This is an inadequate representation of real-life occurrences of demand. Electric power demands recorded under practical applications are time-series data with uncertainties and are mostly correlated. A single point out of the sample forecasts the future value of demand at a specific time based on historic data. On the other hand, the density forecast gives a forecast at a certain probability value, because in reality, it is difficult to forecast the demand with certainty at a certain time in the future. Density forecast models are useful not only in forecasting the future behaviour, but also in determining optimal operation and control policies [16]. Most DSM approaches do not take into consideration the stochastic nature of demand.

This paper proposes a solution to DSM via an optimal BESS schedule that takes into consideration uncertainties in demand. The approach employs dynamic-interval density forecast (DIDF) to forecast the demand distribution profile a day ahead multiple times in a day horizon. Although the method and subsequent accuracy of the forecast greatly affects the performance of DSM, the specific method is beyond the scope of this study; the authors are preparing this topic for a separate work. In this paper, only the concept and format of DIDF are presented for application to the dynamic scheduling of a BESS. To this end, a dimension-reduction method, termed piecewise peak approximation (PPA), is developed to reduce the dimension of the demand probability distribution (DPD) obtained from DIDF for a faster computational time. The method captures the stochastic nature in demand by using stochastic optimization [17] to provide a robust BESS schedule while satisfying the technical constraint of maximizing BESS efficiency and life cycle. The proposed method is then applied to an actual environment in South Korea to verify the performance.

The rest of this paper is organized as follows. Section II describes the proposed approach to DSM via stochastic optimization. Section III discusses the problem formulation. Section IV elaborates on a case study and experimental evaluation of the proposed approach using data from a real site in South Korea. Finally, Section V provides a summary of this paper with spotlights on the main concepts and conclusions.

2. Proposed Approach: DSM Via Stochastic Optimization

This paper proposes a DSM solution made up of three modules. I. Dynamic-interval density forecast module, II. Dimensionality Reduction module, III. Stochastic optimization module

2.1. Dynamic-Interval Density Forecast

A density forecast is generated a day in advance based on empirical data as a probability distribution at each time instance in a day horizon. It is important to capture the uncertainties in demand. Most day-ahead forecast algorithms forecast a single value for each time instance in a day horizon, as shown in Figure 1(a). The problem with this approach is that, in practical applications, electric demand has uncertainties that need to be accounted for, as shown in Figure 1(b). When a deterministic forecast is used for DSM, it is expected that the forecasted demand will be equal to observed demand. When this is the case, the resulting BESS scheduled after design optimization is able to resolve the peak, as shown in Figure 2(a). On the other hand, when the observed demand deviates significantly from the forecasted demand, the BESS is unable to resolve the peak, as shown




Figure 1: Comparison between (a) deterministic and (b) probabilistic forecast models




Figure 2: Deterministic forecast and BESS schedule analysis (a) when forecast coincides with observed (b) when observed deviates from forecast

in Figure 2(b). Electric demand is a random variable that depends on many factors like weather, special events, and socioeconomic factors. The density forecast provides a good description of the uncertainty associated with a forecast and provides a forecast of probability distribution of demand at each time instance in the day horizon, as seen in Figure 3(a). We refer this as demand probability distribution (DPD) profile. The details of the forecast methods are out of the scope of this paper and it is to be considered in authors' another work.




Figure 3: (a) Demand forecast as a probability distribution (DPD), (b) Demand distribution forecast with confidence interval

As depicted in Figure 3(b), the probability distribution is generally narrow at the beginning of the forecast stages and becomes wider as it gets farther from the current moment. This phenomenon calls for re-forecasting to restore confidence in the forecast. In dynamic-interval forecasting, the forecast is performed multiple times in a day horizon in other to restore confidence in the forecast.

The notion is to forecast at wider intervals during the demand off-peak period and narrow intervals during demand peak periods. DIFD helps track the forecasted distribution with high accuracy because the confidence interval of the forecast is improved in the next forecast interval.

2.2. Dimensionality Reduction module

Because of the stochastic nature of the input data, many demand profile scenarios are possible. For example, given demand distribution samples at 15-min intervals in a day horizon, there are $n=96$ sample points, where n is the number of demand distributions in a day horizon. The number of possible demand profile scenarios that can arise from this setup is a^n , where a is the number of samples in each demand distribution. If there are $a=5$ samples in each demand distribution, the number of possible demand profile scenarios can be evaluated as 5^{96} , which is not feasible for real-time optimization even with a high-performance computer. A Monte Carlo simulation can be used to select plausible scenarios to follow the original demand distribution for a representational selection. However, the number of scenarios to select is a trade-off between accuracy and computational complexity. In real-time applications, time is of the essence; therefore, using dense or high-dimensional data will affect the execution time. From this perspective, it is prudent to perform dimensionality reduction of the data with high fidelity.

2.2.1. Time-Of-Use (TOU) Partitioning

This paper proposes a method to reduce the dimension of DPD to improve the computational time of the optimization algorithm. This is achieved by reducing the n samples in DPD to m samples. The value of m is influenced by partitions of the contracted TOU price in a day horizon. In Figure 4, a TOU policy of the Korean electric power company (KEPCO) is illustrated. Each partition has a different pricing policy with periods from late morning to afternoon tagged as peak times (red band and yellow), which have a higher price compared to that of early mornings and late evenings (green band). The partitions also vary depending on the current season [18]. A typical day horizon can be partitioned into $f = \{1, 3, 7, 8\}$, as shown in Figure 4.




Figure 4: KEPCO TOU daily partitions

The value of f depends on the day of week and season. $f = 1$ represents the number of partitions for Sundays in all seasons, $f = 3$ represents the number of partitions for Saturdays in all seasons, $f = 7$ represents the number of partitions for weekdays in spring or fall, and $f = 8$ represents the number of partitions for weekdays in winter or summer [18]. As established above, the maximum number of partitions possible in a day is $w = 8$. The value of the reduced dimension m is a trade-off between accuracy and computation speed. The minimum value that m can take is $m = 8$. When $f < w = m$ or $f \leq w < m$ a parameter c is introduced to pad f to reach m . c can be evaluated using (1).

$$c = \begin{cases} w - f, & f < w = m \\ m - f, & f \leq w < m \end{cases} \quad (1)$$

2.2.2. Piecewise Peak Approximation

Given a probability distribution forecast of demand, referred to as DPD, $X = \{d_1, d_2, \dots, d_n\}$, where d_i is the probability distribution forecasted at the i -th time instance, piecewise peak approximation (PPA) is performed after DPD is marked into m partitions following TOU. PPA is achieved by approximating all distributions that fall within a partition as a single distribution. The most common measure of central tendency used for such approximations is the average, as used in the deterministic case in [19] and [20]. This idea is also applicable in a stochastic case. However, since the peaking value is of the essence, using the average of demand distributions that fall in a partition could compromise the peak information. To carry the peaking feature, the distributions in a partition are approximated as the distribution with the maximum peak propensity, as illustrated in Figure 5(a) and Figure 5(b). The PPA produces a reduced demand probability distribution (RDPD) represented as $H = \{<\hat{d}_1, r_1>, <\hat{d}_2, r_2>, \dots, <\hat{d}_m, r_m>\}$, where \hat{d}_k is the distribution with the maximum peak propensity in the k -th partition, r_k marks the beginning of the $(k+1)$ -th partition and end of the k -th partition, with $k=1, 2, \dots, m$. r_k corresponds to potential points where TOU pricing changes occur. Preserving these price-change points during dimensionality reduction makes it convenient to apply the right TOU price during optimization.




Figure 5: (a) Converting distributions in a partition distribution to a single distribution using PPA
(b) Peak propensity or failure region of demand distribution

Algorithm 1 describes the PPA process.

Algorithm 1: PPA(X)

begin

1. $q = \text{TOU_band}(X)$

2. $c = (w - f)I\{w = m\} + (m - f)I\{m > w\}$

3. for $i=1$ to c

4. $Z = \text{max_sub_divide}(q)$

5. endfor

6. for each partition in Z, k

7. $H_k = \text{max_peak_propensity}(Z(k), Z(k-1), X)$

```
8.       $r_k = Z(k)$ 
```

```
9.      endfor
```

```
end
```

2.2. Stochastic Optimization

Stochastic programming is an approach for modelling optimization problems that involve uncertainty. Whereas deterministic optimization problems are formulated with known parameters, real world problems almost invariably include parameters which are unknown at the time a decision should be made. When the parameters are uncertain, but assumed to lie in some given set of possible values, one might seek a solution that is feasible for all possible parameter choices and optimizes a given objective function[17].

Stochastic optimization approaches the demand side management (DSM) problem by optimizing (minimizing) the total cost on average, $\min_{x \in X} E[f(D, x)]$, where x is the decision variable and D is demand as a random variable. Stochastic optimization evaluates the best cost and controls the peak demand for a given objective under demand uncertainties.

3. Problem Formulation

The objective of the proposed approach is to provide demand side management considering demand uncertainties. The algorithm performs probability distribution forecast at set intervals using empirical data. The demand probability distribution(DPD) produce after the forecast is dimensionally reduced for faster computation via piecewise peak approximation (PPA). The reduce demand probability distribution (RDPD) is used as input to the stochastic optimization in conjunction with energy tariff and parameter constraints which seeks a robust BESS schedule with a given objective while satisfying BESS's technical and efficiency constraints, as shown in Figure 6. The objective function of the stochastic optimization is divided into two parts:




Figure 6: Proposed system architecture

1. Energy Cost (TOU): this is computed at every time interval
2. Demand (Peak) Cost: this is evaluated at the end of every month

3.2. Energy Cost

The energy cost represents the amount of energy used within a period multiplied by the TOU energy price. In a distribution sense, the energy cost is the total expected demand multiplied by the TOU energy price, which can be evaluated using (2).

$$\text{Cost}^{TOU} = \sum_{k=1}^m g_k \times C_k^{TOU} \quad (2)$$

$$g_k = E[\hat{d}_k + e_k] \quad (3)$$

187 where \hat{d}_k is the k -th distribution in RDPD, e_k is the BESS schedule provided at the k -th instance by
 188 the optimization algorithm, C_k^{TOU} is the TOU energy price at the k th instance, g_k is the expected
 189 demand of the k -th distribution in RDPD, and Cost^{TOU} is the total expected cost of energy in a
 190 day.

191 3.2. Demand Cost

192 The demand cost is the maximum 15-min average power over a month multiplied by the
 193 demand price. This is evaluated using (4). The demand cost and energy cost must be unified.
 194 Normally, the demand cost is evaluated monthly, whereas the energy cost is calculated at a unit time
 195 interval. Because of this difference in units, the demand cost needs to be evaluated correctly at unit
 196 time intervals such that the accumulated demand cost over a month is equal to the monthly demand
 197 cost, as expressed by (8). The unified daily demand cost can be evaluated using (9).

$$\text{Cost}^D = D_{\max} \times C^D \quad (4)$$

$$D_{\max} = \|H_1^{\max}, H_2^{\max}, \dots, H_q^{\max}\|_{\infty} \quad (5)$$

$$H_l^{\max} = \|h_{l1}, h_{l2}, \dots, h_{lm}\|_{\infty} \quad (6)$$

$$h_{lk} = \begin{cases} Pl \times P(\hat{d}_{lk} + e_k), & (\hat{d}_{lk} + e_k) < Pl \\ (\hat{d}_{lk} + e_k) \times P(\hat{d}_{lk}), & (\hat{d}_{lk} + e_k) > Pl \end{cases} \quad (7)$$

$$\text{Cost}^D = \sum_{l=1}^q \| \{h_{lk}\}_{k=1}^m \times C^U \|_{\infty} \equiv D_{\max} \times C^D \quad (8)$$

$$\text{Cost}^d = \| \{h_{lk}\}_{k=1}^m \times C^U \|_{\infty} \quad (9)$$

$$C^U = \left(\frac{C^D}{q} \right) / m \quad (10)$$

$$q = \begin{cases} 28, & \text{Feb} \\ 29, & \text{Feb(leap year)}, \\ 30, & \text{Sept, Apr, Jun, Nov} \\ 31, & \text{Otherwise} \end{cases} \quad (11)$$

198 where C^D is demand price for a month, H_l^{\max} is the maximum demand on the l -th day, D_{\max} is
 199 maximum demand for a month, h_{lk} is the peak demand distribution at instance k on the l -th day,
 200 \hat{d}_{lk} is the demand distribution at an instance k in RDPD on l -th day, Pl is the peak demand limit, $P(\cdot)$

is a probability function, C^U is the unified demand price at any instance in a day, Cost^D is the monthly demand cost, Cost^d is the unified daily demand cost, q is the number of days in a month, with $l = 1, 2, \dots, q$.

By KEPCO policy, the demand value used to evaluate demand cost is obtained using (7); thus, if the current recorded demand is greater than the Pl , the recorded demand value is used in calculating the cost. If the recorded demand is less than the Pl , the value of the Pl is used to compute the cost. This is evaluated to achieve peak demand control.

3.3. Optimization

The objective function of the stochastic optimization is formulated as the ensemble of energy cost and demand cost (EC) (12). The design optimization algorithm provides BESS control schedule candidates at each iteration of the optimization process, $u_x = e_1, e_2, \dots, e_m$, based on conditions established as constraints to the objective function, where u_x is the x -th BESS control schedule, e_k is the BESS value scheduled at the k th instance in u_x , $x = 1, 2, \dots, s$, s is the number of iterations via the optimization algorithm.

For each u_x , the ensemble of energy cost and demand cost is evaluated, this is evaluated as the minimum of both parameters. This is repeated for each iteration of the BESS control sequences until the one with the least cost on average is found. The objective function for the stochastic optimization is formulated as (14).

$$EC = f(H, u_x) \quad (12)$$

$$f(H, u_x) = \min\left(\sum_{k=1}^m \text{Cost}_k^{TOU}, \text{Cost}^d\right) \quad (13)$$

$$\arg \min_{u_x} f(H, u_x) \quad (14)$$

An inequality constraint is imposed on the objective function such that the state of the charge (SOC) of the BESS at the beginning of a day should be the same as that at the end of the day (15). Furthermore, the SOC of the BESS should be in the range of SOC_{\max} and SOC_{\min} , thus maximum and minimum SOC, respectively as expressed by (16).

$$\text{SOC}_0 = \text{SOC}_{\text{final}} \quad (15)$$

$$\text{SOC}_{\min} \leq \text{SOC}_k \leq \text{SOC}_{\max} \quad (16)$$

$$\text{SOC}_k = \text{SOC}_{k-1} + e_k \frac{\gamma}{S_{\text{BESS}}} \quad (17)$$

$$\gamma = \text{eff}^{ch}, \gamma = \frac{1}{\text{eff}^{dch}}, \quad (18)$$

where SOC_k is the SOC at instance k ; SOC_0 and $\text{SOC}_{\text{final}}$ are the initial and final SOC respectively, γ is the efficiency of BESS, eff^{ch} and eff^{dch} are the charge and discharge efficiency respectively. The constraints guarantee that the optimization returns feasible solutions.

4. Case Study

In this section, the proposed approach is implemented with a case study and simulated for results. For the case study, 2016 and 2017 data from a real-site in South Korean was obtained. The data is recorded at an interval of 15 min in a day horizon, because of KEPCO's policy of recording peak demand in 15-min intervals. The 2016 data is used for the daily interval forecast for 2017. The 2017 forecast data is used to implement the DSM algorithm, and the observed data is used for testing and result analysis.

By convenience, a density forecast of 250 elements per each distribution is used. Dynamic-interval density forecast (DIDF) is performed following TOU partitions in a day horizon to obtain demand probability distribution (DPD). DPD of n dimensional space is reduced to m dimensional space which is referred to as a reduced demand probability distribution (RDPD) via PPA for stochastic optimization. During peak times, the forecast is performed after every 15-min interval, whereas at off-peak times, the forecast is made on the order of hour intervals, followed by 2 hours, 3 hours, etc., depending on the size of the off-peak interval. Stochastic optimization is performed using RDPD. Particle-swarm optimization (PSO) [21] with a swarm size of 500, inertia of 0.6, and 200 iteration is used to implement the stochastic optimization procedure using the parameters in Table I at intervals following DIDF. TOU pricing is based on data from KEPCO [18].

Table 1 shows the parameters used for the case study. The simulation was realized in MATLAB 2014 on an Intel i5 processor with 16 GB of RAM. On average, it takes 55 s to complete a single run of the stochastic optimization.

Table 1. Simulation parameters

Parameters	Symbols	Symbols
Peak demand limit	Pl	6610 kW
BESS capacity	S_{BESS}	500 kWh
BESS efficiency	γ	90%
Initial SOC	soc_0	0.2
Maximum/Minimum SOC	soc_{max} / soc_{min}	0.9/0.2
Number of sample points	m	24
Number of distributions in a day,	n	96
Number of samples in a distribution	a	250

Figure 7 and Figure 8 present the results of the robust BESS schedule as applied to the expected demand. The results also show a comparison of the expected demand under the BESS schedule as well as when the BESS is absent. Each figure presents the expected demand, SOC of BESS as well as the cost for expected demand when the BESS schedule is applied and when it is not. At the beginning of the day, BESS starts operation from the minimum SOC value, and the same value is maintained at the end of the day. The optimal BESS schedule obtained after stochastic optimization is verified against the most probable demand of the distribution. Figure 7(a) presents a stochastic optimization algorithm considering only energy arbitrage. It can be observed that the BESS discharges heavily during the critical TOU periods (peak times), indicated by the red band, because the TOU price is high during this period. As such, it discharges prior to charging to full capacity during the off-peak period, in which TOU price is cheaper. Figure 7(b) shows the result where the algorithm considers only the peak demand cost. Figure 8 presents the results where the algorithm considers both the peak demand cost and energy arbitrage. In Figure 7(b) and Figure 8, the BESS schedule discharges heavily during the peak periods from 10 am to 2 pm to resolve the demand peak exceeding the peak limit.




Figure 7: (a) DSM algorithm results considering only energy arbitrage (b) DSM algorithm results considering only peak demand control




Figure 8. DSM algorithm results considering energy arbitrage and peak demand control

From Table II, it can be observed that implementing the algorithm considering only energy arbitrage cost performs poorly in terms of peak reduction, but it is the best in terms of cost reduction. This is because it seeks only to reduce cost and not peak demand. With a previous peak value of 1763 kW, the algorithm causes a new peak of 2072 kW, representing a 18% increment in peak. In contrast, it provides the best yearly cost reduction of ₩35,296,338 in 2017. When the algorithm features only peak control, it is able to reduce the peak from 1763 kW to 1330 kW, which is a peak reduction of 26% and a yearly cost reduction of ₩2,937,306.

An ensemble of energy arbitrage and peak control seeks to harness the benefit of the two algorithms; as such, the results show a reduction of 1308 kW in peak, representing a 26% decrease and a yearly cost reduction of ₩9,636,600.


Although implementing energy arbitrage alone provides the best energy cost, it also results in the worst peak control. The peak control case also has a good peak demand reduction, but also the worst yearly cost reduction. A combination of the two presents a compromise between these two factors to achieve a better cost and the best cost reduction.

281 Table 2. Simulation results

Parameter		Value
Original Peak (Without BESS)		1763 kW
New Peak (With BESS)	Energy arbitrage	2072 kW
	Peak Control	1330 kW
	Ensemble	1308 kW
Peak Reduction	Energy arbitrage	-18 %
	Peak Control	25 %
	Ensemble	26 %
Original Cost (Without BESS)		₩ 235,084,438
Yearly Cost Reduction (With BESS)	Energy arbitrage	₩ 35,296,338
	Peak Control	₩ 2,937,306
	Ensemble	₩ 9,636,600
Yearly Cost Reduction	Energy arbitrage	15 %
	Peak Control	1 %
	Ensemble	4%

282 5. Discussion

283 The proposed demand side management algorithm is compared with a deterministic
284 optimization (DO) method using a deterministic day ahead forecast which is predominantly
285 proposed in other research. The deterministic approach forecasts a day ahead demand profile which
286 is used to evaluate an optimal BESS schedule for the next day, as shown in Figure 9(a).



287 Figure 9. (a) Day ahead forecast and observed demand, (b) BESS schedule on forecasted demand
288 using DO

289 Figure 10(b) shows the forecasted demand and the effect of the subsequent BESS schedule that
290 was generated from the optimization algorithm. From the figure it can be observed that although the
291 peak demand is reduced, the reduction strictly follows the peak limit. The peak is reduced from
292 1518kW to 1370kW representing a 9.8% reduction.

293 Figure 10(a) shows the results of the BESS schedule obtained from the optimization algorithm
294 as applied to the observed demand. It can be observed that the BESS schedule generated fails to
295 reduce the peak demand because of inaccuracies in the forecast as compared to the observed
296 demand. The BESS schedule rather increases the peak from 1563kW to 1624kW, representing a 3.8
297 increase in peak demand.

298 Figure 10(b) show the results when the proposed real-time demand side management solution
299 is applied to the observed demand. It can be observed that the real time algorithms perform better
300 since the dynamic interval density forecast, reforecast the demand at set intervals to correct the

deviation in forecast. The approaches is able to reduce the peak demand from 1563kW to 1236kW representing a 20.9% reduction.




Figure 11. (a) BESS schedule on observed demand using DO (b) BESS schedule on observed demand using proposed approach.

6. Conclusion

This paper has proposed a DSM solution that incorporates a dynamic interval density forecast with a piecewise peak approximation for stochastic optimization.

The DSM solution has been verified using demand data from a real industrial site in South Korea. The results show that energy arbitrage alone cannot reduce the peak demand. In the case where the algorithm implements only energy arbitrage, a peak increase of 18% was incurred. When the algorithm implements an ensemble of energy arbitrage and peak demand cost, the peak demand is reduced by 26%. Unlike the deterministic case, where the forecast is performed once in a day horizon, the proposed solution performs the forecast at set intervals in a day horizon to restore confidence in the forecast should it deviate. This ensures a much more accurate forecast and a robust BESS schedule. For verification the proposed demand side management algorithm is compared to a deterministic algorithm, the proposed method achieves 20.9% in peak reduction while the deterministic case achieves 9.8%. This real-time algorithm is applicable to industrial or commercial settings.

Acknowledgments: This work was supported by Korea Electric Power Research Institute (KEPRI) belonging to Korea Electric Power Corporation (KEPCO) for the project no. R16DA01.

Author Contributions: S.H conceived and supervised the work, M.A.K. designed, performed the experiments and wrote the paper. D.K proof read the paper.

Conflicts of Interest: The authors declare no conflict of interest

References

[1] L. Gelazanskas and K. A. A. Gamage, "Demand side management in smart grid: A review and proposals for future direction," *Sustain. Cities Soc.*, vol. 11, pp. 22–30, 2014.

[2] A. A. Akhil *et al.*, "DOE/EPRI Electricity Storage Handbook," no. February, 2015.

[3] G. J. Tsekouras, F. D. Kanellos, and N. Mastorakis, "Computational Problems in Science and Engineering," vol. 343, 2015, pp. 19–59.

[4] G. Aneiros, J. Vilar, and P. Raña, "Short-term forecast of daily curves of electricity demand and price," *Int. J. Electr. Power Energy Syst.*, vol. 80, pp. 96–108, 2016.

- 332 [5] G. M. Khan, S. Khan, and F. Ullah, "Short-term daily peak load forecasting using fast learning
333 neural network," *2011 11th Int. Conf. Intell. Syst. Des. Appl.*, pp. 843–848, 2011.
- 334 [6] P. K. Dash, H. P. Satpathy, and A. C. Liew, "A real-time short-term peak and average load
335 forecasting system using a self-organising fuzzy neural network," *Eng. Appl. Artif. Intell.*, vol.
336 11, no. 2, pp. 307–316, 1998.
- 337 [7] E. A. Feinberg and D. Genethliou, "Peak demand control in commercial buildings with target
338 peak adjustment based on load forecasting," *Appl. Math. Power Syst.*, no. September, pp.
339 269–285, 2005.
- 340 [8] M. Dabbagh, B. Hamdaoui, A. Rayes, and M. Guizani, "Shaving Data Center Power Demand
341 Peaks Through Energy Storage and Workload Shifting Control," *IEEE Trans. Cloud Comput.*,
342 vol. 7161, no. c, 2017.
- 343 [9] Q. Lin, M. Yin, D. Shi, and H. Qu, "Optimal Control of Battery Energy Storage System
344 Integrated in PV Station Considering Peak Shaving," *Chinese Autom. Congr. (CAC)*, 2017, pp.
345 2750–2754, 2017.
- 346 [10] C. Lu, H. Xu, X. Pan, and J. Song, "Optimal sizing and control of battery energy storage
347 system for peak load shaving," *Energies*, vol. 7, no. 12, pp. 8396–8410, 2014.
- 348 [11] K. Cho, S. Kim, J. Kim, E. Kim, Y. Kim, and C. Cho, "Optimal ESS Scheduling considering
349 Demand Response for Electricity Charge Minimization under Time of Use Price Key words,"
350 no. 14, pp. 264–267, 2016.
- 351 [12] F. Q. Elizabeth, T. X. Nghiem, M. Behl, R. Mangharam, and G. J. Pappas, "Scalable
352 Scheduling of Building Control Systems for Peak Demand Reduction," *Am. Control Conf.*, pp.
353 3050–3055, 2012.
- 354 [13] T. X. Nghiem, M. Behl, R. Mangharam, and G. J. Pappas, "Green scheduling of control
355 systems for peak demand reduction," *Proc. IEEE Conf. Decis. Control*, pp. 5131–5136, 2011.
- 356 [14] G. Carpinelli, S. Khormali, F. Mottola, and D. Proto, "Optimal operation of electrical energy
357 storage systems for industrial applications," *IEEE Power Energy Soc. Gen. Meet.*, pp. 1–5, 2013.
- 358 [15] G. Carpinelli, G. Celli, S. Mocci, F. Mottola, F. Pilo, and D. Proto, "Optimal Integration of
359 Distributed Energy Storage Devices in Smart Grids," *IEEE Trans. Smart Grid*, vol. 4, no. 2, pp.
360 985–995, 2013.
- 361 [16] E. Chiodo and D. Lauria, "Probabilistic description and prediction of electric peak power
362 demand," *Electr. Syst. Aircraft, Railw. Sh. Propulsion, ESARS*, 2012.
- 363 [17] A. Shapiro and A. Philpott, "A tutorial on stochastic programming," *Manuscript. Available*
364 *www2.isye.gatech.edu ...*, pp. 1–35, 2007.
- 365 [18] S. June and S. Mar, "Korea Electric Power Corporation Tariff," 2013.

- 366 [19] E. Keogh, K. Chakrabarti, M. Pazzani, and S. Mehrotra, "Dimensionality Reduction for Fast
367 Similarity Search in Large Time Series Databases," *Knowl. Inf. Syst.*, vol. 3, no. 3, pp. 263–286,
368 2001.
- 369 [20] K. Chakrabarti, E. Keogh, S. Mehrotra, and M. Pazzani, "Locally adaptive dimensionality
370 reduction for indexing large time series databases," *ACM Trans. Database Syst.*, vol. 27, no. 2,
371 pp. 188–228, 2002.
- 372 [21] J. Kennedy and R. Eberhart, "Particle swarm optimization," *Neural Networks, 1995.*
373 *Proceedings., IEEE Int. Conf.*, vol. 4, pp. 1942–1948 vol.4, 1995.