

Article

Not peer-reviewed version

Numerical Analysis of Inlet-Outlet Leg Barriers in Vertical Borehole Heat Exchangers: A Strategy to Mitigate the Thermal Resistance

[Asfia Nishat](#) * and [Hossam Abuel-Naga](#)

Posted Date: 7 January 2025

doi: 10.20944/preprints202411.1508.v2

Keywords: Ground source heat pump; ground source heat exchanger; vertical ground source heat pump; borehole heat exchanger; heat transfer for ground source heat pump; borehole thermal resistance; thermal short-circuiting in borehole heat exchanger



Preprints.org is a free multidisciplinary platform providing preprint service that is dedicated to making early versions of research outputs permanently available and citable. Preprints posted at Preprints.org appear in Web of Science, Crossref, Google Scholar, Scilit, Europe PMC.

Copyright: This open access article is published under a Creative Commons CC BY 4.0 license, which permit the free download, distribution, and reuse, provided that the author and preprint are cited in any reuse.

Article

Numerical Analysis of Inlet-Outlet Leg Barriers in Vertical Borehole Heat Exchangers: A Strategy to Mitigate the Thermal Resistance

Asfia Nishat ^{1,*} and Hossam Abuel-Naga ²

¹ Research candidate, School of Computing, Engineering and Mathematical Sciences, La Trobe University, Victoria 3086 Australia

² Professor, Head of Engineering Department, La Trobe University Victoria 3086 Australia

* Correspondence: asfianishat@hotmail.com

Abstract: The efficiency of heat transfer through borehole heat exchangers is influenced by the thermal resistances of both the borehole and the surrounding soil. Optimizing these resistances can improve the heat transfer performance and reduce system costs. Soil thermal resistance is geographically specific and challenging to reduce, according to previous research. In contrast, borehole resistance can be minimized through practical approaches, such as increasing the thermal conductivity of the grout or adjusting the shank spacing in the U-tube configuration. Previous literature also suggests coaxial pipes as more efficient design than single U-tube borehole heat exchanger. A novel approach involves inserting a barrier between the U-tube's inlet and outlet legs, though a limited literature exists on its unique contribution to reduce thermal resistance. Using FlexPDE software, the study numerically assesses the sole contribution of barrier in mitigating borehole resistance. The study examines the effects of different barrier geometries and materials, considering various grout and soil thermal conductivities as well as shank spacing configurations. The study suggests that the barrier technique is an effective solution for optimizing U-tube borehole heat exchangers, especially with reduced shank spacing and lower thermal conductivity soil. It can reduce the length of a U-tube borehole by up to 8.1m/kW of heat transfer offering a viable alternative to increasing shank spacing in the U-tube borehole or enhancing thermal conductivity of the grout. Moreover, under specific conditions of soil and grout with low to medium thermal conductivity, U-tube borehole heat exchanger with a barrier between the legs demonstrates a reduction of up to 43.4m per kW heat transfer (22.7%) in overall length compared to coaxial pipes.

Keywords: Ground source heat pump; ground source heat exchanger; vertical ground source heat pump; borehole heat exchanger; heat transfer for ground source heat pump; borehole thermal resistance; thermal short-circuiting in borehole heat exchanger

1. Introduction

Closed loop vertical ground source heat pumps are notably widespread for their efficiency and effectiveness compared to other ground source heat pump types like horizontal closed loop, direct exchange, open loop, and surface water ground source heat pumps [1]. One of their key advantages is the compact footprint of the heat exchanger in the form of a borehole, which makes them especially suitable for residential areas with small plots and commercial buildings [1]. They also ensure stable ground temperature and demand minimal pumping energy [1]. However, the system does have drawback of requirement for a deep borehole drilling which contributes to a higher cost and challenges related to expertise in borehole drilling and proper implementation [1,2].

Typically, water (or a mixture of water and antifreeze in below-freezing soil conditions) circulates on one side of the ground source heat exchange system, while refrigerant circulates on the other side, directly connected to the heat pump. According to ASHRAE-Applications [3], U-tube

boreholes typically range from 100-150mm in diameter and have depths of 15-120 meters. U-tube borehole length can be further increased to 180m or more if the procedures for deep boreholes are followed. A U-tube containing the circulating fluid is inserted into each borehole, typically made of polyethylene with a diameter of 20-40 mm, although other pipe materials may also be utilized [3]. Figure 1(a) and Figure 1(b) illustrate the U-pipe arrangement.




Figure 1. Schematic diagram showing BHX; (a & b) Plan & section for U-tube arrangement; (c & d) Plan & section for Coaxial pipe arrangement with inflow through annular pipe.

An alternative to U-tube boreholes is coaxial pipe arrangement where a smaller pipe (the inner pipe) is enclosed within a larger outer pipe. The heat transfer fluid can be circulated in two ways. One way is to enter the fluid through the outer pipe (inlet pipe) and return the fluid via inner pipe (outlet pipe). The other flow arrangement is to enter the fluid via inner pipe (inlet pipe) and return the fluid via outer pipe (outlet pipe). Figure 1(c) and Figure 1 (d) illustrate the coaxial pipe arrangement with inflow through the annular pipe.

Usually the space between the U-tube/ coaxial pipe and the borehole wall is filled with grout, which serves a crucial role in stabilizing the U-tube/ coaxial pipe within the buried system and in preventing water seepage into the borehole. BHX cost (which is mainly the cost of U-pipe, grout and borehole drilling) for GSHP typically accounts for more than 30% of the total cost of the GSHP system [4] Given its significant expense, optimizing this component is vital for enhancing heat transfer efficiency and for harnessing more sustainable energy from the same area of the land.

The total thermal resistance consists of two parts: the soil itself and the borehole as shown in Figure 2. In a conventional U-tube BHX having a geometrical symmetry of the inlet and outlet legs, the fluid temperature to be considered for the evaluation of borehole thermal resistance is the mean temperature of the inlet and outlet fluid temperatures [5].

$$T_f = \frac{T_{fi} + T_{fo}}{2} \quad (1)$$




Figure 2. Thermal resistance network for U-tube BHX.

The borehole resistance component includes the resistance offered by grout, pipe material, and the circulating fluid. Contact thermal resistance is assumed to be negligible for simplification. The total thermal resistance is the sum of soil and borehole resistance.

$$R_t = R_b + R_s \quad (2)$$

Reduction in any of the above two components or both will lead to an improved heat transfer. The heat transfer resistance characteristics of soil vary with geographic location and are generally immutable. Deep soil mixing offers a viable method to lower soil thermal resistance, yet its implementation is expensive and may not be economically feasible across all site conditions and soil types [6]. On the other hand, there are methods to decrease R_b i.e., BHX thermal resistance. Therefore, the overall thermal resistance of the system can be reduced for an enhanced heat transfer by adopting techniques to lower the BHX thermal resistance.

Increasing the length of the ground loop in a BHX reduces the approach of BHX defined as the difference between average loop temperature T_f and the initial ground temperature T_s .

$$Approach = T_s - T_f \quad (3)$$

$$T_f \rightarrow T_s, \text{ as } L \rightarrow \infty \quad (4)$$

Reducing the thermal resistance between the ground and the circulating fluid enhances the heat transfer, thereby reducing the required length of the heat exchanger per kW for a given approach.

Previous research on the optimization of borehole thermal resistance has investigated the impact of pipe material, borehole diameter, shank spacing, and grout material. Research by Kerme et al. [7] discusses various geometric factors (shank spacing, borehole size/diameter, borehole depth), grout and soil thermal conductivity for single and double U tube arrangements and then proposes the combined effective measures for heat transfer improvement. Shen et al. [8] discusses the various influential factors (such as flow rate, inlet temperature, heat extraction rate, length of BHX and backfill material) on the performance of deep U-tube BHX and suggest an optimal control of flow rate.

According to Kavanaugh and Rafferty [2] the choice of thermally enhanced grout material is also challenging. The grout filler must block surface water and unwanted groundwater from reaching aquifers, as they can pollute drinking or irrigation supplies. High-solids sodium bentonite grout (>20% solids), while effective, is a poor heat conductor, whereas materials with good heat transfer may allow water migration. Some regulations may permit porous materials if the top 6 meters of the borehole are sealed with a nonporous grout. Cement-based sealants are ineffective for BHX due to pipe shrinkage but can be enhanced with additives. Pouring of thermally enhanced grout with

abrasive sand might also be challenging due to unavailability of the pumping equipment with the installer.

Erol and François [9] studied various BHE grout materials, including bentonite-based, silica sand-based, and homemade admixtures with graphite. Increasing graphite content beyond 5% or using all types of graphite powders in BHE backfill mixtures is impractical, as graphite's varying properties can negatively affect grout flowability, permeability, and strength. By TRT test, they found that adding just 5% homemade natural flakes graphite enhances grout thermal conductivity, crucial for optimizing heat transfer efficiency when matched appropriately to ground conductivity.

Study by Mahmoud et al. [10] suggests that selecting the right grout depends on system conditions. Traditional grouts like bentonite and cement offer strength but require additives for better thermal performance. Phase change material (PCM) is recommended for its storage capacity and stability. A mix of conventional grouts, additives, and PCMs is recommended for optimal results.

Liu et al. [11] conducted a comprehensive study to assess potential cost reductions through enhancements in borehole heat transfer under diverse geological and thermal conditions and revealed that improvements such as enhanced grout and double U-tube loops effectively reduce borehole lengths. The study primarily focuses on installation costs and relies on the simplified geometrical approach of Eskilson's g-function through commercial software.

Research work is also available on comparison of U-tube with coaxial pipe and a few other arrangements like double U-tube, discussing the thermal behavior of the BHX with these arrangements. Study made by Zanchini et al. [12] showed that in coaxial pipes, the configuration where water flows into the BHX through the outer annular pipe and exits through the inner pipe provides superior thermal performance compared to the opposite arrangement, where inflow occurs through the center or inner pipe and outflow through the outer annular portion. Brown et al. [13] modelled coaxial, single U-pipe and double U-pipe configurations, finding coaxial pipes exhibiting highest heat transfer rate and lower pressure drop. Harris et al. [14] demonstrated that the coaxial BHX configuration is more effective than the double U-pipe design. According to Chen et al. [15], by using double U-tubes in parallel in BHXs, the heat transfer capacity may increase by over 50% from the single U tube system which could justify the cost increase in installation and pumping energy consumption. Chen and Tomac [16] suggest use of VIT (Vacuum Insulated Tube) for coaxial pipe arrangement to prevent thermal short-circuiting. An economic analysis is suggested as the cost of VIT is 5 times more than the cost of un-insulated tubing.

While there is an ample research work available on the comparative study of materials and geometry of the U-tube BHX and its comparison with the other arrangements like coaxial pipes and double U-tube, there is not much research work on segregating the inlet and outlet leg of the U-tube to prevent them from a direct interaction with each other.

Al-Chalabi [6] investigated the effects of introducing I-shape and U-shape obstructions in a U-tube BHX. However, the study did not account for the thickness of the U-tubes, which led to extremely overestimated efficiency of the barriers compared to scenarios where tube thickness is considered. In addition, the study is limited to the highly thermally conductive grout with a ratio k_g/k_s of 2, and does not provide an insight into the various alternatives of the grout and soil. The results are reported in terms of the borehole thermal resistance instead of an overall thermal resistance. High thermal conductivity grout results in a lower contribution of the BHX thermal resistance out of the total thermal resistance of the soil and BHX. Therefore, there is a need to report the net impact of the saving in terms of an overall reduction in the total thermal resistance or borehole length or an overall increase in the heat transfer.

Ngo and Ngo [17] conducted a numerical assessment to evaluate the impact of an insulated flat shape barrier between the U-tube legs of ground heat exchanger. The study examines the effects of Reynolds number on heat transfer, focusing on laminar flow with a low Reynolds number value (optimal heat transfer at Reynolds number of 120 and suggests that at lower Reynolds number values, heat transfer increases due to a decrease in the outlet temperature (T_{fo}) for a given inlet temperature

(T_{fi}), though it does not address the impact of reduced mass flow rate on the heat transfer as a result of lower Reynolds number value. The heat rejected by the fluid for cooling will be as follows [2]:

$$Q = -m_f \times c_p \times (T_{fi} - T_{fo}) \quad (5)$$

The expression for Reynolds number is as follows [18].

$$Re = \frac{\rho \times V \times D_h}{\mu} = \frac{m_f \times D_h}{A_c \times \mu} \quad (6)$$

The above equation depicts that the mass flow rate of the fluid is a function of Reynolds number. Under the given geometry and fluid temperature, the Reynolds number varies directly proportional to the mass flow rate of the fluid, which means the more the mass flow rate, the more will be the Reynolds number for a given geometry and fluid temperature. In case of turbulent flow through pipes, the Reynolds number is $\geq 10,000$ [18]. Ngo study with Reynolds number of 120 will have a significantly lower flowrate through the same geometry than the flow conditions considered in other studies with turbulent flow. The study does not very clearly state the pipe material considered in the study, however mentions that their study reports high efficiency operation with 16% enhanced heat transfer when copper pipe is used instead of high-density polyethylene. It is therefore understood that they have conducted a study based on copper pipes. Previous studies suggest that use of HDPE pipes is very common due to better performance, durability and economics [2,19–21]. The assumption of copper piping with laminar flow within the U-tube could increase the risk of thermal short-circuiting than that with high density polyethylene pipe [2]. Due to more short-circuiting, the results of improved heat transfer due to barrier between the inlet & outlet pipe will be misleading. Thickness of the pipe is also neglected which will overestimate the performance of the barrier. Because the study is not based on optimal parameters, there is a potential to increase the heat transfer further by improving the flow rate and pipe material. Measures to improve these parameters will result in a change in the reported impact of the barriers in the study, which warrants further analysis to draw definitive conclusions.

Previous studies about grout material have suggested that grout selection for better thermal conductivity might be challenging and may be compromised for the strength of the BHX and/or economy. The study of the novel technique of barriers between the two legs of BHX for optimization of heat transfer is required to be explored as an alternative to conventional way of increasing the heat transfer by thermally enhanced grout. The technique can also be applied in addition to the conventional methods to further increase the heat transfer. There is a need for a detailed evaluation of the thermal performance of the barrier between the two legs of a U-tube BHX, with a specific comparison to a conventional U-tube system. Due to complexity of the BHX geometry, numerical assessment would be more appropriate. Flat plate and U-shape geometries of the barrier are to be studied with various materials and thickness. The design parameters of BHX geometry and flow are to be optimized before evaluating the effect of barrier. Comparison to be made with a focus to depict the sole contribution of barrier from the base case. It is also required to report the results of an overall impact in terms of net increase in heat transfer or net reduction in the BHX length. This would allow for a clearer assessment of the barrier's unique contribution in optimizing the BHX length and will help implementing the barrier technique where they contribute to the enhancement of heat transfer through the BHX. Additionally, it would be beneficial to compare the results of numerical assessment for barrier techniques with other heat transfer enhancement techniques, such as coaxial pipe arrangements, to offer a broader selection of borehole heat exchanger (BHX) design options.

2. Methods

A traditional single U-tube heat exchanger was numerically assessed and validated for different combinations of shank spacing and grouts. A coaxial pipe BHX was also assessed to see the improvements in efficiency of the heat transfer in the BHX with coaxial pipe arrangement compared to a traditional single U-tube BHX. Next investigation was to see the effects of novel techniques of different barriers/ obstructions between the two legs of a U-tube BHX and comparison of the resulting improvement. Numerical assessment was done on FlexPDE software version 6.51, a finite element model builder and solver.

2.1. Model Assumptions and Governing Equation

The analysis was performed for a single BHX under steady-state heat transfer. The heat transfer inside the borehole for longer time steps can be considered as steady-state heat transfer within that time step [22]. The lower limit of the time step is 5 times r_b^2/α , which is usually a few hours for different soils and borehole sizes [5,22]. Similarly, a radial steady-state approximation for the small annulus of the soil near the borehole gives an error of less than 0.3% in determining the resistance of the soil outside the borehole [22]. Thus, for a time efficient model, we conclude that it is appropriate to consider steady-state heat transfer both inside and outside the borehole.

Homogeneous ground condition is considered in the analysis as a simplification assumption [5]. With the assumptions of steady-state heat flow and homogenous ground material, a two-dimensional model can effectively capture the essential heat flow characteristics in the material and is therefore considered for the analysis.

A far-field radius is the radius of influence and beyond it, the temperature of the soil remains un-disturbed [23]. According to the study made by Ruan, the soil within 0.5 meters of the borehole reacts to the short-term heat flux from the ground to the fluid. In contrast, the area beyond 0.5 meters is primarily influenced by the long-term net energy input into the ground heat exchange system. After 1 meter from the center of the borehole, there is no significant change in the mean fluid temperature [24]. We therefore based our analysis for a far-field radius of 1 meter.

No contact resistance, no moisture migration through the soil, homogenous grout & pipe materials, water as a fluid and winter heating mode are considered in the analysis.

Fourier's law of heat conduction is as follows [25].

$$Q = -kA\nabla T \quad (7)$$

The transient heat transfer equation in three dimensional cartesian coordinate system is as follows [25].

$$\left(\frac{\partial^2 T}{\partial x^2}\right) + \left(\frac{\partial^2 T}{\partial y^2}\right) + \left(\frac{\partial^2 T}{\partial z^2}\right) = \left(\frac{1}{\alpha}\right)\left(\frac{\partial T}{\partial \tau}\right) - \left(\frac{q_{\text{gen}}}{k}\right) \quad (8)$$

The steady state two-dimensional equation in cartesian coordinates reduces to the following expression which shall be the governing equation in this study which is expressed as follows [25].

$$\left(\frac{\partial^2 T}{\partial x^2}\right) + \left(\frac{\partial^2 T}{\partial y^2}\right) = 0 \quad (9)$$

2.2. Analysis for Traditional Single U-Tube Borehole Heat Exchanger

Figure 3 describes the geometry of the U-tube model. Far-field boundary is not shown here to represent an enlarged view of the borehole for clarity. Refer to **Figure 1** to see the far-field boundary.




Figure 3. U-tube BHX model geometry.

The size and material of U tube and borehole diameter are in accordance with the recommendations in ASHRAE-Applications [3]. Heating mode for winter operation of the GSHP is considered. For a better efficiency, the outlet temperature of the fluid in heating mode should be 5°C to 8°C less than the undisturbed ground temperature. [2]. ΔT of 4°C to 3°C is adopted for water as a fluid to keep the cost and pumping energy within reasonable limits [2]. The soil temperature taken is an approximation used to represent a range of Australian soils where the average geothermal ground temperatures are from 14°C to 18°C [26–28]. Soil thermal conductivity of 0.5 to 2 W/m.K also represents various soil conditions in Victoria, Australian Capital Territory and the near-by areas of New South whales [29,30]. The grout materials are considered to represent a variety of grouts with or without a filler material to enhance their thermal conductivity. Neat cement grout with water-to-cement ratio of 0.6 has a thermal conductivity of 0.585 W/m.K after drying, whereas grouts with thermal conductivity of 1 & 2 W/m.K represent thermally enhanced cement grouts with a combination of filler materials [31]. The description of shank spacing is shown in **Figure 4** and covers the whole range of possible shank spacing from minimum to maximum in a symmetrical configuration with pipes in the center of the borehole. To estimate the convective heat transfer coefficient, the flow rate of 0.642 L/s (10.2 USgpm) which is a fully developed turbulent flow under the considered geometry of the U-tube is considered. The properties of water are taken from [32].




Figure 4. Various shank spacings of U-tube BHX model.

Reynolds number is calculated from Equation (6). Calculation of Nusselt number and convective heat transfer coefficient is from the following equations [18].

$$Nu = 0.023 Re^{0.8} \times Pr^{0.4}$$

(10)

$$h = (Nu \times k)/D_h$$

(11)

Correlation in Equation (10) is valid for forced convection in fully turbulent flow (condition met when $Re \geq 10,000$ for flow in pipes) and is applicable for fluid flow in heating mode [18]. The physical and thermal properties of the numerical model along with the summary of calculated results for Re, Nu and h are as depicted in **Table 1**.

Table 1. U-tube BHX model parameters.

S. No.	Model Parameter	Value	Units
1	Un-disturbed soil temperature T_s	15	°C
2	Temperature of the outlet pipe of U-tube, T_{fi}	9	°C
3	Temperature of the inlet pipe of U-tube, T_{fo}	6	°C
4	Mean fluid temperature, $T_f = \frac{T_{fi} + T_{fo}}{2}$	7.5	°C
5	Borehole Diameter, D_b	100	mm
6	Various soils thermal conductivity, k_s , considered in the analysis are:	0.5	W/m.K
		1	W/m.K
		2	W/m.K
7	Various grouts thermal conductivity, k_g , considered in the analysis are:	0.585	W/m.K
		1	W/m.K
		2	W/m.K
8	Various shank spacing options, S, considered in the analysis are:	31.8	mm
		50	mm
		68.1	mm
9	U-tube pipe material	High density polyethylene (HDPE)	-
10	Pipe thermal conductivity [33,34]	0.45	W/m.K
11	Pipe outer diameter, d_{po} [35]	31.8	mm
12	Pipe thickness, t_p [35]	2.9	mm
13	Fluid (water) density [32]	999.5	kg/m ³
14	Fluid (water) dynamic viscosity [32]	0.001418	kg/m.s
15	Fluid Prandtl number [32]	10.2768	-
16	Calculated Reynolds number for fluid	22,164	-
17	Calculated Nusselt number for fluid	174.98	-
18	Calculated Convective heat transfer coefficient of fluid, h	3,907	W/m ² .K

It is to be note that in a borehole of 100mm with U tube external diameter of 31.8mm, the maximum shank spacing will be 68.2mm, however we have considered 68.1mm as $S_{\max}$ because of the software (FlexPDE 6.51) limitations in providing solution for 68.2mm shank spacing in a few scenarios.

Finite element triangular meshes were considered for the complete borehole field geometry. The software FlexPDE 6.51 automatically decides the initial mesh size based on the defined geometry and the complexity of the problem. For the borehole region and the soil region near the borehole, finer mesh size was defined. Region “1.1 grout” represents the soil region near the grout/ borehole within a radius of r_{go} defined as 1.1 times r_g . The soil region at the boundary of 1.1 r_{go} was defined with a finer mesh spacing of $d_{po}/20$. For borehole/ grout, the mesh spacing was $d_{po}/30$ and that for the U-tube inlet and outlet pipes was $d_{po}/50$. With these conditions, numerical analysis on FlexPDE version 6.51 was performed.

2.3. Validation of the Results of the Numerical Model

Various analytical and semi-analytical equations available for determination of borehole thermal resistance have been numerically assessed and their validity is compared to the results of numerical analysis by previous studies. Analytical models estimate the heat transfer from the borehole wall to the surrounding soil, ignoring the internal borehole region, while numerical models use finite difference or finite volume methods to calculate the temperature distribution throughout the entire domain, including both the surrounding soil and the internal borehole [36].

Sharqawy et al. [36] performed a detailed study where the effective pipe-to-borehole thermal resistance in vertical ground heat exchangers was investigated through numerical simulations. A detailed analysis was conducted to identify the dimensionless geometrical parameters that influence this thermal resistance. The heat transfer rates between U-shaped pipes and the borehole were determined numerically and compared with well-established limiting analytical solutions. A dimensionless correlation for the effective pipe-to-borehole thermal resistance was developed. The results of the empirical formula established were also compared with approximate analytical models that treat the U-shaped pipes as a single pipe with an equivalent diameter, as well as with experimental data from the literature. The findings indicated that the existing models do not provide an accurate representation of the effective pipe-to-borehole thermal resistance.

Lamarche et al. [37] also performed a detailed study on the various theoretical, empirical and experimental approaches for determining the effective borehole thermal resistance. The multi-pole method (Bennett et al. 1987) was found to be the best fit for determining borehole thermal resistance.

Liao et al. [38] also proposed an empirical formula for the effective borehole thermal resistance and the dimensionless borehole thermal resistances obtained from the correlation was compared with those from other equations available.

Al-Chalabi [6] and Abuel-Naga and Al-Chalabi [39] worked on Equations by Paul [40], Bennet et al. [41], Gu and O’Neal [42], Hellström [43], Shonder and Beck [44] and Sharqawy et al. [36] and found that the equation by Bennet et al. [41] i.e., Equation (12) as follows, was the closest to PDE solutions. Bennet et al. [41] utilized multi-pole method. The method uses a series of linear heat sources or sinks to represent the pipes within the circular borehole, allowing for the modeling of borehole configurations with multiple U-tubes, including asymmetrical setups.

$$R_b = \frac{1}{(4\pi k_g)} \left[\ln \left(\frac{\lambda_1 \lambda_2^{1+4\sigma}}{2 (\lambda_2^4 - 1)^\sigma} \right) - \frac{\lambda_3^2 \left(1 - \left(\frac{4\sigma}{\lambda_2^4 - 1} \right) \right)^2}{\left(1 + \lambda_3^2 \left(1 + \frac{16\sigma}{\left(\lambda_2^2 - \frac{1}{\lambda_2^2} \right)^2} \right) \right)} \right] \quad (12)$$

$$\lambda_1 = D_b/D_p \quad (13)$$

$$\lambda_2 = D_b/s \quad (14)$$

$$\lambda_3 = D_p/2s = \lambda_2 / 2\lambda_1 \quad (15)$$

$$\sigma = (k_g - k_s) / (k_g + k_s) \quad (16)$$

The equation by Bennet et al. [41] does not consider the thickness of the pipe. The work by Al-Chalabi [6] and Abuel-Naga and Al-Chalabi [39] was ignoring thickness of U pipe and its thermal conductivity in the numerical analysis, Bennett equation was used.

Javed and Spitler [45] studied the theoretical formulas and empirical correlations to find the effective borehole thermal resistance. It was found that the solution which is a combination of zeroth-order multipole solution and the correction originating from the first-order multipoles is the best fit for almost all scenarios. It was therefore advised to use the modified first order multipoles method instead of other published methods.

The modified Bennett equation by Javed and Spitler [45] which accounts for pipe material will give accurate results for the study which accounts for the thickness of pipe material.

We therefore validated the results of FlexPDE 6.51 with the modified Bennett equation by Javed and Spitler [45]. The validation was performed for all conditions of the grout and shank spacings considered in the analysis.

$$R_b = \frac{1}{(4\pi k_g)} \left[\beta + \ln \left(\frac{\lambda_1 \lambda_2^{1+4\sigma}}{2 (\lambda_2^4 - 1)^\sigma} \right) - \frac{\lambda_3^2 \left(1 - \left(\frac{4\sigma}{\lambda_2^4 - 1} \right)^2 \right)}{\left(\frac{1+\beta}{1-\beta} + \lambda_3^2 \left(1 + \frac{16\sigma}{\left(\lambda_2^2 - \frac{1}{\lambda_2^2} \right)^2} \right) \right)} \right] \quad (17)$$

Where,

$$\beta = 2\pi k_g (R_p + R_i) \quad (18)$$

$$R_p = \ln(r_2/r_1)/(2\pi k_p) \quad (19)$$

$$R_i = 1/(2\pi r_1 h) \quad (20)$$

$$\beta = 2\pi k_g R_p \quad (21)$$

$$\beta = 2\pi k_g \ln(r_2/r_1)/(2\pi k_p)$$

(22)

Table 2 shows the results of using Equation (17) compared to FlexPDE 6.51 results where the error between the two results was only 0.5% or lesser. This indicates the authenticity of FlexPDE version 6.51 results and further analysis was done using FlexPDE version 6.51.

Table 2. Validation results for FlexPDE 6.51 analysis of U-tube BHX.

k_g	S	U-tube BHX thermal resistance from modified Bennet equation	U-tube BHX thermal resistance from numerical analysis on FlexPDE version 6.51	Difference in percentage
W/m.K	mm	(W/m.K) ⁻¹	(W/m.K) ⁻¹	%
0.585	31.8	0.2367	0.2356	0.5
	50	0.1820	0.1816	0.2
	68.1	0.1352	0.1349	0.2
1	31.8	0.1577	0.1572	0.3
	50	0.1255	0.1252	0.3
	68.1	0.1022	0.1019	0.3
2	31.8	0.1005	0.1008	0.2
	50	0.0835	0.0833	0.2
	68.1	0.0736	0.0735	0.2

2.4. Analysis for Insulated Outlet Leg in a Conventional U-Tube Arrangement

To see the impact of insulation on the outlet leg of the U-tube BHX in reducing the thermal short-circuiting, analysis was performed for the U-tube BHX of the same parameters as defined in Table 1 with 3 mm closed cell foam insulation on the outlet pipe. The thermal conductivity of the insulation was considered as 0.0342 W/m.K [46]. Due to insulated outlet leg, the minimum shank spacing was 34.8 mm. Analysis was performed for soil of thermal conductivity 1 W/m.K.

2.5. Analysis for Coaxial Pipe Arrangement

In the previous literature, the performance of coaxial pipe arrangement was found to be better than U-tube. Therefore, coaxial pipe arrangement was analyzed for the comparison of the improvements in the heat transfer rate. Coaxial pipes were analyzed with water flowing into the borehole through the outer annular pipe, as previous studies have shown this arrangement to be thermally more efficient than the one with inflow from the central pipe [12].

Unlike U-tube, the outlet (inner) pipe of coaxial arrangement has no direct contact with the grout and exchanges heat solely with the inlet (outer) pipe. As a result, short-circuiting effects are more evident in uninsulated coaxial pipe arrangements because of the significantly increased thermal pathway between the inlet and outlet pipes, Lamarche [5]. Due to the extremely high short-circuiting losses in uninsulated outlet pipe in coaxial arrangement, most of the previous studies recommend insulation on the outlet (inner) pipe of the coaxial arrangement of tubes to minimize the thermal short-circuiting [5,16]. For insulation of the outlet pipe, the following are few options commonly available:

(a) uniform insulation throughout the BHX which is usually applied by insulating the outlet pipe with insulation applied on its external side. A protective pipe over the insulation is required to protect it from the water damage of the annular pipe [16,47].

(b) Non-uniform insulation using vacuum insulated pipe (VIT) as the outlet pipe where vacuum is created between two metallic pipes [16,47].

Because of two-dimensional study, we analyzed coaxial arrangement with a uniform 3mm insulation of close cell foam on the outlet (inner) pipe under the same operating conditions. To protect the insulation from water, a PVC tube casing was considered. Because, only the fluid in the outlet pipe is directly exposed to the borehole, the fluid temperature for the calculation of borehole thermal resistance is the temperature of the fluid in the outer (inlet) pipe Lamarche [5]. Figure 5 describes the geometry of the coaxial model.




Figure 5. U-tube BHX with insulated outlet pipe.




Figure 6. Insulated Coaxial pipes model geometry.

Grout & soil properties and the fluid temperatures of the model were identical to the U-tube model as summarized in **Table 1**. Nusselt number was calculated from the following equations [18,48–50].

$$Nu = \frac{\left(\frac{f_{ann}}{8}\right) (Re - 1000) Pr}{1.07 + 12.7 \left(\frac{f_{ann}}{8}\right)^{1/2} (Pr^{2/3} - 1)} \times \left(1 + \left(\frac{D_h}{L}\right)^{2/3}\right) F_{ann} K \tag{23}$$

Correlation in Equation (23) is proposed by Gnielinski and is called Gnielinski equation. The equation is valid for $0.1 \leq Pr \leq 1,000$ and $Re > 4,000$. According to Gnielinski [50], f_{ann} which is the annular pipe friction factor, is different from the friction factor for the circular tube and can be calculated from the following equation.

$$f_{ann} = (1.08 \log_{10} Re^* - 1.5)^{-2} \tag{24}$$

Where,

$$Re^* = Re \times \frac{(1 + a^2) \ln a + (1 - a^2)}{(1 - a)^{2 \times \ln a}} \tag{25}$$

$$a = \text{annular diameter ratio} = \frac{\text{inner pipe outer diameter}}{\text{outer pipe inner diameter}} \tag{26}$$

$$a = r_{pvc}/r_{oi}$$

For the boundary condition of heat transfer at the outer wall with inner wall insulated, F_{ann} is determined by Equation (28) [50].

$$F_{ann} = (0.9 - 0.15a^{0.6}) \tag{28}$$

Value of K is 1 if the fluid temperature at the wall of the annular pipe and the bulk fluid temperature are considered to be the same [50].

The other physical and thermal properties of the numerical model along with the summary of calculated results for Re , Nu and h are as depicted in Table 3.

Table 3. Coaxial pipes model parameters.

S. No.	Model Parameter	Value	Units
1	Fluid temperature for estimation of borehole thermal resistance, $T_f = T_{fi}$	6	°C
2	Inlet (Outer) pipe material	Black steel	-
3	Inlet (Outer) pipe thermal conductivity [33]	43	W/m.K
4	Inlet (Outer) pipe diameter (external) [51,52]	48.3	mm
5	Inlet (Outer) pipe thickness [51,52]	3.68	mm
6	Outlet (Inner) pipe material	HDPE	-
7	Outlet (Inner) pipe thermal conductivity [33,34]	0.45	W/m.K
8	Outlet (Inner) pipe diameter (external) [35]	25	mm
9	Outlet (Inner) pipe thickness [35]	2.3	mm
10	Thickness of insulation on outlet (inner) pipe	3	mm

11	Thermal conductivity of insulation [46]	0.0342	W/m.K
12	Thickness of uPVC protective pipe [53]	1.5	mm
13	Thermal conductivity of uPVC protective pipe [54]	0.17	W/m.K
14	Inlet fluid (Water at 6°C):		
	• Density [32]	999.6	kg/m³
	• Dynamic viscosity [32]	0.001483	kg/m.s
	• Prandtl number [32]	10.8029	
	• Calculated Nusselt number	55.66	
	• Calculated Reynolds number	7,355	
	• Friction factor f_{ann}	0.0378	
	• Calculated convective heat transfer coefficient for inlet (outer) pipe, h_i	4,634	W/m².K
15	Outlet fluid (Water at 9°C):		
	• Density [32]	999.3	kg/m³
	• Dynamic viscosity [32]	0.00135	kg/m.s
	• Prandtl number [32]	9.7507	
	• Calculated Reynolds number	23,276	
	• Calculated Nusselt number	215.94	
	• Calculated convective heat transfer coefficient for inlet (outer) pipe, h_i	6,173	W/m².K

The resistance network for the arrangement is shown in **Figure 7**. Contact thermal resistance was assumed to be negligible for simplification.




Figure 7. Thermal resistance network for coaxial pipes BHX.

$$R_b = R_{fo} + R_{po} + R_g \tag{29}$$

$$R_b = \frac{1}{2\pi r_{oi} h_o} + \frac{\ln\left(\frac{r_{oo}}{r_{oi}}\right)}{2\pi k_{po}} + \frac{\ln\left(\frac{r_b}{r_{oo}}\right)}{2\pi k_g} \tag{30}$$

$$R_{sc} = R_{fi} + R_{pi} + R_{ins} + R_{pvc} + R_{fo} \quad (31)$$

$$R_{sc} = \frac{1}{2\pi r_{ii} h_i} + \frac{\ln\left(\frac{r_{io}}{r_{ii}}\right)}{2\pi k_{pi}} + \frac{\ln\left(\frac{r_{ins}}{r_{io}}\right)}{2\pi k_{ins}} + \frac{\ln\left(\frac{r_{pvc}}{r_{ins}}\right)}{2\pi k_{pvc}} + \frac{1}{2\pi r_{pvc} h_o} \quad (32)$$

2.6. Analysis for Flat Plate Barrier Arrangement Between the Inlet & Outlet Legs of the U-Tube

By introducing a flat plate barrier throughout the length of the BHX, the outlet pipe will be thermally separated from the inlet pipe, but its direct contact with the soil and grout will not be restricted. These barrier arrangements were analyzed to see if they lead to a better thermal performance. Several arrangements were analyzed numerically which are listed as follows. Analysis was done for soil thermal conductivity of 0.5, 1 & 2 W/m.K, grout thermal conductivity of 0.585, 1 & 2 W/m.K, minimum, average and maximum shank spacing. The minimum shank spacing due to insertion of the barrier will be more than the minimum shank spacing of 31.8mm for the conventional U-pipe. If the heat transfer savings of the U-tube with barrier is compared with the conventional U-tube at a lower shank spacing of 31.8mm, the savings will be misleading because of the comparison with a different shank spacing. Therefore, to depict the sole contribution of the barriers, the results of the analysis are compared to a conventional U-tube BHX with shank spacing $S_{min-actual}$.

$$S_{min-actual} = 31.8mm + \text{Overall thickness of barrier in mm} \quad (33)$$

Figure 8 shows these arrangements diagrammatically.




Figure 8. Schematic of Flat plate shape barrier arrangements for U-tube BHX.

2.6.1. Flat Plate Plastic Barrier

To minimize the thermal short circuit losses between the inlet and outlet legs, 3mm thick and 80mm long plastic barrier as shown in Figure 8a were analyzed. Following thermal conductivity for the plastic barriers were analyzed:

- Barrier nomenclature FSB-3PL1: 3mm flat plate shape plastic barrier of thermal conductivity 0.17 W/m.K. This may be an unplasticized polyvinyl chloride pipe (uPVC) material which is commonly available [54].
- Barrier nomenclature FSB-3PL2: 3mm flat plate shape plastic barrier of thermal conductivity 0.5 W/m.K. This may be a specialized rigid plastic material [55].
- Barrier nomenclature FSB-3PL3: 3mm flat plate shape plastic barrier of thermal conductivity 2 W/m.K. This may be a specialized rigid plastic material [55].

The thickness of the barrier was considered according to previous study and in the perspective of the strength for its underground installation [6].

2.6.2. Flat Plate Plastic Barrier with Metallic Tape

In addition to the attempt to minimize the short-circuit losses with the plastic barrier, a 0.2mm thermally conductive metallic tape was applied to improve the thermal distribution of the inlet pipe. Barrier nomenclature FSB-3PLMT is used for this arrangement. Metallic tapes are common in heat transfer and electronics applications. The thermal conductivity of these tapes is dependent on the thermal conductivity of the metal used, the percentage of impurities in the metal and the thermal conductivity of the adhesive. Copper tapes usually have thermal conductivity in the range of 200-250 W/m.K and are usually available in thicknesses up to 0.2mm [56]. Figure 8b shows the geometry. The considered tape had an overall thermal conductivity of 200 W/m.K [56].

2.6.3. Flat Plate Metallic Barrier

To observe the sole impact of improvement in temperature distribution of inlet pipe, without an attempt to reduce the thermal short-circuit between the two legs by a plastic barrier, metallic barriers were considered with a thickness of 3mm and a width of 80mm as shown in Figure 8a. The following materials were considered as a barrier due to their corrosion resistant properties, which makes them suitable for underground application.

- Barrier nomenclature FSB-3SS: 3mm flat plate shape stainless steel SS304 barrier of thermal conductivity 16 W/m.K [33,57]
- Barrier nomenclature FSB-3BR: 3mm flat plate shape brass of thermal conductivity 109 W/m.K [33]

2.6.4. Flat Plate Double Barrier

Because plastic barrier helps to mitigate short-circuiting losses and metallic barrier helps to enhance the temperature distribution of the inlet pipe, our next analysis was to see the effect of a double flat plate barrier of plastic and metal where flat plate plastic and flat plate metal barriers were combined to form a double flat barrier. The options considered for the analysis were as follows:

- Barrier nomenclature FSB-3PL3AL: 4mm double flat plate shape barrier with 3mm plastic (thermal conductivity 0.17 W/m.K) [54] & 1mm aluminum (thermal conductivity 237 W/m.K) [58]. Refer Figure 8c.
- Barrier nomenclature FSB-3PL3SS: 6mm double flat plate shape barrier with 3mm plastic thermal conductivity 0.17 W/m.K) [54] & 3mm stainless steel (thermal conductivity 16 W/m.K) [33,57]. Refer Figure 8d.
- Barrier nomenclature FSB-3PL3BR: 6mm double flat plate shape barrier with 3mm plastic thermal conductivity 0.17 W/m.K) [54] & 3mm brass (thermal conductivity 109 W/m.K) [33]. Refer Figure 8d.

2.7. Analysis of U Shape Barrier Arrangement Between the Inlet & Outlet Legs

For the outlet pipe, the half of the pipe facing the inlet pipe rejects heat while the other half facing the opposite side takes heat from the surrounding grout and soil. An improvement measure may be analyzed by introducing a U barrier instead of a flat plate barrier, surrounding the half perimeter of the outlet pipe from where it rejects heat and the portion of the pipe which takes heat from the ground is kept free. The barrier will be surrounding the half perimeter of the outlet pipe and extending 10mm further to prevent the mixing of thermal distribution of the outlet pipe and the inlet pipe.

The thermal properties of the selected materials were the same as considered in the flat plate barrier arrangements. Analysis was done for soil thermal conductivity of 0.5, 1 & 2 W/m.K, grout thermal conductivity of 0.585, 1 & 2 W/m.K, minimum and average and maximum shank spacing. Like the analysis in the flat plate shape barriers, the impact of barriers in heat transfer improvement for maximum shank spacing was not found to be significant and therefore dropped-out for further discussions. Several geometrical arrangements were analyzed numerically which are listed as follows. Figure 12 shows these arrangements schematically.

- Barrier nomenclature USB-3PL: U-shape barrier with 3mm thick plastic of thermal conductivity 0.17 W/m.K [54]. Refer Figure 9a.
- Barrier nomenclature USB-3PLMT: U-shape barrier with 3mm thick plastic of thermal conductivity 0.17 W/m.K [54] and 0.2mm self-adhesive metallic tape of an overall thermal conductivity 200 W/m.K [56]. Refer Figure 9b.
- Barrier nomenclature USB-3SS: U-shape barrier with 3mm thick stainless steel of thermal conductivity 16 W/m.K [33,57]. Refer Figure 9a.
- Barrier nomenclature USB-3BR: U-shape barrier with 3mm thick brass of thermal conductivity 109 W/m.K [33]. Refer Figure 9a.
- Barrier nomenclature USB-3PL1AL: 4mm double U-shape barrier with 3mm plastic (thermal conductivity 0.17 W/m.K [54]) & 1mm aluminum (thermal conductivity 237 W/m.K [58]). Refer Figure 9c.
- Barrier nomenclature USB-3PL3SS: 6mm double U-shape barrier with 3mm plastic thermal conductivity 0.17 W/m.K [54]) & 3mm stainless steel (thermal conductivity 16 W/m.K [33,57]). Refer Figure 9d.
- Barrier nomenclature USB-3PL3BR: 6mm double U-shape barrier with 3mm plastic thermal conductivity 0.17 W/m.K [54]) & 3mm brass (thermal conductivity 109 W/m.K) [33]. Refer Figure 9d.




Figure 9. Schematic of U-shape barrier arrangements for U-tube BHX.

3. Results

3.1. Analysis for U-Tube BHX:

Figure 10 shows the results of the heat transfer for the inlet & outlet pipes of the U-tube at various soil, grout and shank spacings.




Figure 10. Heat transfer from U-tube BHX Inlet & Outlet legs; (a) for k_s : 0.5 W/m.K (b) for k_s : 1 W/m.K (c) for k_s : 2 W/m.K.

The results showed that the inlet pipe had a positive value of heat flux indicating that pipe absorbs heat from the surrounding soil. Heat transfer in the outlet occurs in two ways: a positive gain

due to a 6°C temperature difference between the soil and fluid outlet, and a negative loss due to the short-circuiting near the inlet pipe. The net heat transfer through the outlet pipe can be either positive or negative, depending on the direction in which the heat transfer is greater. The more thermally conductive is the soil, the more will be the net heat transferred. Wider shank spacing and thermally enhanced grout materials also lead to improved net heat transfer.

3.2. Analysis for U-Tube BHX Having Insulated Outlet Leg

As shown in **Figure 11**, the thermal efficiency of insulated outlet leg of the U-tube BHX either decreased (for lower thermal conductivity grouts) or showed a marginal increase (for higher thermal conductivity grout).




Figure 11. Comparison of Net heat transfer for uninsulated U-tube and U-tube with insulated outlet leg; k_s : 1 W/m.K.

Therefore, restricting the heat flow path of the outlet leg of U-tube BHX to minimize or eliminate the thermal short-circuit losses does not always lead to better overall heat transfer efficiency. This is due to a few reasons which offset the thermal efficiency improvement by reduction in the thermal short-circuit losses; one being the isolation of the outlet leg from the grout and soil to exchange heat, the other being the changes in the temperature distribution of the inlet pipe due to reduced grout area in the central region within the BHX which leads to a decrease in the inlet pipe heat flow, especially at reduced shank spacing, this effect is more pronounced. In addition, the contribution of BHX thermal resistance for lower thermal conductivity grout is comparatively more in the net heat transfer compared to the case with higher thermal conductivity grout which makes the impact of the increase in BHX thermal resistance more contributing towards reduction in the overall hat transfer.

3.3. Analysis for Coaxial Pipes

Figure 12 shows the results in terms of the heat transfer rates for inlet and outlet pipes. The thermal short-circuit losses were 2.58 W/m. These short-circuit losses remain constant for the same geometric and flow parameters, regardless of the thermal conductivity of the soil and grout, therefore their contribution in low thermal conductivity soils and grouts is comparatively higher in percentage of the total heat flow.




Figure 12. Heat transfer rate from the inlet & outlet pipes for insulated coaxial pipes (inflow through outer pipe).

Figure 13 shows the net heat transfer in W/m from the inlet & outlet pipes at various operating conditions for U-tube and coaxial pipe arrangements. For the soil with comparatively lower thermal conductivity of 0.5 W/m.K, the performance of U-pipe was better than the insulated coaxial pipe arrangement for all scenarios of the shank spacing. For soil with thermal conductivity of 1 W/m.K and for grout with 0.585 W/m.K thermal conductivity, the performance of insulated coaxial arrangement is lesser for S_{avg} & S_{max} case and shows better performance for S_{min} . The same trend was observed for grout thermal conductivity of 1 and 2 W/m.K. In crease in soil and grout thermal conductivity was making coaxial pipes performance better than U-tube BHX.




Figure 13. Net heat transfer rate for U-tube and coaxial BHXS.

3.4. Single Flat Plate Barrier Arrangement for U-Tube BHX

3.4.1. Flat Plate Plastic Barrier

Table 4 shows the results of the numerical analysis for the three arrangements of plastic flat plate barrier (FSB-3PL1, FSB-3PL2 & FSB-3PL3) at soil thermal conductivity of 1 W/m.K. The results show that the BHX thermal resistance increased causing a reduction instead of an increase in the total heat transfer through the borehole after introducing thermal barrier. The plastic with higher thermal conductivity of 0.5 W/m.K exhibited a marginally smaller negative percentage. The increase in thermal resistance or a decrease in the total heat transfer was more for closer shank spacings and for lower thermal conductivity grouts. To verify this trend, another specialized plastic material of thermal conductivity 2 W/m.K was analyzed. The results showed a marginal increase in the total heat transfer for the higher thermal conductivity plastic with the same trend of comparatively better performance at closer shank spacings and lower thermal conductivity grouts.

Table 4. Comparison of U-tube BHX heat transfer for plastic barrier arrangements FSB-3PL1, FSB-3PL2 and FSB-3PL3; k_s : 1 W/m.K.

k_g	S	Conventional U-tube BHX (Base case for the comparison)			U-tube BHX with barrier arrangement FSB-3PL1			
		Q_{in}	Q_{out}	Q_t	Q_{in}	Q_{out}	Q_t	POI in Q_t (Note-1)
W/m.K	mm	W/m	W/m	W/m	W/m	W/m	W/m	
0.585	34.8	11.65	(0.99)	10.67	10.36	0.27	10.63	-0.38%
	50	10.11	1.28	11.38	9.72	1.64	11.36	-0.23%
	68.1	9.91	2.34	12.25	9.74	2.49	12.24	-0.12%
1	34.8	14.05	(2.12)	11.94	12.02	(0.13)	11.89	-0.38%
	50	12.22	0.23	12.45	11.40	1.03	12.42	-0.22%
	68.1	11.44	1.51	12.95	11.04	1.90	12.94	-0.12%
2	34.8	17.04	(3.98)	13.06	14.01	(0.99)	13.02	-0.34%
	50	15.09	(1.71)	13.38	13.45	(0.09)	13.36	-0.17%
	68.1	13.75	(0.13)	13.62	12.82	0.79	13.61	-0.10%

k_g	S	U-tube BHX with barrier arrangement FSB-3PL2				U-tube BHX with barrier arrangement FSB-3PL3			
		Q_{in}	Q_{out}	Q_t	POI in Q_t (Note-1)	Q_{in}	Q_{out}	Q_t	POI in Q_t (Note-1)
W/m.K	mm	W/m	W/m	W/m		W/m	W/m	W/m	
0.585	34.8	11.52	(0.86)	10.66	-0.07%	12.37	(1.59)	10.78	1.06%
	50	10.07	1.31	11.38	-0.04%	10.29	1.17	11.45	0.61%
	68.1	9.90	2.35	12.25	-0.02%	9.99	2.30	12.29	0.30%
1	34.8	13.43	(1.52)	11.91	-0.22%	14.45	(2.47)	11.98	0.39%
	50	11.99	0.44	12.44	-0.12%	12.35	0.13	12.48	0.22%
	68.1	11.33	1.61	12.94	-0.07%	11.50	1.47	12.97	0.12%
2	34.8	15.73	(2.70)	13.02	-0.27%	17.04	(3.98)	13.06	0.00%
	50	14.44	(1.07)	13.36	-0.13%	15.09	(1.71)	13.38	0.00%
	68.1	13.39	0.22	13.61	-0.08%	13.75	(0.13)	13.62	0.00%

Note-1: POI: Percentage of increase from the base case. Positive value indicates an increase from the base case whereas negative value indicates a decrease.

The presence of a barrier having a thermal conductivity lower than the grout material decreased the heat transfer through the inlet pipe, resulting in a reduction in heat flow from the inlet pipe leg. Consequently, despite the mitigation of the short-circuiting losses the net heat transfer was still lower than the base case. The plastic with higher thermal conductivity of 2 W/m.K increased the short-circuiting effect but offered marginal increase in the overall heat transfer.

3.4.2. Flat Plate Plastic Barrier with Self-Adhesive Metallic Tape

Table 5 shows the resulting heat transfer for barrier arrangement FSB-3PLMT i.e., 3mm plastic flat plate barrier with 0.2mm self-adhesive metal tape. The table also shows the previously discussed barrier arrangement FSB-3PL1 i.e., 3mm plastic barrier of 0.17 W/m.K for a comparison of the changes after adding a metallic layer over the plastic barrier. At lower thermal conductivity grout of 0.585 W/m.K and at closest shank spacing of 35mm, there was a significant increase in the overall heat transfer from 10.63 to 11.20 W/m which is around 5% increase from the base case. The percentage increase in the heat transfer rate started to diminish at increased shank spacings and thermal conductivity of the grout. At the lower thermal conductivity grout of 0.585 W/m.K, the heat transfer from the outlet pipe was also improved in addition to an increase in the heat transfer through the inlet pipe. For grout materials with higher thermal conductivity, the heat transfer in the outlet pipe decreased from the case of a simple plastic barrier without any metallic tape. However, due to the

increased heat transfer in the inlet leg in case of metallic tape on the plastic barrier, this scenario still resulted in an overall improvement in heat transfer.

Table 5. Comparison of heat transfer for barrier arrangement FSB-3PL1 and FSB-3PLMT; k_s : 1 W/m.K.

k_g	S	U-tube BHX with barrier arrangement FSB-3PL1				U-tube BHX with barrier arrangement FSB-3PLMT			
		Q_{in}	Q_{out}	Q_t	POI in Q_t	Q_{in}	Q_{out}	Q_t	POI in Q_t
		W/m	W/m	W/m	(Note-1)	W/m	W/m	W/m	(Note-1)
0.585	S_{min}	10.36	0.27	10.63	-0.38%	11.12	0.08	11.20	4.99%
	S_{avg}	9.72	1.64	11.36	-0.23%	10.01	1.64	11.65	2.31%
	S_{max}	9.74	2.49	12.24	-0.12%	9.87	2.51	12.38	1.02%
1	S_{min}	12.02	(0.13)	11.89	-0.38%	12.69	(0.37)	12.32	3.20%
	S_{avg}	11.40	1.03	12.42	-0.22%	11.69	0.96	12.64	1.54%
	S_{max}	11.04	1.90	12.94	-0.12%	11.17	1.88	13.05	0.75%
2	S_{min}	14.01	(0.99)	13.02	-0.34%	14.55	(1.26)	13.29	1.74%
	S_{avg}	13.45	(0.09)	13.36	-0.17%	13.73	(0.23)	13.50	0.86%
	S_{max}	12.82	0.79	13.61	-0.10%	12.96	0.72	13.68	0.45%

Note-1: POI: Percentage of increase from the base case. Positive value indicates an increase from the base case whereas negative value indicates a decrease.

Figure 14 to **Figure 16** show the temperature distribution within the BHX for a conventional - tube, a U-tube with barrier arrangement FSB-3PL1 and FSB-3PLMT. The temperature distribution shown is for k_s of 1 W/m.K and k_g of 0.585 W/m.K. Shank spacing is 34.8mm for **Figure 14** & **Figure 15**, and 35mm for **Figure 16**.




Figure 14. Temperature distribution in grout region for conventional U-tube BHX, k_s : 1 W/m.K, k_g : 0.585 W/m.K and S: 34.8mm.




Figure 15. Temperature distribution in grout region for U-tube BHX with barrier arrangement FSB-3PL1, k_s : 1 W/m.K, k_g : 0.585 W/m.K and S: 34.8mm.




Figure 16. Temperature distribution in grout region for U-tube BHX with barrier arrangement FSB-3PLMT, k_s : 1 W/m.K, k_g : 0.585 W/m.K and S: 35mm.

For the temperature distribution in the grout regions shown, the temperature values are also noted at a few locations as shown in **Figure 14** to **Figure 16**. In our analysis, the U-tube was centered along x-axis, therefore the temperatures in upper right quarter xy plane were identical to the lower right quarter xy' plane. Similarly, temperatures in the upper left quarter $x'y$ plane were identical to the lower left quarter $x'y'$ plane.

The addition of plastic barrier between the two legs (arrangement FSB-3PL1 and **Figure 15**) shows the temperature distribution for this arrangement) restricted the direct heat exchange between the inlet and outlet legs of the U-tube. Because of restriction in the heat flow from the outlet leg, the temperature near the outlet leg at locations 1,3 & 5 increased. Because of the restricted direct heat flow, there was no short-circuiting between the two legs and the grout temperature near the inlet leg therefore decreased at locations 2,4 & 6, compared to the U-tube without barrier (**Figure 14**). So, the plastic barrier in this way was positively impacting in improving the heat transfer rate in the U-tube BHX.

The resulting heat transfer rate from the outlet leg of the U-tube improved from -0.99 W/m to 0.27 W/m. However, at the same time, the grout region near the barrier had a low thermal conductivity plastic material which caused restricted temperature distribution from the grout to the BHX wall. The increased grout temperatures near the barrier facing the outlet leg also caused an increase in the grout temperature of the grout in the right half (xy and xy' planes) of the BHX. As a result, the temperature near the BHX wall at locations 7,8 & 9 and the grout regions near-by increased after addition of plastic barrier, and the heat flow rate from the inlet leg reduced from 11.65 W/m to 10.36 W/m. The net heat transfer rate marginally decreased from 10.67 W/m to 10.63 W/m.

The addition of metallic tape over the plastic barrier facing the inlet pipe side (arrangement FSB-3PLMT and **Figure 16**) decreased the overall thermal resistance between the inlet and outlet legs, causing thermal short-circuiting between the two legs due to which the overall heat flow rate from the outlet leg reduced again from 0.27 W/m (for FSB-3PL1) to 0.08 W/m (for FSB-3PLMT). Metallic

tape improved the temperature distribution between the grout and BHX wall facing the inlet pipe side, causing noticeable reduction in the temperature at locations 4,6 and 8 to 14. This caused the heat flow rate from the inlet leg to increase from 10.36 W/m (for FSB-3PL1) to 11.12 W/m (for FSB-3PLMT). The net heat transfer rate increased from 10.63 W/m (for FSB-3PL1) to 11.2 W/m (for FSB-3PLMT).

3.4.3. Flat Plate Metallic Barrier

The results of heat transfer for the two flat plate metallic barriers analyzed are shown in **Table 6**. The results of a conventional U-tube BHX are already shown in **Table 4**. Although the values of heat transfer loss from the outlet leg of the BHX are more in these two cases from the conventional U-tube outlet leg heat loss, the overall heat transfer is improved. In addition, for closer shank spacing, the improvement in the heat transfer with barrier arrangement FSB-3SS was less than that with barrier arrangement FSB-3PLMT as shown in **Table 5**. For farther shank spacings, the performance of FSB-3SS was found to be marginally better. The heat transfer performance of the barrier arrangement FSB-3BR was significant for minimum and average shank spacings, whereas for farthest shank spacing of 68.1mm, the lowest increase was noted.

Table 6. U-tube BHX heat transfer for flat plate metallic barriers FSB-3SS and FSB-3BR, k_s : 1 W/m.K.

k_g	S	U-tube BHX with barrier arrangement FSB-3SS				U-tube BHX with barrier arrangement FSB-3BR			
		Q_{in}	Q_{out}	Q_t	POI in Q_t (Note-1)	Q_{in}	Q_{out}	Q_t	POI in Q_t (Note-1)
W/m.K	mm	W/m	W/m	W/m		W/m	W/m	W/m	
0.585	34.8	12.87	(1.69)	11.19	4.86%	13.03	(1.61)	11.42	7.09%
	50	10.45	1.22	11.67	2.55%	10.52	1.27	11.79	3.53%
	68.1	10.06	2.34	12.40	1.18%	10.09	2.36	12.45	1.60%
1	34.8	14.99	(2.71)	12.28	2.90%	15.15	(2.64)	12.51	4.83%
	50	12.55	0.09	12.65	1.56%	12.63	0.14	12.76	2.51%
	68.1	11.59	1.46	13.06	0.80%	11.63	1.48	13.12	1.27%
2	34.8	17.65	(4.41)	13.24	1.35%	17.81	(4.38)	13.43	2.82%
	50	15.38	(1.91)	13.47	0.70%	15.46	(1.89)	13.58	1.47%
	68.1	13.91	(0.23)	13.67	0.38%	13.95	(0.22)	13.73	0.80%

Note-1: POI: Percentage of increase from the base case. Positive value indicates an increase from the base case whereas negative value indicates a decrease.

3.4.4. Impact of Single Flat Plate Barrier on BHX Length

The analysis of single flat plate barriers in **Table 4** depicted that the contribution of plastic barriers in mitigating the borehole thermal resistance is marginal or even negative in various scenarios, though adding a 0.2mm metallic tape of thermal conductivity 200 W/m.K on 3mm plastic barrier substantially improves the results. Therefore, plastic barriers FSB-PL1, FSB-PL2 & FSB-PL3 are not an option to increase the heat transfer of U-tube BHX.

From **Table 4** to **Table 6**, it was noted that the increase in heat transfer rate due to the addition of a barrier was not substantial compared to the minimum and average shank spacings, we therefore focused on the minimum and average shank spacings only to present the resulting impact on BHX length.

As shown in **Table 7** the absolute decrease in the length of the BHX because of barrier was more for the lower thermal conductivity soil, however the percentage reduction was more for the higher thermal conductivity soil. Because the absolute reduction in length is directly related to the cost of the BHX, comparison of absolute length reduction might lead to a better decision in terms of barrier selection.

Table 7. Absolute and percentage reduction in length for U-tube BHX with barrier arrangement FSB-3BR.

k_g	S	Length per kW_t for Conventional U-tube BHX (Base case for the comparison)			Length for U-tube BHX with barrier arrangement FSB-3BR								
		$k_s=0.5$	$k_s=1$	$k_s=2$	$k_s=0.5$			$k_s=1$			$k_s=2$		
		L in m/kW_t	L in m/kW_t	L in m/kW_t	L in m/kW_t	ΔL in m/kW_t	POR (Note-1)	L in m/kW_t	ΔL in m/kW_t	POR (Note-1)	L in m/kW_t	ΔL in m/kW_t	POR (Note-1)
0.585		34.8	157.5	93.7	61.8			151.2	6.4	4.04%	87.5	6.2	6.62%
		50	152.0	87.8	55.5			148.7	3.3	2.19%	84.9	3.0	3.41%
1		34.8	147.5	83.8	51.9			143.5	3.9	2.68%	79.9	3.9	4.61%
		50	144.2	80.3	48.2			142.1	2.1	1.48%	78.3	2.0	2.45%
2		34.8	140.2	76.6	44.7			138.1	2.1	1.51%	74.5	2.1	2.74%
		50	138.4	74.7	42.8			137.3	1.1	0.81%	73.6	1.1	1.45%
Note-1: POR: Percentage of reduction from the base case. Positive value indicates a reduction from the base case whereas negative value indicates an increase.													
Note-2: Units for k_s are W/m.K													

The results of absolute reduction in the BHX length by introducing a 3mm plastic barrier with metallic tape (FSB-3PLMT) and that with 3mm thick metallic barriers of stainless steel and brass (FSB-3SS & FSB-3BR) are shown in Figure 17 & Figure 18 for shank spacing S_{min} & S_{avg} respectively.




Figure 17. Reduction in U-tube BHX length at S_{min} , for flat plate barriers at various conditions of grout & soil thermal conductivity.




Figure 18. Reduction in U-tube BHX length at S_{avg} , for flat plate barriers at various conditions of grout & soil thermal conductivity.

3.5. Double Flat Plate Barrier Arrangement for U-Tube BHX

3.5.1.4. mm Double Barrier

Table 8 shows the results for the 4mm barrier (3mm plastic & 1mm aluminum).

Table 8. Comparison of heat transfer from U-tube BHX with barrier arrangement FSB-3PL1AL, k_s: 1 W/m.K.

k _g	S	Conventional U-tube BHX (Base case for the comparison)			U-tube BHX with double barrier arrangement FSB-3PL1AL			
		Q _{in}	Q _{out}	Q _t	Q _{in}	Q _{out}	Q _t	POI in Q _t (Note- 1)
		W/m	W/m	W/m	W/m	W/m	W/m	
0.585	35.8	11.43	(0.72)	10.72	11.45	0.02	11.47	6.09%
	50	10.11	1.28	11.38	10.16	1.60	11.76	3.31%
1	35.8	13.85	(1.87)	11.97	13.05	(0.48)	12.57	4.36%
	50	12.22	0.23	12.45	11.88	0.88	12.76	2.50%
2	35.8	16.86	(3.78)	13.09	14.96	(1.45)	13.50	2.81%
	50	15.09	(1.71)	13.38	13.97	(0.36)	13.61	1.69%

Note-1: POI: Percentage of increase from the base case. Positive value indicates an increase from the base case whereas negative value indicates a decrease.

A noticeable increase in heat transfer especially at low thermal conductivity of grout and closer shank spacing resulted due to barrier.

3.5.2. 6 mm Double Barrier

Table 9 shows the results for the 6mm barrier for two different 3mm thick metallic barriers are used with 3mm PVC to form a 6mm thick barrier. The improvement in heat transfer for 6mm double barrier of PVC & stainless steel was less than observed for 4mm double barrier with PVC & aluminum.

Table 9. Comparison of heat transfer from U-tube BHX with double barrier arrangements FSB-3PL3SS & FSB-3PL3BR; ks: 1 W/m.K.

k_g	S	Conventional U-tube BHX (Base case for the comparision)			U-tube BHX with double barrier arrangement FSB-3PL3SS				U-tube BHX with double barrier arrangement FSB-3PL3BR			
		Q_{in}	Q_{out}	Q_t	Q_{in}	Q_{out}	Q_t	POI in Q_t	Q_{in}	Q_{out}	Q_t	POI in Q_t
		W/m	W/m	W/m	W/m	W/m	W/m	(Note-1)	W/m	W/m	W/m	(Note-1)
0.585	37.8	11.08	(0.27)	10.81	11.27	0.12	11.39	5.34%	11.58	0.04	11.62	7.50%
	50	10.11	1.28	11.38	10.22	1.49	11.71	2.86%	10.34	1.48	11.82	3.87%
1	37.8	13.49	(1.45)	12.05	12.80	(0.34)	12.46	3.41%	13.17	(0.48)	12.69	5.34%
	50	12.22	0.23	12.45	11.89	0.80	12.69	1.92%	12.06	0.76	12.82	2.94%
2	37.8	16.54	(3.40)	13.13	14.61	(1.23)	13.37	1.81%	15.05	(1.46)	13.59	3.45%
	50	15.09	(1.71)	13.38	13.88	(0.36)	13.52	1.07%	14.14	(0.49)	13.65	2.02%

Note-1: POI: Percentage of increase from the base case. Positive value indicates an increase from the base case whereas negative value indicates a decrease.

3.5.3. Impact of Double Flat Plate Barrier on BHX Length

The results of reduction in the BHX length by introducing double flat plate barrier are shown in Figure 19 & Figure 20 for shank spacing S_{min} & S_{avg} respectively.




Figure 19. Reduction in U-tube BHX length at S_{min} , for double flat plate barriers at various conditions of grout & soil thermal conductivity.




Figure 20. Reduction in U-tube BHX length at S_{avg} , for double flat plate barriers at various conditions of grout & soil thermal conductivity.

3.6. Single U-Shape Barrier Arrangement for U-Tube BHX

3.6.1. U-Shape Plastic Barrier

Table 10 depicts the results of single U-shape barrier of PVC plastic with 0.17 W/m.K. Soil thermal conductivity was 1 W/m.K in the analysis. The results showed that the BHX thermal resistance increased causing a reduction instead of an increase in the total heat transfer through the borehole after introducing 3mm thick plastic U-barrier. The trend is like the flat plate barrier case and the change of the barrier geometry from flat plate to U-shape does not help in heat transfer improvement in this case.

Table 10. Comparison of U-tube BHX heat transfer for plastic barrier arrangements USB-3PL; k_s : 1 W/m.K.

k_g	S	Conventional U-tube BHX (Base case for the comparison)			U-tube BHX with barrier arrangement USB-3PL			
		Q_{in}	Q_{out}	Q_t	Q_{in}	Q_{out}	Q_t	POI in Q_t (Note-1)
		W/m	W/m	W/m	W/m	W/m	W/m	
0.585	34.8	11.65	(0.99)	10.67	10.65	0.00	10.65	-0.12%
	50	10.11	1.28	11.38	9.95	1.41	11.36	-0.21%
1	34.8	14.05	(2.12)	11.94	12.56	(0.58)	11.97	0.31%
	50	12.22	0.23	12.45	11.82	0.66	12.48	0.24%
2	34.8	17.04	(3.98)	13.06	14.92	(1.73)	13.19	1.04%
	50	15.09	(1.71)	13.38	14.19	(0.67)	13.52	1.03%

Note-1: POI: Percentage of increase from the base case. Positive value indicates an increase from the base case whereas negative value indicates a decrease.

3.6.2. U-Shape Plastic Barrier with Self-Adhesive Metallic Tape

Table 11 shows the resulting heat transfer and also shows the previously discussed plastic barrier of 0.17 W/m.K for a comparison of the changes after adding a metallic layer over the plastic barrier. At the lower thermal conductivity grout of 0.585 W/m.K and at closest shank spacing of 35mm, the percentage increase in the overall heat transfer from the base case was the highest. The percentage increase in the heat transfer rate started to diminish at increased shank spacings and

thermal conductivity of the grout. Unlike the flat plate barrier case, at lower thermal conductivity grout of 0.585 W/m.K, the heat transfer from the outlet pipe decreased from the base case. For other grouts of higher thermal conductivity also, the heat transfer in the outlet pipe reduced from a plastic U-barrier with no metal tape. Due to an increase in the heat transfer of the inlet leg, in overall this arrangement improved the net heat transfer.

Table 11. Comparison of heat transfer from U-tube BHX with barrier arrangement FSB-3PL1 and FSB-3PLMT; k_s : 1 W/m.K.

k_g	S	U-tube BHX with barrier arrangement USB-3PL				U-tube BHX with barrier arrangement USB-3PLMT			
		Q_{in}	Q_{out}	Q_t	POI in Q_t	Q_{in}	Q_{out}	Q_t	POI in Q_t
		W/m	W/m	W/m	(Note-1)	W/m	W/m	W/m	(Note-1)
0.585	S_{min}	10.65	0.00	10.65	-0.12%	12.12	(1.05)	11.06	3.72%
	S_{avg}	9.95	1.41	11.36	-0.21%	10.25	1.24	11.49	0.95%
1	S_{min}	12.56	(0.58)	11.97	0.31%	13.91	(1.57)	12.34	3.43%
	S_{avg}	11.82	0.66	12.48	0.24%	12.21	0.39	12.60	1.21%
2	S_{min}	14.92	(1.73)	13.19	1.04%	16.02	(2.55)	13.47	3.16%
	S_{avg}	14.19	(0.67)	13.52	1.03%	14.62	(1.01)	13.61	1.70%
Note-1: POI: Percentage of increase from the base case. Positive value indicates an increase from the base case whereas negative value indicates a decrease.									

3.6.3. U-Shape Metallic Barrier

Table 12 shows the results of this analysis. Both metallic U-shape barrier options USB-3SS & USB3BR exhibited lower improvement in the net heat transfer than USB-3PLMT, except for one scenario. For farther shank spacings and at lower thermal conductivity grout of 0.585 W/m.K, the performance of USB-3BR was found to be marginally better.

Table 12. U-tube BHX heat transfer for metallic U-barriers USB-3SS & USB-3BR k_s : 1 W/m.K.

k_g	S	3mm thick U-barrier of stainless steel with 16 W/m.K thermal conductivity				3mm thick U-barrier of brass with 109 W/m.K thermal conductivity			
		Q_{in}	Q_{out}	Q_t	POI in Q_t	Q_{in}	Q_{out}	Q_t	POI in Q_t
	mm	W/m	W/m	W/m	(Note-1)	W/m	W/m	W/m	(Note-1)
0.585	34.8	13.42	(2.53)	10.89	2.12%	13.99	(2.97)	11.02	3.31%
	50	10.32	1.17	11.49	0.93%	10.38	1.15	11.53	1.31%
1	34.8	12.56	(0.58)	11.97	0.31%	16.22	(3.94)	12.28	2.88%
	50	11.82	0.66	12.48	0.24%	12.65	(0.08)	12.58	1.02%
2	34.8	14.92	(1.73)	13.19	1.04%	18.88	(5.53)	13.36	2.27%
	50	14.19	(0.67)	13.52	1.03%	15.72	(2.24)	13.48	0.77%
Note-1: POI: Percentage of increase from the base case. Positive value indicates an increase from the base case whereas negative value indicates a decrease.									

3.6.4. Impact of U-Shape Barrier on BHX Length

The results of reduction in the BHX length by introducing 3mm thick metallic barriers and a 3mm plastic barrier with metallic tape are shown in **Figure 21** & **Figure 22**.




Figure 21. Reduction in the BHX length for various single U- barriers; k_s: 0.5 W/m.K.




Figure 22. Reduction in the BHX length for various single U- barriers; k_s: 2 W/m.K.

3.7. Double Flat Plate Barrier Arrangement for U-Tube BHX

3.7.1. 4 mm Double U-Shape Barrier

Table 13 shows the results for the barrier arrangement USB-3PL1AL i.e., 4mm double U-barrier (3mm plastic & 1mm aluminum).

Table 13. Comparison heat transfer for U-tube BHX with double barrier arrangement USB-3PL1AL; k_s: 1 W/m.K.

k_g	S	Conventional U-tube BHX (Base case for the comparision)			U-tube BHX with double barrier arrangement USB-3PL1AL			
		Q_{in}	Q_{out}	Q_t	Q_{in}	Q_{out}	Q_t	POI in Q_t
		W/m	W/m	W/m	W/m	W/m	W/m	(Note-1)
0.585	35.8	11.43	(0.72)	10.72	12.74	(1.45)	11.29	4.42%
	50	10.11	1.28	11.38	10.40	1.15	11.56	1.51%
1	35.8	13.85	(1.87)	11.97	14.62	(2.05)	12.57	4.35%
	50	12.22	0.23	12.45	12.45	0.22	12.67	1.77%
2	35.8	16.86	(3.78)	13.09	16.82	(3.14)	13.68	4.14%
	50	15.09	(1.71)	13.38	15.00	(1.32)	13.68	2.24%
Note-1: POI: Percentage of increase from the base case. Positive value indicates an increase from the base case whereas negative value indicates a decrease.								

3.7.2. 6 mm Double U-Shape Barrier

Table 14 shows the results for the double U-barrier for two different 3mm thick metallic barriers combined with 3mm PVC to form a 6mm thick barrier which are designated as barrier arrangement USB-3PL3SS & USB-3PL3BR. The improvement in heat transfer for USB-3PL3SS was lesser than observed for USB-3PL1AL.

Table 14. U-tube BHX heat transfer for double barrier arrangements USB-3PL3SS & USB-3PL3BRs; 1 W/m.K.

k_g	S	U-tube BHX with double barrier arrangement USB-3PL3SS				U-tube BHX with double barrier arrangement USB-3PL3BR			
		Q_{in}	Q_{out}	Q_t	POI in Q_t	Q_{in}	Q_{out}	Q_t	POI in Q_t
		W/m	W/m	W/m	(Note-1)	W/m	W/m	W/m	(Note-1)
0.585	37.8	12.19	(0.93)	11.26	4.17%	12.88	(1.42)	11.46	6.03%
	50	10.42	1.13	11.55	1.43%	10.57	1.04	11.61	2.02%
1	37.8	13.92	(1.45)	12.47	3.54%	14.75	(2.06)	12.70	5.39%
	50	12.38	0.26	12.63	1.48%	12.65	0.07	12.72	2.14%
2	37.8	15.93	(2.40)	13.53	3.03%	16.92	(3.17)	13.75	4.72%
	50	14.74	(1.12)	13.62	1.78%	15.21	(1.50)	13.71	2.48%
Note-1: POI: Percentage of increase from the base case. Positive value indicates an increase from the base case whereas negative value indicates a decrease.									

3.7.3. Impact of Double U-Shape Barrier on BHX Length

The resulting reduction in the BHX length by introducing double U- barrier of plastic & metal is shown in **Figure 23** to **Figure 24**.




Figure 23. Reduction in the BHx length for various U- barriers; $k_s: 0.5 \text{ W/m.K}$.




Figure 24. Reduction in the BHx length for various U- barriers; $k_s: 2 \text{ W/m.K}$.

4. Discussion

4.1. Comparison of this Study with the Previous Studies

The barrier analysis conducted by Al-Chalabi [6] was based on a k_g/k_s value of 2 with d_b/d_p value of 3.33. The ratio d_b/d_p in our analysis was 3.15; which is considered to be approximately equal to the value in the study by Al-Chalabi [6], for the comparison. The far-field radius was 1m in both studies. The values of thermal conductivities of the barrier materials and their geometry were identical. The previous study mentioned the results corresponding to the ratio k_g/k_s which has a value of 2 in the previous study. In this study, k_g/k_s value of 2 will be equivalent to the following two scenarios:

- k_s of 0.5 W/m.K & k_g of 1 W/m.K
- k_s of 1 W/m.K & k_g of 2 W/m.K

The comparative summary of the results of the analysis by Al-Chalabi [6] and the relevant results in our analysis are depicted in **Table 15**.

Table 15. The comparative summary of the results of the analysis by Al-Chalabi [6] and the relevant results of this study.

Description	Previous study					This study					
	k _g /k _s :2					k _g /k _s :2 with Scenario 1 (k _s : 0.5 and k _g : 1)			k _g /k _s :2 with Scenario 2 (k _s : 1 and k _g : 2)		
	S	BHX resistance	POR noted	POR calculated	Comments	S	BHX resistance	POR	S	BHX resistance	POR
	mm	m.K/W	from the study	mm		m.K/W	mm		m.K/W		
Conventional U-tube	30	0.0606	Base case			31.8	0.1575	Base case	31.8	0.1008	Base case
	40	0.0528				37.8	0.1460		37.8	0.0938	
	50	0.0463				50	0.1272		50	0.0833	
	67.5	0.0385				68.1	0.1090		68.1	0.0735	
double flat plate barrier	40	0.0298	-44%	-44%	Note 1	37.8	0.1060	27%	37.8	0.0748	20%
	50	0.0336	-36%	-27%	Note 2	50	0.1049	18%	50	0.0722	13%
	67.5	0.0318	-40%	-17%	Note 3	Not evaluated					
double U shape barrier	40	0.0122	-77%	-77%	Note 1	37.8	0.0918	37%	37.8	0.0681	27%
	50	0.0215	-54%	-54%	Note 1	50	0.1011	21%	50	0.0697	16%

POR: Percentage of reduction from the base case

Units for k_g : W/m.K

Units for k_s : W/m.K

Note 1: The calculated percentage matches the POR noted in the previous study

Note 2: The calculated percentage does not match the POR noted in the previous study. It seems that the previous study calculated it from the base-case of 40mm shank spacing instead of 50mm shank spacing.

Note 3: The calculated percentage does not match the POR noted in the previous study. It seems that the previous study calculated it from the base-case of 40mm shank spacing instead of 67.5mm shank spacing.

The previous study presents the results in terms of ratio k_g/k_s which was set as 2; however as per this study, the results of heat transfer rate & borehole thermal resistance for two scenarios of identical k_g/k_s ratio, but different values of k_g and k_s resulted in a different result of the value of borehole thermal resistance.

The values of borehole thermal resistance between this and the previous study do not match with lower values in the previous study. This is because of not considering the thickness of HDPE pipe in the analysis and therefore the resistance of pipe material is not added in the BHX thermal resistance. In addition, it is noted in this study that increasing the soil thermal conductivity decreases the borehole thermal resistance for the same k_g/k_s ratio so the difference of values in the two studies might also be due to use of non-similar conditions of k_s and k_g .

In this study, the barrier technique is found to be more effective in decreasing the BHX resistance for a lower k_g/k_s ratio. The previous study is based on a higher value of k_g/k_s , therefore lacks the analysis for the scenarios where barrier technique may perform more effectively.

The previous study discusses only the percentage reduction in the thermal resistance of the borehole and does not provide an overview of the goal of improving the heat transfer rate or reducing the BHX length. The percentage of borehole thermal resistance in the total resistance of a ground heat exchange system varies with changes in grout thermal conductivity and is more for lower values of thermal conductivity grouts and gradually decreases with increase in the grout thermal conductivity. Therefore, the indication of percentage reduction in the thermal resistance of the borehole will not warrant the effectiveness of the barrier design which offers a higher percentage reduction in borehole thermal resistance. Indication of net heat transfer rate or BHX length reduction instead, may provide a better understanding.

This study fills the gap in the previous study by providing a comprehensive study discussing various combinations of soil and grout thermal conductivity with a conclusive indication of heat transfer rates and BHX length reduction.

4.2. Comparison of Different Barriers with Conventional U-Tube

The impact of a barrier between U-tube legs of BHX in reducing the length is better for closer shank spacing than average shank spacing. For example, the saving in U-tube BHX length reduces from 6.4 to 3.3 m/kW_t, for the case of FSB-3BR with k_s of 0.5 W/m.K and k_g of 0.585 W/m.K, when shank spacing is increased from 34.8mm to 50mm (Refer to Figure 17). The maximum reduction in absolute length of the BHX due to barrier arrangement was 4 m/kW_t for flat plate barrier when FSB-3PL3BR double flat plate barrier was introduced for S_{avg} , k_s of 0.5 W/m.K and k_g of 0.585 W/m.K. For the U-shape barrier, the maximum reduction was 4.2 W/m.K when USB-3PL3BR double flat plate barrier was introduced for S_{avg} , k_s of 0.5 W/m.K and k_g of 2 W/m.K.

The absolute reduction in length was found to be more for lower thermal conductivity grout, except for the case of double U-barriers with average shank spacing, where the absolute reduction for higher thermal conductivity grout was found to be more.

The performance of flat plate-shaped barriers does not show a significant variation across different soil thermal conductivities when the grout thermal conductivity remains constant. However, this difference becomes quite pronounced for U-shaped barriers. For example, the reduction in BHX length for the case of FSB-3BR at S_{min} & k_g of 0.585 W/m.K, is 6.4, 6.2 & 6.1 m/kW_t for soil thermal conductivity of 0.5, 1 & 2 W/m.K respectively; whereas for the case of USB-3BR at S_{min} & k_g of 0.585 W/m.K, the reduction was 6.4, 3.0 & 2.7 m/kW_t for soil thermal conductivity of 0.5, 1 & 2 W/m.K respectively.

The performance of double U-barrier USB-3PL3BR was found to be the best out of various single and double barriers of U-shaped. The same trend was noted for flat shape barrier also where FSB-3PL3BR was the best in thermal performance.

The performance of flat plate barrier arrangement FSB-3PLMT was found to be better than FSB-3SS for almost all scenarios of shank spacing, k_s and k_g ; the same trend followed for U-shape barrier also where USB-3PLMT outperformed USB-3SS.

The absolute reduction in length achieved by using a double flat plate barrier was not twice that of the single metallic barrier under the same operating conditions, but instead showed a slight increase. For instance, with k_s of 0.5 W/m.K and k_g of 0.585 W/m.K, the BHX length reduction was improved from 6.4 m/kW_t to 7.8 m/kW_t, representing a further reduction of 1.4 m/kW_t (or 22%) between the FSB-3BR and FSB-3PL3BR. This trend was even less pronounced at higher soil thermal conductivities of 1 and 2 W/m.K. For U-shaped barriers, the trend showed a marginal improvement over flat plate barrier.

4.3. Overall Comparison of Different Ground Heat Exchange Systems Discussed in this Study

The design of insulated outlet leg of the U-tube BHX was found to be ineffective in improving the heat transfer rate of the BHX. Design for the coaxial pipe arrangement showed the arrangement suitable to improve the heat transfer for medium and high thermal conductivity soil of 1 & 2 W/m.K. For soil with low thermal conductivity of 0.5 W/m.K, the significant short-circuit losses in coaxial pipes make the conventional U-tube a more favorable option compared to coaxial pipes.

Figure 25 to Figure 27 show the absolute reduction in the BHX length compared to the coaxial pipe arrangement for k_s of 0.5, 1 and 2 W/m.K respectively. The figures show the length reduction for the conventional U-tube BHX and for different scenarios of U-tube BHX with single and double barriers. The performance of the stainless-steel barrier options (FSB-3SS and USB-3SS) was found to be comparable to or lower than that of the FSB-3PLMT and USB-3PLMT options in most scenarios. As a result, for simplicity, the single stainless-steel barrier options have been omitted from these figures. Similarly, the performance of FSB-3PL3SS & USB-3PL3SS were found to be less than FSB-3PL1AL & USB-3PL1AL and therefore omitted.




Figure 25. Reduction in length for various arrangements of U-tube BHx compared to coaxial pipes; k_s : 0.5 W/m.K, (a) S_{min} (b) S_{avg} .




Figure 26. Reduction in length for various arrangements of U-tube BHx compared to coaxial pipes; k_s : 1 W/m.K, (a) S_{min} (b) S_{avg} .




Figure 27. Reduction in length for various arrangements of U-tube BHX compared to coaxial pipes; k_s : 2 W/m.K, (a) S_{min} (b) S_{avg} .

The minimum shank spacing (S_{min}) for the various U-tube BHX configurations shown in Figure 25 to Figure 27 varies depending on the geometry. It is 31.8 mm for the conventional U-tube BHX, 34.8 mm for the FSB-3BR and USB-3BR, 35 mm for the FSB-3PLMT and USB-3PLMT, 35.8 mm for the FSB-3PL1AL and USB-3PL1AL, and 37.8 mm for the FSB-3PL3BR and USB-3PL3BR. The average shank spacing is 50 mm across all options.

In **Figure 25** to **Figure 27**, for the configurations where the performance of the conventional U-tube BHX (without a barrier) is superior to the coaxial pipe arrangement, the contribution of the barrier to reducing the BHX length is the difference in length reduction between the conventional U-tube and the barrier-equipped option. For example, in **Figure 25**, with k_s and k_g values of 0.5 and 0.585 W/m.K at S_{avg} , replacing coaxial pipes with a conventional U-tube BHX reduces the length from 191.4 m/kW_t (for coaxial pipes) to 158.8 m/kW_t (for conventional U-tube). Adding the USB-3PL3BR barrier to the U-tube BHX further reduces the length to 148.2 m/kW_t.

The best-performing barriers were the double barriers made of 3mm plastic and 3mm brass, both in flat plate and U-shape configurations. The flat plate barrier FSB-3PL3BR outperformed the U-shape barrier USB-3PL3BR in reducing the BHX length for k_g value of 0.585 W/m.K. However, the USB-3PL3BR demonstrated better performance than the FSB-3PL3BR for k_g value of 2 W/m.K, as shown in **Figure 25** to **Figure 27**. The performance difference between FSB-3PL3BR and USB-3PL3BR was minimal for k_g value of 1 W/m.K.

5. Conclusions

Vertical Ground source heat pumps can be implemented as an economical option for heating/cooling, subject to its careful designing especially for the ground loop heat exchanger. Over-designing of this component will lead to uneconomical design, whereas under-designing will lead to discomfort. There is a need to adopt techniques for reducing the borehole thermal resistance or in other words to improve the heat transfer process across the BHX.

Various barrier arrangements between the two legs of U-tube BHX have been proposed which provide a viable alternative to conventional U-tube arrangements and serve as a better option than coaxial pipes in certain conditions of soil and grout thermal conductivity.

The options of double barrier arrangement FSB-3PL3BR & USB-3PL3BR have shown the best performance over a conventional U-tube BHX, with a possible saving of 7.8 & 8.1m in length of BHX per kW of heat transfer respectively for k_s of 0.5 W/m.K and k_g of 0.585 W/m.K. The other simple option of 3mm plastic barrier with 0.2mm metallic tape i.e., barrier arrangements FSB-3PLMT & USB-3PLMT, though offering comparatively lower heat transfer improvements may still perform economically, especially in settings where installation simplicity and cost-effectiveness are prioritized. A reduction of 7.3 & 7.5m in length of BHX per kW of heat transfer is possible from FSB-3PLMT & USB-3PLMT for k_s of 0.5 W/m.K and k_g of 0.585 W/m.K.

Based on **Figure 25** to **Figure 27**, we conclude the decision tree as shown in **Figure 28** for the selection of the best ground heat exchange system to get an optimized length of BHX. Soil of 0.5, 1 and 2 W/m.K is considered as low, medium and high thermal conductivity soil respectively. Grout thermal conductivity of 0.585, 1 and 2 W/m.K is considered low, medium and high respectively.




Figure 28. Decision tree for the type BHX for the minimum length.

The study demonstrates that the novel design of various geometries and materials of barrier between the two legs of a U-tube BHX presents viable alternative to conventional U-tube arrangements in ground heat exchanger systems and show better performance over coaxial pipes for low to medium thermal conductivity soil and grout. Although flat & U-shape barriers with 3mm plastic & 3mm brass were the best options of the barrier for length reduction, the other options discussed in the study which showed an improvement in the heat transfer may also be considered based on simplicity in construction or lower cost. A cost-benefit analysis is recommended for the selection of the type of BHX arrangement among the various options discussed for a given soil condition, especially where the difference between various options is marginal.

The study for barrier techniques in this study is limited to two-dimensional steady state analysis. Further numerical study with a three-dimensional analysis may precisely determine the resulting reduction in the BHX length. Dynamic modelling may also help in the précised determination of the overall improvement in the heat transfer for the long-term. A minimum overall barrier thickness of 3mm has been considered to ensure the strength and stability of the barrier for deep burial in the vertical borehole. Structure analysis for the précised thickness of the barrier may be undertaken for further optimization. The study can be continued for double U-pipe arrangement and other configurations.

Author Contributions: This research work was conducted as a part of Asfia Nishat's Master by Research program supervised by Dr. Hossam Abuel Naga, at Latrobe University, Melbourne, Australia.

Nomenclature for the Barrier Arrangements Discussed

FSB-3PL1: Flat plate shape barrier- 3mm plastic of thermal conductivity 0.17 W/m.K
 FSB-3PL2: Flat plate shape barrier- 3mm plastic of thermal conductivity 0.5 W/m.K
 FSB-3PL3: Flat plate shape barrier- 3mm plastic of thermal conductivity 2 W/m.K
 FSB-3PLMT: Flat plate shape barrier- 3mm plastic of thermal conductivity 0.17 W/m.K & 0.2mm metal tape of thermal conductivity 200 W/m.K
 FSB-3SS: Flat plate shape barrier- 3mm stainless steel of thermal conductivity 16 W/m.K
 FSB-3BR: Flat plate shape barrier- 3mm brass of thermal conductivity 109 W/m.K
 FSB-3PL1AL: Double flat plate shape barrier- 3mm plastic of thermal conductivity 0.17 W/m.K & 1mm aluminum of thermal conductivity 237 W/m.K
 FSB-3PL3SS: Double flat plate shape barrier- 3mm plastic of thermal conductivity 0.17 W/m.K & 3mm stainless steel of thermal conductivity 16 W/m.K
 FSB-3PL3BR: Double flat plate shape barrier- 3mm plastic of thermal conductivity 0.17 W/m.K & 3mm brass of thermal conductivity 109 W/m.K
 USB-3PL: U-shape barrier- 3mm plastic of thermal conductivity 0.17 W/m.K
 USB-3PLMT: U-shape barrier- 3mm plastic of thermal conductivity 0.17 W/m.K & 0.2mm metal tape of thermal conductivity 200 W/m.K
 USB-3SS: U-shape barrier- 3mm stainless steel of thermal conductivity 16 W/m.K
 USB-3BR: U-shape barrier- 3mm brass of thermal conductivity 109 W/m.K
 USB-3PL1AL: Double U-shape barrier- 3mm plastic of thermal conductivity 0.17 W/m.K & 1mm aluminum of thermal conductivity 237 W/m.K
 USB-3PL3SS: Double U-shape barrier- 3mm plastic of thermal conductivity 0.17 W/m.K & 3mm stainless steel of thermal conductivity 16 W/m.K
 USB-3PL3BR: Double U-shape barrier- 3mm plastic of thermal conductivity 0.17 W/m.K & 3mm brass of thermal conductivity 109 W/m.K

Other Nomenclature

A_c : Area of cross-section in m^2
 BHX: Borehole heat exchanger
 BHXs: Borehole heat exchangers
 C_p : Specific heat at constant pressure in $kJ/kg.K$
 ΔT : Temperature difference
 D_b : Borehole diameter in mm or m
 D_h : Hydraulic diameter in mm or m
 D_p : Pipe external diameter in mm or m
 h : Convective heat transfer coefficient of the fluid in W/m^2K
 k_g : Grout thermal conductivity in $W/m.K$
 k_p : Pipe thermal conductivity in $W/m.K$
 k_s : soil thermal conductivity in $W/m.K$

kWt: kilo-watt thermal
 L: Length of U tube pipe
 m_f: Mass flow rate of fluid
 Nu: Nusselt number
 Pr: Prandtl number
 Q or q: Heat flow rate in W/m
 Q_{in}: Heat transfer rate in the inlet pipe in W/m
 Q_{out}: Heat transfer rate in the outlet pipe in W/m
 q_{gen}: Heat generated in W
 r_i: Pipe internal radius in mm or m
 r_b: Borehole radius in mm or m
 Re: Reynolds number
 R_b: Thermal resistance of borehole in (W/m.K)⁻¹
 R_{fo}: Thermal resistance of fluid in the inside pipe for coaxial pipes in (W/m.K)⁻¹
 R_{fo}: Thermal resistance of fluid in the outside pipe for coaxial pipes in (W/m.K)⁻¹
 R_g: Thermal resistance of grout in (W/m.K)⁻¹
 R_{ins}: Thermal resistance of insulation for coaxial pipes in (W/m.K)⁻¹
 R_p: Thermal resistance of pipe for U-tube BHX in (W/m.K)⁻¹
 R_{pi}: Thermal resistance of inside pipe for coaxial pipes in (W/m.K)⁻¹
 R_{po}: Thermal resistance of outside pipe for coaxial pipes in (W/m.K)⁻¹
 R_{pvc}: Thermal resistance of PVC protective pipe for coaxial pipes in (W/m.K)⁻¹
 R_s: Thermal resistance of soil in (W/m.K)⁻¹
 R_{sc}: Thermal resistance due to short-circuit between inlet & outlet pipes in (W/m.K)⁻¹
 R_t: Total thermal resistance of BHX in (W/m.K)⁻¹
 S or s: Shank spacing in mm or m
 S_{max}: Maximum Shank spacing in mm or m
 S_{avg}: Average Shank spacing in mm or m
 S_{min}: Minimum Shank spacing in mm or m
 T_s: undisturbed soil temperature at far-field boundary in °C
 T_{bhw}: temperature of borehole wall in °C
 T_r: Average Fluid Temperature of inlet and outlet pipe of U tube heat exchanger in °C
 T_{fi}: Average Fluid Temperature of inlet pipe of U tube heat exchanger in °C
 T_{fo}: Average Fluid Temperature of outlet pipe of U tube heat exchanger in °C
 V_{avg}: Average velocity of fluid in m/s
 α: Thermal diffusivity in m²/s
 ρ: Density in kg/m³
 τ: Time
 γ: Euler's constant = 0.5772

Abbreviations

ASHRAE: American Society of Heating, Refrigeration & Air-conditioning Engineers
 GSHP: Ground source heat pump
 HDPE: High density polyethylene
 PDE: Partial differential equation
 PE: Polyethylene
 TRT: Thermal response test
 PVC: Polyvinyl Chloride
 uPVC: Un-plasticized polyvinyl chloride

References

1. Sarbu, I. and C. Sebachievici, *Using Ground-Source Heat Pump Systems for Heating/Cooling of Buildings*, in *Advances in Geothermal Energy*. 2016. p. 17.
2. Kavanaugh, S. and K. Rafferty, *Geothermal heating and Cooling, Design of Ground Source heat Pump systems*. 2014: W. Stephen Comstock.
3. ASHRAE-Applications, ed. *ASHRAE Handbook, Applications, SI Edition 2023*. ed. A.T. Committees. 2023.
4. Yoon, S., S. Lee, and G. Go, *A numerical and experimental approach to the estimation of borehole thermal resistance in ground heat exchangers*. *Energy*, 2014. **71**: p. 547-555.
5. Lamarche, L., *Fundamentals of Geothermal Heat Pump Systems, Design and Application*. 2020: Springer Nature Switzerland AG
6. Al-Chalabi, R., *Thermal Resistance of U-tube Borehole Heat Exchanger System: Numerical Study, Thesis for Master of Philosophy in the Faculty of Engineering and Physical Sciences, School of Mechanical, Aerospace and Civil Engineering, University of Manchester.*, in *School of Mechanical, Aerospace and Civil Engineering, University of Manchester*. 2013.
7. Kerme, E.D., A.S. Fung, and W.H. Leong, *Analysis of the Combined Effect of Major Influencing Parameters for Designing High-Performance Single (sBHE) and Double (dBHE) U-Tube Borehole Heat Exchangers*. *Energies*, 2024. **17**(11).
8. Shen, J., et al., *Comprehensive thermal performance analysis and optimization study on U-type deep borehole ground source heat pump systems based on a new analytical model*. *Energy*, 2023. **274**.
9. Erol, S. and B. François, *Efficiency of various grouting materials for borehole heat exchangers*. *Applied Thermal Engineering*, 2014. **Volume 70**(1): p. 788-799.
10. Mahmoud, M., et al., *A review of grout materials in geothermal energy applications*. *International Journal of Thermofluids*, 2021. **10**: p. 100070.
11. Liu, X., et al. *An Analysis on Cost Reduction Potential of Vertical Bore Ground Heat Exchangers Used for Ground Source Heat Pump Systems*. in *Stanford Geothermal Workshop 44th Annual Conference*. 2019. Stanford, California, United States of America.
12. Zanchini, E., et al., *Effects of flow direction and thermal short-circuiting on the performance of coaxial ground heat exchangers in International Conference on Renewable Energies and Power Quality (ICREPQ'09) 2009: Valencia, Spain*.
13. Brown, C.S., et al., *Comparison of the thermal and hydraulic performance of single U-tube, double U-tube and coaxial medium-to-deep borehole heat exchangers*. *Geothermics*, 2024. **Volume 117**.
14. Harris, B.E., et al., *Analysis of the transient performance of coaxial and u-tube borehole heat exchangers*. *Geothermics* 2022 **101**.
15. Chen, J., et al., *Research on ground-coupled heat exchangers*. *International Journal of Low-Carbon Technologies*, 2010. **5**(1): p. 35-41.
16. Chen, H. and I. Tomac, *Technical review on coaxial deep borehole heat exchanger*. *Geomechanics and Geophysics for Geo-Energy and Geo-Resources*, 2023. **9**(1).
17. Ngo, I.L. and V.H. Ngo, *A new design of ground heat exchanger with insulation plate for effectively geothermal management*. *Geothermics*, 2022. **105**.
18. ASHRAE-Fundamentals, *ASHRAE Handbook, Fundamentals, SI Edition, 2021*, ed. A.T. Committees. 2021: ASHRAE.
19. Javadi, H., et al., *Performance of ground heat exchangers: A comprehensive review of recent advances*. *Energy*, 2019. **178**: p. 207-233.
20. Magdic, L., T. Zakula, and L. Boban, *Improved Analysis of Borehole Heat Exchanger Performance*. *Energies*, 2023. **16**(17).
21. Mendrinos, D., S. Katsantonis, and C. Karytsas, *Pipe materials for borehole heat exchangers*, in *European Geothermal Congress 2016: Strasbourg, France*.
22. Eskilson, P., *Thermal Analysis of Heat Extraction Boreholes*, in *Department of Mathematical Physics*. 1987, University of Lund, Sweden.
23. Ruan, W. and W.T. Horton, *Model-Based Performance Analysis of a Single Borehole in Ground Heat Exchanger*, in *International High Performance Buildings Conference*. 2010: Purdue.

24. Zhou, K., et al., *Prediction and parametric analysis of 3D borehole and total internal thermal resistance of single U-tube borehole heat exchanger for ground source heat pumps*. Energy and Built Environment, 2023. **4**(2): p. 179-194.
25. F. Naterer, G., *Advanced Heat Transfer*. 2021, Milton, United Kingdom: Taylor & Francis Group.
26. Faizal, M., A. Bouazza, and R.M. Singh, *Heat transfer enhancement of geothermal energy piles*. Renewable and Sustainable Energy Reviews, 2016. **57**: p. 16-33.
27. Sadeghi, H. and R.M. Singh, *Driven precast concrete geothermal energy piles: Current state of knowledge*. Building and Environment, 2023. **228**: p. 109790.
28. <https://toyesi.com.au/>, *Are Geothermal Heat Pumps for Me*. 2024, Toyési.
29. Barry-Macaulay, D., et al., *Thermal conductivity of soils and rocks from the Melbourne (Australia) region*. Engineering geology, 2013. **164**: p. 131-138.
30. Usowicz, B., et al., *Thermal properties of soil in the Murrumbidgee River Catchment (Australia)*. International journal of heat and mass transfer, 2017. **115**: p. 604-614.
31. Allan, M.L. and S.P. Kavanaugh, *Thermal Conductivity of Cementitious Grouts and Impact On Heat Exchanger Length Design for Ground Source Heat Pumps*. HVAC&R Research, 2011. **5**(2): p. 85-96.
32. Holman, J.P., *Heat Transfer, Tenth Edition*. 2010: McGraw Hill.
33. <https://www.engineeringtoolbox.com>, *Thermal Conductivity of common Materials and Gases*. n.d.
34. Olam, M., *Mechanical and Thermal Properties of HDPE/PET Microplastics, Applications, and Impact on Environment and Life*. IntechOpen, 2023.
35. acu-tech.com.au, *HDPE Pipe Systems, Product Catalogue*. Acu-Tech Piping systems.
36. Sharqawy, M.H., E.M. Mokheimer, and H.M. Badr, *Effective pipe-to-borehole thermal resistance for vertical ground heat exchangers*. Geothermics, 2009. **38**(2): p. 271-277.
37. Lamarche, L., S. Kajl, and B. Beauchamp, *A review of methods to evaluate borehole thermal resistances in geothermal heat-pump systems*. Geothermics, 2010. **39**(2): p. 187-200.
38. Liao, Q., et al., *Effective Borehole Thermal Resistance of A Single U-Tube Ground Heat Exchanger*. Numerical Heat Transfer, Part A: Applications, 2012. **62**(3): p. 197-210.
39. Abuel-Naga, H. and R. Al-Chalabi, *Borehole thermal resistance of U-tube borehole heat exchanger*. Géotechnique Letters, 2016. **6**(4): p. 250-255.
40. Paul, N.D., *The Effect of Grout Thermal Conductivity on Vertical Geothermal Heat Exchanger Design and Performance*. 1996, South Dakota University, Vermillion, SD, USA: USA.
41. Bennet, J., J. Claesson, and G. Hellström, *Multipole method to compute the conductive heat transfer to and between pipes in a composite cylinder*. Notes on heat transfer 3-1987. , in Department of Building Physics. 1987, Lund Institute of Technology, Lund, Sweden.
42. Gu, Y. and D.L. O'Neal, *Development of an equivalent diameter expression for vertical U-tubes used in ground-coupled heat pumps*. ASHRAE Transactions, 1998. **104**: p. 347.
43. Hellström, G., *Ground heat storage, thermal analyses of duct storage systems, part I: Theory*, in *Mathematical Physics*. 1991, University of Lund, Lund, Sweden: Sweden.
44. Shonder, J.A. and J.V. Beck, *Field test of a new method for determining soil formation thermal conductivity and borehole resistance / Discussion*. ASHRAE Transactions, 2000. **106**: p. 843.
45. Javed, S. and J.D. Spitler, *Calculation of borehole thermal resistance*, in *Advances in Ground-Source Heat Pump Systems*, S. Rees, Editor. 2016, Elsevier Science & Technology.
46. <http://www.aeroflexusa.com>, *EPDM Sheet and Roll insulation Data Sheet 062424*. 2024, Aeroflex.
47. Luo, Y., G. Xu, and T. Yan, *Performance evaluation and optimization design of deep ground source heat pump with non-uniform internal insulation based on analytical solutions*. Energy and Buildings, 2020. **229**.
48. Yavuzturk, C., *Modelling of vertical ground loop heat exchangers for ground source heat pump systems*, in *Faculty of the Graduate College 1999*, Oklahoma State University
49. Pan, A., et al., *A new analytical heat transfer model for deep borehole heat exchangers with coaxial tubes*. International Journal of Heat and Mass Transfer, 2019. **141**: p. 1056-1065.
50. Gnielinski, V., *Turbulent Heat Transfer in Annular Spaces—A New Comprehensive Correlation*. Heat Transfer Engineering, 2015. **36**(9): p. 787-789.
51. Steel, A., *Pipe Dimensions chart Rev Jan 2012*

52. Box, T.E.T., *ANSI Schedule 40 Steel Pipes - Dimensions*. n.d.
53. www.iplex.com.au, *Iplex PVC U Pressure Series-1 Pipe-Dimensions*. n.d.
54. <https://www.professionalplastics.com>, *Professional Plastics Thermal Properties of Plastic Materials* n.d.
55. Patti, A. and D. Acierno, *Thermal Conductivity of Polypropylene-Based Materials*. 2019.
56. www.3M.com/electronics, *3M(TM) Thermally Conductive Heat Spreading Tape 9876*.
57. Thyssenkrupp, *Stainless Steel 304 - 1.4301 Data Sheet thyssenkrupp Materials (UK)*. 2024.
58. Zhang, A. and Y. Li, *Thermal Conductivity of Aluminum Alloys-A Review*. Materials (Basel), 2023. **16**(8).

Disclaimer/Publisher's Note: The statements, opinions and data contained in all publications are solely those of the individual author(s) and contributor(s) and not of MDPI and/or the editor(s). MDPI and/or the editor(s) disclaim responsibility for any injury to people or property resulting from any ideas, methods, instructions or products referred to in the content.