

1 *Research Article*

## 2 3 **Effectiveness of Prevailing Flush Guidelines to** 4 **Prevent Exposure to Lead in Water**

5  
6 **Adrienne Katner<sup>1\*</sup>, Kelsey Pieper<sup>2</sup>, Komal Brown<sup>1</sup>, Hui-Yi Lin<sup>1</sup>, Jeffrey Parks<sup>2</sup>, Xinnan Wang<sup>1</sup>,**  
7 **Chih-yang Hu<sup>1</sup>, Sheldon Masters<sup>3</sup>, Howard Mielke<sup>4</sup> and Marc Edwards<sup>2</sup>**

8  
9 <sup>1</sup> School of Public Health, Louisiana State University Health Center, New Orleans, LA, USA; [akatn1@lsuhsc.edu](mailto:akatn1@lsuhsc.edu)

10 <sup>2</sup> Department of Civil and Environmental Engineering, Virginia Tech, Blacksburg, VA, USA;

11 [kpieper@lsuhsc.edu](mailto:kpieper@lsuhsc.edu)

12 <sup>3</sup> Corona Environmental Consulting, Philadelphia, PA, USA; [smasters@coronaenv.com](mailto:smasters@coronaenv.com)

13 <sup>4</sup> Department of Pharmacology, Tulane University, School of Medicine, New Orleans, LA, USA;

14 [hmielke@tulane.edu](mailto:hmielke@tulane.edu)

15 \* Correspondence: [akatn1@lsuhsc.edu](mailto:akatn1@lsuhsc.edu); +1504-568-5942

16  
17  
18  
19 **Abstract:** Flushing tap water is often promoted as a simple and low cost approach to reducing water  
20 lead exposures. This study evaluated lead reduction when prevailing flush guidelines (30 seconds-2  
21 minutes) are implemented in a city compliant with lead-associated water regulations (New Orleans,  
22 LA). Water samples (n=1,497) collected from a convenience sample of 376 residential sites (2015-2017)  
23 were analyzed for lead in samples collected: at 1) first draw (n=375), and after incremental flushes of 2)  
24 30-45 seconds (n=375), 3) 2.5-3 minutes (n=373), and 4) 5.5-6 minutes (n=218). There was no significant  
25 reduction when compared to the first draw lead level, until the 6 minute flush (p<0.05); but most sites  
26 (52%) still had detectable lead (≥1 ppb) after 6 minutes. Older homes (pre-1950) and low occupancy  
27 sites had significantly higher WLLs (p<0.05). Each sample type had health-based standard exceedances  
28 at over 50% of sites sampled (max: 58 ppb). While flushing is an effective short-term approach to  
29 remediate high lead, prevailing flush recommendations are an inconsistently effective exposure  
30 prevention measure that can often inadvertently increase exposures. Public health messages should be  
31 modified to ensure appropriate application of flushing for specific cities, while acknowledging its  
32 short-comings and practical limitations.

33  
34 **Keywords:** drinking water; lead; Pb; flush; exposure prevention; intervention; lead service line

## 43 1. Introduction

44

45 The knowledge that no safe threshold for childhood lead exposures has been found [1], and increased  
46 awareness of lead in drinking water triggered by the events in Flint, Michigan, have contributed to a  
47 renewed emphasis on preventing exposure to Pb in drinking water. Waterborne Pb may be a more  
48 significant source of total Pb to young children when compared to estimates made three decades ago [2],  
49 and can represent the most significant source for formula-fed infants [3]. In 2010, the United States (U.S.)  
50 Environmental Protection Agency (EPA) acknowledged that significant “exposure to <water> lead may  
51 be taking place, even though the action level is not exceeded” [4]. Water lead levels (WLLs) below the  
52 drinking water Pb Action Level (AL=15 ppb) are predicted to cause exceedance of the U.S. Centers for  
53 Disease Control and Prevention’s (CDC) childhood BLL Reference Level [5 micrograms per deciliter  
54 ( $\mu\text{g}/\text{dL}$ )] in 9-25% of exposed children [5,6]. Chronic exposure to water lead levels (WLLs) as low as 1  
55 ppb, which is the detection limit for many laboratories, have been estimated to increase a child’s BLL by  
56 35% after 150 days [7]. This information underscores a critical need for vulnerable populations to take  
57 proactive precautionary measures to prevent chronic exposures to low-dose waterborne lead.

58 The EPA’s Lead and Copper Rule (LCR) regulates control of Pb in tap water [3]. It mandates that  
59 water utilities sample tap water in high-risk homes (i.e., homes with lead service lines (LSLs), and homes  
60 with copper pipes with lead solder installed after 1982). The EPA requires that no more than 10% of post-  
61 stagnation first draw water samples exceed the Pb AL. In 2015, the National Drinking Water Advisory  
62 Council re-emphasized that the LCR was not intended to ensure protection of all individuals from  
63 waterborne Pb exposure; rather, it was designed as a regulatory tool to identify system wide problems  
64 and broadly reduce lead exposure [8]. Lead from sites built prior to 1986 can be derived from lead service  
65 lines (LSL), which are often the greatest contributor to water lead when it is present [9]. Water lead can  
66 also come from Pb solder in homes built before 1986, or from galvanized pipes and brass faucet  
67 fixtures/fittings through present day construction [10].

68 Flushing is a widely recommended practice to reduce consumer exposure to Pb. Studies report that  
69 repeated periods of extended flushing at high flow rates are an effective remediation strategy when there  
70 are high levels of dissolved Pb [11-16]. The Consumer Confidence Report Rule (CCR) (63 FR 44511,  
71 §141.154) requires that water utilities promote flushing on all annual reports to consumers, “regardless  
72 if a system did or did not detect lead” [17]. This requirement was brought about by EPA’s recognition  
73 that even in LCR-compliant cities, “there are situations where the most vulnerable populations may be  
74 exposed to elevated levels of lead for many months before or without being notified” [17]. The EPA also  
75 requires utilities to promote flushing when a utility is not LCR-compliant. The original messaging  
76 required by the Public Education provision of the LCR (56 FR 26460 §141.85) was “Run the water for 15-  
77 30 seconds [or one minute if the home has a LSL], before drinking water to flush lead from interior  
78 plumbing” [3,17].

79 The Washington D.C. Lead Crisis (2001-2004) first demonstrated that the standard water lead  
80 avoidance flushing guidance was inadequate during action level exceedances, and that flushing only 15-  
81 30 seconds would directly expose consumers to hazards of water that had been held within the LSLs [3,  
82 15, 18]. A decade of follow up research has since confirmed that flushing protocols which reduce  
83 exposure in a given home, are highly dependent on variables that are difficult or impossible to control,

84 including, but not limited to: length, configuration, material, condition and disturbance of service lines  
85 or plumbing; water use patterns; spatial changes in chemical and microbiological water quality within a  
86 given distribution system; and type of Pb released (particulates vs dissolved) [9-11, 14-15, 19-37]. In light  
87 of the evidence challenging the efficacy of flushing under different conditions, the EPA identified a need  
88 to further evaluate flushing [38], and revised the LCR and CCR to allow utilities to modify the required  
89 flush time recommendations if they determine longer flush times are needed [17, 39-40]. The EPA  
90 indicated in its updated guidance to utilities that “It is likely that systems with lead service lines will  
91 need to collect data to determine the appropriate flushing times” [4].

92 However, this knowledge has not translated into widespread changes in public health messaging or  
93 policies, perhaps because of the dearth of published data on flushing ineffectiveness under select  
94 conditions. Despite the new flexibility authorized by the EPA, industry knowledge of the inconsistent  
95 effectiveness of flushing, and acknowledgement by government officials about the uncertainty of optimal  
96 flush times and frequencies, officials from water utilities [41] and federal agencies [42-44] continued to  
97 provide outdated outreach materials with the harmful advice to flush water for 15 - 30 seconds in systems  
98 with LSLs. While some utilities and public health officials have resorted to adding a general caveat to  
99 their risk reduction messages, that “longer flushing may be required” dependent on site specific site  
100 circumstances, that message does nothing to inform consumers when that instruction applies to their  
101 situation; and it leaves open what “longer flushing” means.

102 This study explicitly examines concerns that flushing may not be an effective lead reduction strategy  
103 in LCR-compliant cities with LSLs. Prior research on flushing efficacy has typically been conducted in  
104 cities with non LCR compliant systems (i.e., high WLLs and LCR exceedances), rather than the lower-to-  
105 moderate WLLs that are typically associated with water systems with optimized corrosion control  
106 treatment [31]. To address this gap, this study was conducted in New Orleans, Louisiana (NOLA), a city  
107 which has consistently met LCR requirements. Best estimates from the mid-1990s suggested that LSLs  
108 may comprise 65-80% of the city’s service line system [45]. After EPA regulations on flush time  
109 recommendations were relaxed, the city’s water utility, the Sewerage and Water Board (S&WB),  
110 continued to promote the original flush recommendations from 2009 to 2015 [41, 46]. At the  
111 commencement of this study, the S&WB encouraged residents to flush their taps “for 30 seconds to 2  
112 minutes before using water for drinking or cooking” daily under normal use conditions [41] (**Figure S1,**  
113 **Supplementary Materials**). New Orleans is also representative of many U.S. cities today, in that it has  
114 relatively non-corrosive water, and an aging drinking water infrastructure in need of repair [47].  
115 Hurricane damage to water infrastructure has necessitated a multi-year project to repair and replace  
116 corroding water mains, LSLs and other underground utilities throughout the city. While over ten years  
117 have passed since Hurricane Katrina, the rebuilding process is ongoing- city and utility officials are also  
118 in the process of conducting 16,000 partial lead service lines replacements (PLSLRs) [48].

119 The primary aim of this study is to evaluate the effectiveness of prevailing flush time  
120 recommendations commonly promoted by utilities and public health officials for New Orleans.  
121 Specifically, lead levels were measured in cold water post-stagnation samples that were collected at first  
122 draw and after various flush times (30 seconds, 2.5-3 minutes and 5.5-6 minutes). A second objective of  
123 this study is to identify factors which may be associated with WLLs in an effort to better understand

124 conditions which may contribute to high WLLs, and identify sites in potential need of targeted  
125 monitoring, outreach, or intervention. Results reveal that low-occupancy and older homes have  
126 significantly higher WLLs; and suggest that LSLs may be a main contributor to NOLA WLLs. Flushing  
127 according to prevailing guidelines (30 seconds to 2 minutes) does not result in significant or substantial  
128 WLL reductions in the city of New Orleans.

129

130

## 131 2. Materials and Methods

132

### 133 2.1 Site selection and sampling campaign

134

135 This study focused recruitment and sampling efforts in NOLA- in particular, on the city's East Bank  
136 of the Mississippi River (the city's source water). Specific information about the water treatment plants  
137 can be found in the **Supplementary Materials** section. Between February 2015 and November 2016, a  
138 convenience sample of 450 NOLA residents were recruited via news media and word of mouth to  
139 participate in a free water testing effort. Of the original 450 study participants, 421 returned self-collected  
140 water samples (94% return rate), and 381 returned self-administered surveys (85% return rate). A total of  
141 1,497 samples were collected from 375 occupied homes under normal use conditions that met any of the  
142 criteria for potential risk, which included: (1) sites with LSLs or galvanized pipes based on S&WB data  
143 or self-reports (10%); (2) buildings constructed prior to 1950 based on self-reports an approach used by  
144 (59%)[49]; (3) homes of families with lead-poisoned children directed to the study by State's Office of  
145 Public Health (8%); and buildings located in high risk neighborhoods, as determined by the S&WB's  
146 LCR-compliance data (26%). Participant and household characteristics (and associated mean WLLs) are  
147 presented in **Table S2 (Supplementary Materials)**. Some sites met multiple criteria- for example, of the  
148 8% of homes with lead-poisoned children, 76% also lived in pre-1950 homes and one reported having a  
149 LSL. Some sites were excluded due to either improper collection of water samples (2 sites) or sampling  
150 outside of the water utility's service area (10 sites).

151 To evaluate WLLs in buildings under atypical conditions, samples were also collected by either the  
152 researchers or building owners from 14 sites. These included schools (n=9); and homes with full or partial  
153 LSL replacements (n=5). Residents in homes with LSL replacements were encouraged to purchase water  
154 filters if continued use of the water for drinking or cooking was expected. All of these sites were analyzed  
155 separately from normal use occupied homes.

156 Participation entailed collecting tap water and completion of a household survey. The study  
157 protocols and survey were reviewed and approved by the LSU Health Sciences Institutional Review  
158 Board (FWA 00002762) to assure protection of human research subjects (IRB 8870). Participation in the  
159 study did not begin until a study consent had been obtained. The lengths of water service lines and  
160 premise plumbing pipes were estimated based on resident measurements reported on returned surveys  
161 (**Figure S2, Supplementary Materials**). Residents were asked to measure the distance from the middle  
162 of the street to the water line as it enters the home (service line length) and the distance from where line  
163 enters home to the kitchen tap as measured along wall (premise plumbing). Researchers also derived  
164 google map measurements of potential service line lengths for all sites, based on measures taken from

165 the center of the street to the front of the home in the satellite view of Google Maps using the distance  
166 and area tool.

167

## 168 2.2 Sampling protocol

169

170 Residents were provided with a sampling kit that contained: (1) sampling instructions, (2) four 250  
171 mL wide-mouth sampling bottles, (3) pre-paid return postage, and (4) a questionnaire about the  
172 household and water use characteristics (see survey in **Supplementary Materials**). To evaluate the  
173 effectiveness of flush time recommendations, residents were instructed to collect unfiltered tap water  
174 from the kitchen sink, after a 6+ hour stagnation period. Residents were instructed not to clean or take  
175 off their aerator prior to the stagnation period or water collection. Residents were instructed to collect  
176 water at “normal to high water flow” (estimated flow rate of 3.0 to 8.3 liters/minute [0.8 to 2.2  
177 gallons/minute]) [50]. Specifically, a 250 mL first draw cold-water sample (FD) was collected and the  
178 water was shut off. A 250 mL first draw hot sample (FDH) was then collected from the hot water tap and  
179 immediately shut off after sample collection (the FDH water sample was not collected after the water  
180 temperature increased, rather it was collected at first draw). Two samples were collected after flushing  
181 cold water for 30-45 seconds (F30S), and after flushing for an additional 2 minutes (2.5-3 minutes total  
182 flushing; F3M). Throughout the entire study, all sites were asked to collect FD, F30S, and F3M samples.  
183 Mid-way through the study, it became apparent that flushing did not consistently reduce WLLs. At this  
184 point, an extended flush time sample was collected in lieu of the FDH samples. Residents were asked to  
185 flush their taps for an additional 3 minutes after collecting the F3M samples. These new samples (F6M)  
186 were collected after a 5.5-6 minute total flush time. Samples that were reported by residents to have been  
187 collected inappropriately were removed from the analyses. At some sites, multiple sample sets were  
188 collected from different water sources throughout the building. For these sites, only results for the tap  
189 which had the highest WLLs were retained to represent site conditions.

190

## 191 2.3 Analytical methods

192

193 Sampling kits were shipped by residents to Virginia Tech for analysis. Water samples were  
194 acidified with nitric acid (2% v/v) and digested for 16+ hours before analysis on a Thermo Electron X-  
195 Series Inductively Coupled Plasma – Mass Spectrometry (ICP-MS) per method 3125 B [51]. Blanks  
196 and/or spikes of known concentrations were processed every 10 samples for QA/QC purposes, with a  
197 reporting limit of 1.0 ppb. Blind negative controls, which consisted of filtered water, were sent to the  
198 lab to confirm laboratory reporting (n=9). Other source-specific metals were analyzed to evaluate  
199 correlations with WLLs and identify potential Pb sources in NOLA tap water. These included:  
200 cadmium, chromium, copper, iron, nickel, tin, and zinc.

201

## 202 2.4 Statistical analysis

203

204 The WLLs for the FD, FDH, F30S, F3M, and F6M samples were summarized using descriptive  
205 statistics. Samples with WLLs less than 1 ppb were below our reporting limit (1 ppb) and were considered  
206 non-detects (ND). To represent ND numerically, these samples were assigned a value of half the  
207 reporting limit (0.5 ppb). The WLL differences between samples collected after various flushing times  
208 and the FD sample were tested using the Wilcoxon signed-rank test. Statistical analyses were performed  
209 in SAS Version 9.4 (SAS, Cary, NC). The significance level in this study was defined as  $p\text{-value} < 0.05$ ,  
210 unless otherwise stated.

211 To identify factors associated with WLLs, mean WLLs and standard deviations for FD samples were  
212 calculated by participant and household characteristics. The candidate factors included participant  
213 characteristics (income, race and education) and household factors (number of occupants in household,  
214 number of children < 6 years old, presence or absence of street or sidewalk work within the last 6 months  
215 on site block, era of building construction (pre-, and post-1950), home type (single-family, multi-family,  
216 apartment complex), home ownership (own or rent), and water usage). Water usage, based on resident  
217 reports from last monthly utility bill (monthly total and average daily water usage), had a limited sample  
218 size ( $n=38$ ) so it was not included in modeling. Factors associated with the mean WLL (ppb) and percent  
219 of sites with detectable WLL ( $\geq 1$  ppb) based on all samples types were analyzed using parametric linear  
220 mixed models, and mixed-effects logistic models, respectively. Both univariate and multivariable models  
221 were conducted to evaluate the relationship between WLLs and participant and household factors.  
222 Factors with a  $p\text{-value} < 0.2$  in the models after adjusting for flush time were candidates for building the  
223 multivariable models. The final multivariable models only included predictors with a  $p\text{-value} < 0.05$ .

224 To evaluate WLLs in relation to health or regulatory criteria for all samples and by sample type, the  
225 percent of samples exceeding the following standards, criteria or goals was derived: (1) the American  
226 Academy of Pediatrics' (AAP) recommended level for water in schools (AAP RL,  $>1$  ppb) [52]; (2) the  
227 U.S. Food and Drug Administration's (FDA) allowable lead level in bottled water (FDA AL,  $>5$  ppb) [53];  
228 (3) the World Health Organization's (WHO) provisional guideline value for Pb in water (WHO GV,  $>10$   
229 ppb) [54], (4) the US EPA's Pb AL ( $>15$  ppb) [3], and (5) the US EPA's Maximum Contaminant Level Goal  
230 (MCLG) for Pb, the WLL that EPA considers to be safe, is zero ppb (US EPA 1991 [3]).

231 To determine the most probable location in the water distribution system or premise plumbing that  
232 each sample type may have been sitting during the stagnation period, an estimate of the volume of water  
233 and flush times required to purge the lines was derived based on estimated flow rates at low flow (3.0  
234 liters per minute) and high flow (8.3 liters per minute); typical premise and service line pipe diameters;  
235 and survey respondent measurements of service lines and premise plumbing (**Figure S2, Supplementary**  
236 **Materials**). A 250-mL sample is estimated to represent water in approximately 2.4 meters (or 8 feet) of  
237 piping.

238

239

### 240 3. Results

241

#### 242 3.1 Water lead levels and flushing efficacy for normal use occupied homes

243

244 Descriptive summary statistics for WLLs from normal use occupied homes (**Table 1**), indicate  
245 median WLLs for the FD, F30S, F3M and F6M cold water samples of 1.4, 1.7, 1.4 and 1.1 ppb, respectively.  
246 Overall NOLA WLLs were typically low relative to the 15 ppb EPA action level, as 88% of all samples  
247 from normal-use NOLA sites had WLLs  $\leq 5$  ppb. However, low-dose waterborne Pb exposures ( $\geq 1$  ppb)  
248 are widespread across the city, as half of all samples from normal use sites (60%) had detectable WLLs  
249 of at least 1 ppb or higher (**Table 1**). Median and maximum WLLs were highest for post-stagnation  
250 samples collected after the 30 second flush (F30S), and lowest for post-stagnation samples collected after  
251 a 6 minute total flush (F6M). There was wide variability in WLLs across the sample pool, with WLLs  
252 ranging from non-detect ( $<1$  ppb) in each sample type to a maximum of 58 ppb in F30S samples. The  
253 cumulative distributions of total Pb concentrations by water sample type for normal use occupied homes  
254 did not change substantially between FD samples and F30S or F3M samples (**Figure 1**). It was not until  
255 after 6 minutes of flushing that a decrease in the WLL distribution was observed.

256 The results of the statistical analyses of changes in WLLs from FD to flushed samples (Wilcoxon  
257 signed rank test), and the distributions of changes from FD WLLs to WLLs in flushed and hot water  
258 samples (**Table 2, Figure 2**) demonstrate a small but significant increase (0.6 ppb) in median WLLs from  
259 FD to F30S sample. No significant change in WLLs was observed from FD to F3M samples. Small (0.2-0.4  
260 ppb) but significant declines in median WLLs was observed in F6M and FDH samples, compared to FD  
261 samples (**Table 2; Figure 2**). Even after flushing for 5.5 to 6 minutes, over half of F6M samples (52%,  $n=218$ )  
262 still had detectable Pb ( $\geq 1$  ppb), while 7% had WLLs  $> 5$  ppb (**Table 1**). Flushing may seem to have  
263 induced the mobilization of particulate Pb into water, as evidenced by high "spikes" in some post-  
264 flushing samples- WLLs increased by as much as 50 ppb after 30 seconds of flushing (**Table 2**).

265

266

267

268

269

270

271

272

273

274

275

276

277

278


279

**Table 1.** Distribution of post-stagnation WLLs (ppb) under normal use conditions (New Orleans, LA, 2015-2017)

Sample Type	N	Median WLL	Mean WLL	SD	25 <sup>th</sup> Percentile WLL <sup>a</sup>	75 <sup>th</sup> Percentile WLL	90 <sup>th</sup> Percentile WLL	Max WLL	% Detectable ( $\geq 1$ ppb)
FD	375	1.4	2.3	2.5	0.5	2.9	5.3	16.5	65.3
FDH	156	1.3	2.2	2.7	0.5	2.4	4.4	17.8	60.3
F30S	375	1.7	2.9	5.0	0.5	3.2	6.0	58.1	61.3
F3M	373	1.4	2.5	3.0	0.5	3.2	6.1	22.1	58.2
F6M	218	1.1	1.9	2.1	0.5	2.3	4.2	11.9	52.3
All	1497	1.4	2.4	3.4	0.5	2.9	5.6	58.1	60.1

<sup>a</sup>Samples with WLLs below the reporting level were assigned a value of half the reporting limit or 0.5 ppb.

**Key:** FD: first draw cold sample; F30S: flushing cold water for 30-45 seconds; F3M: flushing cold water for 2.5-3 minutes; F6M: flushing cold water for 5.5-6 minutes; FDH: first draw hot sample; WLL: water lead level; SD: Standard Deviation



280

281 **Figure 1.** Cumulative distribution of total WLLs in occupied normal-use homes by sample type (n=1497

282 samples from 375 sites) (FD: first draw; F30S: 30-45 second total flush; F3M: 2.5-3 minute total flush; F6M:

283 5.5-6 minute total flush)

284

285

286




**Table 2.** Change in WLLs after flushing (vs FD WLLs) (ppb)

Samples <sup>a</sup>	N	Median (25%, 75%)	Mean ±SD	Min	Max	90 <sup>th</sup> percentile	287
							288 p-value <sup>b</sup>
F30S vs. FD	374	0 (-0.4,0.6)	0.6±4.2	-9.4	50.2	1.7	0.040
F3M vs. FD	372	0 (-0.5,0.6)	0.2±2.1	-12.5	15.4	2.1	0.219
F6M vs. FD	218	0 (-0.6,0)	-0.2±1.4	-5.8	7.5	0.7	<0.001
FDH vs. FD	155	-0.1 (-0.9,0)	-0.4±2.4	-12.9	12.1	0.7	<0.001

<sup>a</sup> FD: first draw cold sample; F30S: flushing cold water for 30-45 seconds; F3M: flushing cold water for 2.5-3 minutes; F6M: flushing cold water for 5.5-6 minutes; FDH: first draw hot sample.

<sup>b</sup> Compare with FD based on the Wilcoxon signed-rank test



289

290 **Figure 2.** Distributions of the difference in WLLs in cold water samples collected at first draw (FD)

291 compared to WLLs in samples collected after various flush times (F30S: 30 second flush; F3M: 2.5-3

292 minute flush; F6M: 5.5-6 minute flush) and first draw hot (FDH) samples.

293

294

295 **Table 3** presents the number of samples in each WLL category by sample type; and **Table 4** presents

296 the number and percent of samples with a change in WLL detection or with insubstantial WLL changes

297 (&lt; 1 ppb), compared to FD WLLs. The majority of the households (80-81%) had no change in WLL (&lt;1

298 ppb difference) in flushed samples compared to FD samples (**Table 4**). In general, most NOLA homes

299 with FD WLLs below the reporting limit (&lt;1 ppb) continued to have WLLs &lt;1 ppb in flushed samples. Of

300 sites with FD WLLs &lt;1 ppb, 79%, 83% and 86% also had WLLs &lt;1 ppb in F30S samples (n=136), F3M

301 samples (n=135), and F6M samples (n=86), respectively (**Table 3**). Additionally, most NOLA homes with

302 detectable FD WLLs (≥ 1 ppb) continued to have WLLs ≥ 1 ppb in flushed samples. Of sites with FD

303 WLLs  $\geq 1$  ppb, 82%, 79% and 75% also had WLLs  $\geq 1$  ppb in F30S samples (n=238), F3M samples (n=237),  
 304 and F6M samples (n=132), respectively. (Tables 3).

305

306

**Table 3.** Water lead levels (WLLs) in first draw vs flushed cold samples

FD WLL (ppb)	F30S WLL (ppb) (n)						F3M WLL (ppb) (n)						F6M WLL (ppb) (n)					
	<1	1-4.9	5-9.9	10-14.9	$\geq 15$	n	<1	1-4.9	5-9.9	10-14.9	$\geq 15$	n	<1	1-4.9	5-9.9	10-14.9	$\geq 15$	n
<1	108	27	0	0	1	136	112	22	1	0	0	135	74	12	0	0	0	86
1-4.9	41	134	15	2	4	196	48	127	18	1	1	195	33	75	3	0	0	111
5-9.9	1	6	22	3	3	35	1	10	20	3	1	35	0	8	9	2	0	19
10-14.9	0	2	2	1	0	5	1	1	2	0	1	5	0	0	1	0	0	1
>15	0	0	0	1	1	2	0	0	0	1	1	2	0	0	0	1	0	1
n	150	169	39	7	9	374	162	160	41	5	4	372	107	95	13	3	0	218

**Key:** FD: first draw cold sample; F30S: flushing cold water for 30-45 seconds; F3M: flushing cold water for 2.5-3 minutes; F6M: flushing cold water for 5.5-6 minutes

307

**Table 4.** Flushing effectiveness based on reaching non-detect (ND: <1 ppb)

	F30S (%)	F3M (%)	F6M (%)
Detect in FD to ND	42 (11%)	50 (13%)	33 (15%)
ND in FD to detect	28 (7%)	23 (6%)	12 (5%)
No change (<1 ppb difference)	304 (81%)	299 (81%)	173 (80%)
Total n of sample type	374	372	218

**Key:** FD: first draw cold sample; F30S: flushing cold water for 30-45 seconds; F3M: flushing cold water for 2.5-3 minutes; F6M: flushing cold water for 5.5-6 minutes; ND: Non-detect (< 1ppb).

308

309

310 Some sites went from detect in FD samples to non-detect in flushed samples: F30S=11%, F3M=13%,  
 311 and F6M=15% (Table 4). Mean WLLs for samples with detectable lead ( $\geq 1$  ppb) decreased with increased  
 312 flushing (F30S: 2.11 ppb, n=224; F3M: 2.04 ppb, n=210; F6M: 2.00 ppb, n=111). This indicates some value  
 313 in flushing, however, even a six minute flush does not guarantee lower WLLs for all customers- 5% of  
 314 sites went from non-detect FD WLLs (<1 ppb) to detect ( $\geq 1$  ppb) after flushing for 6 minutes (n=218)  
 315 (Table 4). Median WLLs for samples with detectable lead ( $\geq 1$  ppb) remained the same after increased  
 316 flushing (F30S: 2.00 ppb, n=224; F3M: 2.00 ppb, n=210; F6M: 2.00 ppb, n=111). A small proportion of sites  
 317 also went from non-detect FD WLLs (<1 ppb) to detect ( $\geq 1$  ppb) after flushing for 30 seconds (7%, n=374),

318 and 3 minutes (6%, n=372) (**Table 4**). For sites which had FD, F30S and F3M samples (n=372), 28% had  
319 WLLs that increased by >1 ppb with a 30 second or 3 minute flush.

320

321 *3.2 Water lead levels and flushing efficacy associated with atypical use conditions*

322

323 While not a planned part of the study, conditions arose which allowed us to evaluate the impact of  
324 a one-time 15-minute utility flush on WLLs after LSL replacements at five residential sites. LSL  
325 replacements and construction are known to increase lead in water due to construction disturbances and  
326 galvanic corrosion for periods of weeks to years [19, 30, 38]. While over ten years have passed since  
327 Hurricane Katrina, the rebuilding process is still ongoing, and the city of New Orleans (NOLA) is still in  
328 the process of conducting 16,000 PLSLRs [48]. These conditions were evident during this sampling effort,  
329 as 43% of survey respondents reported there was street or side walk work on their block within the last  
330 year (n=287). Five of our study participants contacted the S&WB after our testing to request removal of  
331 their LSLs. All but one of these residents received a partial LSL replacement (PLSLR) (i.e., only the utility  
332 or customer side was replaced); while one had the full LSL replaced (from water main in the street to the  
333 home). All of the sites were sampled prior to, and after the LSL replacements and the utility or contractor  
334 15-minute post-replacement flush. Only one of these homes was unoccupied due to ongoing home  
335 renovation work. **Table 5** shows sampling procedures and WLL results for each site- unfortunately,  
336 collection procedure for the samples varied from home to home. No definitive conclusions can be drawn  
337 from the post-LSLR samples due to the small sample size and variance in the sampling procedures.  
338 However, the persistent elevation in WLLs (exceeding the EPA AL) can be seen within the week after the  
339 line replacement in occupied homes, in both the full LSLR site (6 days later) and PLSLR Site 3 (1-2 days  
340 later). Post-LSL replacement WLLs reached as high as 226 ppb one day after the PLSLR after a post-  
341 stagnation 30 second flush. These results suggest that rigorous extended flushing protocols may need to  
342 be repeated on a daily basis for an as yet indeterminate time period following line replacements.

343

344

345

346

347

348

349

350

351

352

353

354

355

356

357

358 **Table 5.** Water lead levels in pre- and post-LSL replacement samples (n=5)

Site	WLLs in Post-Line Replacement Samples (ppb)				WLLs in Post-LSL replacement samples (ppb)				Post-Line Replacement Samples
	FD	FDH	F30S	F3M	S1	S2	S3	S4	
Full LSLR	6.5	9.1	<b>49.2<sup>a</sup></b>	12.6	<b>17.8</b>	3.0	2.8	NS	S1: 6 days after LSLR & 45 sec PS flush S2: 2 weeks after LSLR & 45 sec PS flush; S3: 3 weeks after LSLR & 45 sec PS flush
PLSLR Site 1	5.0	2.6	5.8	9.8	0.5	0.5	0.5	0.5	2 weeks after PLSLR and oversight stagnation: S1: FD; S2: F30S; S3: F3M; S4: F6M
PLSLR Site 2	6.4	5.3	<b>24.7</b>	6.8	<b>16.8</b>	10.7	5.5	NS	S1: Immediately after PLSLR & 15 min utility flush; S2: 2 days after PLSLR, PS FD; S3: 3 days after PLSLR, PS FD
PLSLR Site 3	<b>30.0</b>	<b>151.9</b>	7.4	1.3	6.5	<b>225.8</b>	<b>61.8</b>	NS	S1: Immediately after PLSLR and 15 min utility flush; S2: 1 day after PLSLR, F30S PS flush; S3: 2 days after PLSLR, F30S PS flush
PLSLR Site 4 (uninhabited)	<b>161.4</b>	NS	<b>26.6</b>	<b>283.5</b>	<b>64.5</b>	2.5	0.5	0.5	Immediately after PLSLR and 15 min utility flush: S1: FD; S2: F30S; S3: F3M; S4: F6M

<sup>a</sup>Bold WLLs exceeded the EPA AL of 15 ppb. **Key:** LSLR: lead service line replacement; PLSLR: partial lead service line replacement; WLLs: water lead levels; NS: no sample; FD: first draw sample; FDH: first draw hot water sample; F30s: 30 second flush sample; F3M: 3 minute flush sample; PS: Post-stagnation (6+ hour of stagnation prior to water collection); S#: Sample number.

359

360

361 *3.3 Identifying predictive factors for WLLs*

362

363 Select survey variables were evaluated using univariate and multivariate models to identify factors  
364 that may be significantly correlated with WLLs. **Table S2** presents factors considered in univariate and  
365 multivariate mixed models and associated mean FD WLLs. **Table 6** presents the factors associated with  
366 mean WLL (ppb) in all samples after adjusting for flush time; and **Table 7** presents the factors associated  
367 with the percent of sites with detectable Pb ( $\geq 1$  ppb) after adjusting for flush time.

368 After adjusting for number of occupants and era of home construction, the mean WLL increase for  
369 F30S and decrease for F6M samples (compared to FD samples) remained significant [ $\beta$  coefficient=0.68  
370 ( $p=0.017$ ) and -0.25 ( $p=0.020$ ), respectively] (**Table 6**). A decreased likelihood of having detectable Pb  
371 ( $\geq 1$ ppb) was observed after both the 3- and 6-minute flush time compared to FD samples (OR=0.68 and  
372 0.58 with  $p<0.001$  and  $<0.001$ , respectively) (**Table 7**).

Besides flush time, the number of occupants and age of homes were significantly associated with WLLs (ppb), after adjusting for flush time ( $p < 0.05$ ) (Tables 6-7). Occupancy was associated with mean WLLs (Tables 6), and the percent of sites with detectable WLLs ( $\geq 1$  ppb) (Table 7). The era in which the homes was built was associated with the percent of sites with detectable WLLs ( $\geq 1$  ppb) (Table 7). Lower occupancy homes and older homes (pre-1950) were associated with higher WLLs. Mean WLL in FD samples decreased as occupancy increased: 1 occupant=3.9 ppb; 2-3 occupants=2.4 ppb; and  $\geq 4$  occupants = 1.8 ppb (Table S2). Likewise, the prevalence of detectable WLLs in FD samples decreased with occupancy: 1 occupant=92%, 2-3 occupants=68% and  $\geq 4$  occupants=64%. The latter trend is expected given prior work showing that less water use can increase water lead problems [55-56]. Mean WLLs in FD samples decreased in newer homes: Pre-1950=2.4 ppb; Post-1950=1.9 ppb (Table S2); as did the prevalence of detectable WLLs in FD samples: Pre-1950=73.4%; Post-1950=48.5% ( $n=375$ ), which is expected given increased lead content in plumbing with age. This same trend was observed for prevalence of detectable WLLs in older homes in F30S samples ( $p < 0.0001$ ,  $n=375$ ), and F3M samples ( $p=0.010$ ,  $n=373$ ), but not for WLLs in F6M samples ( $p=0.069$ ,  $n=218$ ).

While pre-1950 homes are more likely to have LSLs, the lack of information on LSL presence at all sites limited our ability to evaluate the impact that LSLs may have on WLLs and flushing efficacy. While there was significant difference in mean WLLs by neighborhood and zip code, with higher WLLs in older areas of the city which may have been more likely to have LSLs (Kruskal-Wallis test,  $p < 0.05$ ), the lack of random sampling, and the low sample size in many neighborhoods prevents any definitive conclusions about spatial variability in WLLs. While it is suspected that high WLLs associated with low occupancy homes may be due to reduced water usage, and hence greater water stagnation and Pb leaching, it was not possible to evaluate the association between number of occupants and water use due to the low number of sites reporting that data ( $n=38$ ).

Table 6. Factors associated with mean water lead level in all samples (ppb)<sup>a</sup>

Effect	Univariate model (n=376)		Multivariable model (n=325)	
	Model coefficient (ppb)	P-value	Model coefficient (ppb)	P-value
<b>Flush time (min)</b>				
0	Reference		Reference	
0.5	<b>0.57</b>	<b>0.019</b>	<b>0.68</b>	<b>0.017</b>
3	0.19	0.110	0.19	0.134
6	<b>-0.28</b>	<b>0.001</b>	<b>-0.25</b>	<b>0.020</b>
<b>Occupants</b>				
0-1			Reference	
2-3	-	-	<b>-1.08</b>	<b>0.023</b>
$\geq 4$			<b>-1.67</b>	<b>0.0006</b>
<b>Era build</b>				
Post-1950	-	-	Reference	
Pre-1950			<b>0.59</b>	<b>0.062</b>
Unknown			<b>0.98</b>	<b>0.041</b>

<sup>a</sup>Based on the mixed model; bold:  $p < 0.0$

398

399 **Table 7.** Factors associated with percent of homes with detectable water lead level ( $\geq 1$  ppb) <sup>a</sup>

Effect	Univariate model (n=376)		Multivariable model (n=325)	
	OR (95% CI) <sup>b</sup>	P-value	OR (95% CI) <sup>b</sup>	P-value
<b>Flush time (min)</b>				
0	Reference		Reference	
0.5	0.82 (0.65-1.02)	0.079	0.78 (0.60-1.00)	0.053
3	<b>0.70 (0.58-0.85)</b>	<b>&lt;0.001</b>	<b>0.68 (0.54-0.84)</b>	<b>&lt;0.001</b>
6	<b>0.61 (0.50-0.74)</b>	<b>&lt;0.001</b>	<b>0.58 (0.47-0.72)</b>	<b>&lt;0.001</b>
<b>Occupants</b>				
0-1	-	-	Reference	
2-3			<b>0.26 (0.09-0.74)</b>	<b>0.012</b>
$\geq 4$			<b>0.20 (0.07-0.56)</b>	<b>0.003</b>
<b>Era build</b>				
Post-1950	-	-	Reference	
Pre-1950			<b>2.95 (1.80, 4.83)</b>	<b>&lt;0.001</b>
Unknown			1.25 (0.60-2.61)	0.545

400 <sup>a</sup>Based on the mixed model; bold:  $p < 0.05$ ; <sup>b</sup>Odds ratio (95% confidence interval)

401

402

403

404

405 *3.4 Source evaluation*

406

407

408

409

410

411

412

413

414

415

416

417

418

419


420

421

422

While lack of information on site plumbing materials limited our ability to ascertain the specific source of WLLs in NOLA water system, the observation of peak WLLs in 30-45 second or 2 minute flush samples at 49% of tested sites (n=372), is consistent with the expectation that this flush time is very likely to capture water that was held inside the LSL [3, 11]. An estimate of the volume of water and flush times required to purge LSL of stagnant water was derived based on estimated flow rates, typical pipe diameters, and lengths of service lines and premise plumbing (n=80). **Figure S2** presents the distribution of line lengths (premise + service) reported by survey respondents (n=80). The majority (75%) reported line lengths of 30 meters or less; and one quarter of survey respondents measured premise plumbing plus service line lengths of  $>30$  meters. There were no significant differences in the lengths of service lines for pre- or post-1950 homes ( $p=0.172$ ). **Figure 3** presents the estimated time to flush by total length of service lines and premise plumbing ( $\frac{3}{4}$  or  $\frac{1}{2}$  inches in diameter). Based on plumbing line length estimates presented in **Figure 3**, and an estimate that each 250-mL sample represents water in approximately 8 feet of piping; if a home has the average resident-reported premise + service pipe length of 75 feet (23 meters) with a typical pipe diameter of  $\frac{3}{4}$  inches, a flush time of 2.2 minutes would be required to purge any water sitting in the plumbing or service line over night, when water is run at low flow (3.0 liters per minute). Under a different scenario in which residents run their taps at low flow and have an average

423 reported pipe length of 30 m (premise + service line) approximately 3-minutes of flushing might be  
 424 required. When the water is flushed at high flow (8.3 liters per minute), the same system might be flushed  
 425 in less than a minute (0.8 minutes). Given that study participants were instructed to collect water at  
 426 normal to high flows, and the fact that most respondents had plumbing lengths of 30 meters or less, it is  
 427 likely that WLLs associated with service lines would often reach the tap by 30 seconds. This may explain  
 428 why a peak WLL as high as 58 ppb was observed for in the F30S sample, which was from a single  
 429 occupant home. More time is needed to fully flush the system as the length of plumbing increases, as the  
 430 rate of water flow decreases, and as the diameter of the pipe decreases.  
 431



432

433 **Figure 3.** Estimated time to flush premise plumbing (P) and service line (S) (minutes) based on water  
 434 flow rate (liters per minute), pipe diameter (3/4 or 1/2 inches) and survey-reported P+S length  
 435 (meters)(n=80) [Note: Low flow: 3.0 meters per minute; High flow: 8.3 Liters per minute]  
 436

437 To identify the potential source of NOLA's water lead (i.e., type of plumbing), correlations between  
 438 WLLs and levels of common metals found in other plumbing materials were determined. If specific  
 439 plumbing materials other than LSLs are associated with high WLLs, one would expect to see positive  
 440 correlation between WLLs and metals in those alloys. For example, zinc (Zn) may indicate the presence  
 441 of galvanized water pipes or brass faucet fixtures; nickel (Ni) may indicate the presence of brass faucet  
 442 fixtures; iron (Fe) may indicate the presence of iron water mains; copper (Cu) may indicate the presence  
 443 of copper pipe or brass faucet fixtures; tin (Sn) may indicate the presence of leaded solder; chromium  
 444 may indicate the presence of stainless steel and cadmium (Cd) may indicate the presence of galvanized  
 445 water pipes. No significant strong correlations were observed between any of the metals and WLLs for  
 446 any of the flushed samples ( $P < 0.3$ ,  $p < 0.05$ ). Most samples had no detectable Cd or Sn. These results are

447 consistent with lead from LSLs, which are essentially pure lead, or possibly that many sources are  
448 contributing to WLLs in NOLA water.

449 In Cartier et al. [57], the second consecutive sample was successfully used to confirm the presence  
450 of LSLs in 92% of homes for which LSL presence was documented (at water temperatures above 17°C).  
451 In that study, LSL presence was considered confirmed if the second liter sample after a 15-minute  
452 stagnation period exceeded 3 ppb. If such an approach were used it is necessary to validate WLL  
453 thresholds specific to the system and type of buildings sampled [40]. Given the lack of data to validate  
454 LSL presence for NOLA sites, we could not confirm a lead threshold for NOLA that would enable  
455 accurate validation of the presence of LSLs. However, we did observe for NOLA homes with validated  
456 or reported LSLs (n=38), 37% had WLLs exceeding 3 ppb in FD samples (n=38), as did 37% of F30S  
457 samples (n=38), 40% of F3M samples (n=38), and 32% of F6M samples (n=28). In a similar vein, among  
458 the set of sites with validated or reported LSLs combined with the set of “pre-1950” homes, which we  
459 use as an indicator of potential LSL presence (n=259), 27% of FD samples exceeded 3 ppb (n=259), as did  
460 30% of F30S samples (n=258), 29% of F3M samples (n=257), and 21% of F6M samples (n=143). These data  
461 may lend support to the assumption that LSL presence may lead to sustained WLLs.

462 Further investigations are needed to support the speculation that LSL are a primary risk contributor  
463 in NOLA. But together these data suggest that LSLs may be a major contributor to NOLA: 1) the sustained  
464 low WLLs throughout the NOLA water systems (i.e., throughout all of the different sample types)  
465 (**Figure 1**); 2) the lack of strong significant correlations between WLLs and metals from other plumbing  
466 materials, 3) the occurrence of peak WLLs in flushed samples (**Table 1**); and 4) the significantly higher  
467 WLLs in homes more likely to have LSLs (pre-1950 homes).

468

### 469 3.5. Comparison to utility compliance sample results and evaluation of sufficiency of FD compliance sampling

470

471 Sampling was not conducted as required under the LCR, as samples were not collected exclusively  
472 in warm months (June- September), and sampled sites could not be verified as being high-risk (50% of  
473 sites with LSLs). Thus WLL results are not be representative of required regulatory compliance samples.  
474 In the last utility-reported sampling season, the S&WB’s WLL data for post-stagnation first-draw LCR  
475 compliance samples had a 90<sup>th</sup> percentile WLL of 7 ppb- only 1.6% of compliance samples exceeded the  
476 15 ppb Pb AL (n=60, S&WB 2017). Our results for WLLs in FD samples only are consistent with the  
477 utility’s compliance data, with a 90<sup>th</sup> percentile of 5.3 ppb- <1% of FD WLLs exceeded 15 ppb (n=375,  
478 **Table 1**). A separate analysis was conducted to evaluate WLLs among FD samples, based on sites and  
479 samples that may meet LCR sampling requirements (i.e., sites with reported or validated LSLs and pre-  
480 1950 homes, and samples collected between June and September). The 90<sup>th</sup> percentile WLL remained  
481 within regulatory limits (5.4 ppb).

482 There is some debate about how representative LCR’s required FD compliance samples are of worst-  
483 case scenario exposures (i.e., highest WLLs). First draw samples are also frequently relied upon by many  
484 state lead poisoning prevention and school sampling programs to characterize potential risk [58-59]. Each  
485 sample type (FD, F30S, F3M and F6M) met LCR AL requirements (90<sup>th</sup> percentile ≤15 ppb); though there  
486 were increases in the percent of sites exceeding the AL from 0.5% in FD samples, to 2.4% in F30S samples



487 (Table 8). Even a small increase in the proportion of homes exceeding the AL could have an impact on  
 488 LCR-compliance in cites that are on the borderline of Pb AL exceedances. While there were increases  
 489 from the 90<sup>th</sup> percentile FD WLL value (5.4 ppb) after flushing for 30 seconds (6.0 ppb) and 3 minutes  
 490 total (6.1 ppb) among tested NOLA sites, these increases were minimal (<1 ppb) (Table 1) and would not  
 491 have exceeded the action level trigger, even if worse case flushed samples had been “counted” under the  
 492 regulation.

493

494

### 495 3.6 Comparison of WLLs to health guidelines, standards and goals

496

497 To evaluate the public health relevance of results, WLLs were evaluated against existing health-  
 498 based standards, guidelines or goals (Table 8). Twelve percent of samples had WLLs which exceeded the  
 499 Food and Drug Administration’s (FDA) Allowable Level (AL) for Pb in bottled water (5 ppb) set in 1994  
 500 [53]; while only 2.7% of all samples at normal use occupied homes had WLLs which exceeded the World  
 501 Health Organization’s (WHO) provisional Guidance Value (GV) of 10 ppb set in 2011 [54]. The WHO’s  
 502 provisional GV is not entirely health-based, as other considerations, such as treatment performance and  
 503 analytical achievability, were considered in GV derivation [54]. WHO maintains that provisional  
 504 guideline values are set for “contaminants for which calculated health-based values are not practically  
 505 achievable” [60].

506

**Table 8.** Comparison of NOLA WLLs (ppb) in normal use residential sites to standards (2015-2017)

Sample Type	N	% > AAP RL (1 ppb)	% > FDA AL (5 ppb)	% > WHO GV (10 ppb)	% > EPA’s AL (15 ppb)
FD	375	65.1	11.7	1.9	0.5
FDH	156	60.3	8.3	3.2	0.6
F30S	375	61.1	14.7	4.3	2.4
F3M	373	58.2	14.2	2.4	1.1
F6M	218	52.3	7.3	1.4	0.0
All	1497	60.0	12.1	2.7	1.1

**Key:** AAP RL: American Academy of Pediatrics recommended water lead level for schools; FDA  
 AL: United States Food and Drug Administration’s Allowable Levels of lead in bottled water; WHO  
 GV: World Health Organization’s Guidance Value for lead in water; EPA AL: United States  
 Environmental Protection Agency’s Action Level for lead in water; WLLs: Water lead levels; NOLA:  
 New Orleans, LA.

507

508

509 One recommended health-based level that was set more recently is the American Academy of  
 510 Pediatrics (AAP) recommended WLL limit for schools (RL) of 1 ppb [52]. Overall, 60% of all samples  
 511 from normal use occupied homes exceeded AAP’s recommended Pb level for school water systems

512 (Table 8). Excluded from analyses were the WLL results of nine schools. Of the samples collected from  
513 the nine schools (n=67), 27% exceeded 1 ppb. The percent of school samples with WLLs exceeding 1 ppb  
514 decreased with increased flushing: FD=38%, n=18; F30S=28%, n=18; F3M=17%, n=18; F6M=10%, n=10.

515 Samples exceeding the AAP recommended level for lead in school water also exceeded the EPA's  
516 Maximum Contaminant Level Goal (MCLG) for Pb (0 ppb), the WLL that EPA considers to be safe [3];  
517 and California EPA's Public Health Goal of 0.2 ppb for Pb in water, which was decreased from 2.0 ppb  
518 in 2009 based on neuro-developmental effects of Pb for fetuses and children [61]. These results are  
519 pertinent, as 33% percent of our sample population reported having children less than six years of age  
520 (n=376).

521 The CDC is considering lowering the childhood blood reference value to 3.5 µg/dL [62]. The US EPA  
522 has released tentative results based on the Integrated Exposure Update and Biokinetic model (IEUBK),  
523 which estimate that WLLs of 3.8 ppb and 5.9 ppb could result in a 1% increase in the probability of a child  
524 (formula-fed infants and children 0-7 years of age, respectively) having a BLL of 3.5 µg/dL for families  
525 residing in pre-1950 homes with a high likelihood of having lead-based paint) [63]. Such home conditions  
526 are common in NOLA- 79% of this study's respondents resided in pre-1950 homes. The percent of  
527 sampled sites with WLLs >3.8 ppb increased from 18% in FD samples, to 20% and 22% in F30S and F3M  
528 samples, respectively. This percentage declined to 14% in F6M samples. Similarly, the percent of sampled  
529 sites with WLLs >5.9 ppb increased from 8% in FD samples, to 12% and 11% in F30S and F3M samples,  
530 respectively. This percentage declined to 6% in F6M samples. Thus, flushing according to prevailing  
531 exposure reduction guidelines (3- seconds to 2 minutes) may increase the likelihood of higher WLL  
532 exposures, and higher associated BLLs. Those performing longer flushes (F6M) could increase the  
533 likelihood of reducing their WLLs exposures and associated BLLs.

534

### 535 3.7 Evaluation of potential exposures to lead in water

536

537 Risks do not occur unless both a hazard and an exposure route to that hazard exists. To evaluate  
538 potential Pb exposure, survey respondents answered questions about water use habits, flushing  
539 practices, use of water treatment or filtration devices (survey in **Supplementary Materials**). Almost all  
540 respondents (93%) reported using unfiltered tap water for either cooking or drinking at some point in  
541 time (n=277). Only 21% of survey respondents reported flushing water prior to use (=277). Of these  
542 respondents (n=58), 48 reported their flush times- most flushed for half a minute or less (69%); 75% for 1  
543 minute or less; 92% for 2 minutes or less; and only 8% flushed for over 2 minutes. Peak WLLs for  
544 respondents reporting flushing occurred in: FHD samples for 40% of respondents; F30S samples for 29%;  
545 F3M samples for 29%; and F6M for 3%. While there was not widespread application of flushing  
546 guidelines among study participants, those who did flush water prior to use, may not be flushing long  
547 enough to see significant or substantial WLL decreases; and may also be inadvertently increasing  
548 exposures to WLLs (Tables 6-7).

549 The greatest risks from exposures to waterborne Pb are expected for infants reliant on formula  
550 reconstituted with unfiltered water- 15 respondents reported using unfiltered tap water to reconstitute  
551 baby formula (n=129). WLLs for these study participants ranged from <1 to 11 ppb. Based on EPA's

552 preliminary IEUBK model estimates for formula-fed infants, WLLs of 11 ppb could result in elevated  
553 BLLs in formula-fed infants (>5 µg/dL) when exposures to other sources like soil Pb or Pb-based paint  
554 are taken into consideration [63]. When only water exposures are considered, WLLs of 11 ppb could  
555 result in formula-fed infant BLLs above the CDC-proposed Pb reference value (>3.5 µg/dL) [62], and/or  
556 a 1 µg/dL increase in geometric mean BLLs [63]. When cumulative exposures are considered, Ngueta et  
557 al estimated that for every 1 µg/L increase in WLLs, childhood BLLs may increase by 35% after 150 days  
558 of exposure [7]. Among all samples, WLLs continued to exceed 1 ppb for the majority of all samples (60%,  
559 n=1497); even after flushing for 30 seconds (61%, n=375); for 2.5-3 minutes (58%, n=373); and 5.5-6 minutes  
560 (52%, n=218) (Tables 1, 8). These results suggest widespread exposure to WLLs of potential concern may  
561 be occurring in NOLA for infants who are regularly fed formula reconstituted with unfiltered tap water.

562

563

#### 564 4. Discussion

565

566

567

##### 4.1 *Flushing efficacy and practicality*

568

569

570

571

572

573

574

575

576

577

578

579

580

581

582

583

584

585

586

587

588

589

590

591

Our results indicate that flushing taps according to prevailing utility and public health recommendations (i.e., for thirty seconds to two minutes) may not consistently reduce WLLs and associated exposures either significantly or substantially when applied in a city with LSLs and at sites under normal use conditions (occupied residential sites with no prior line disruptions). In some cases, we observed that flushing for such short periods, especially after only 30-45 seconds, actually increased WLLs as predicted when LSLs are present in a city [3, 31, 38]. It is generally agreed that first-draw samples may be more representative of Pb from the faucet and premise plumbing; while water flushed for 30 seconds to 2 minutes may be more representative of Pb in the service lines [64-65]. However, significant, but not always substantial, reductions in WLLs were observed after extended flushing (after 5.5-6 minutes). These samples are most likely representative of water held in the water main, which are generally not expected to contain Pb. When Pb is detected in samples collected after extended flushing, it may suggest the Pb is picked up during flow from premise plumbing or LSLs. This can occur when there is Pb dissolution or particulate detachment from leaded plumbing [11, 15, 64].

In the aftermath of Flint, many school officials have been considering flushing as a routine water Pb exposure prevention measure. While the percent of residential and school samples with WLLs exceeding 1 ppb did decrease after extended flushing for 5.5 to 6 minutes, reductions in WLLs were not always substantial (>1 ppb). If the aim is to prevent childhood Pb exposure altogether, or at least reduce it to the minimal detectable levels (1ppb) as recommended by the AAP, then NOLA may require more proactive interventions to meet this goal, as over half of NOLA residences and one in ten school samples collected still had detectable Pb ( $\geq 1$  ppb) after extended flushing for 5.5 to 6 minutes. In cases where extended flushing does reduce Pb to non-detectable levels, the question then becomes how frequently would it be needed (e.g., once a day, after certain time periods of water stagnation, prior to each use, etc). Since sampling was only conducted at one point in time after a 6+ hour post-stagnation event, we could not verify that a one-time flush is sufficient to maintain low WLLs throughout the day. Some studies

592 evaluating flushing at school taps suggest frequent flushes may be needed throughout the day [66-67].  
593 Flushing frequency requirements could also not be ascertained for residential sites.

594 Prolonged flushing may also not be practical, cost-effective, or sustainable over the long term,  
595 especially in cities with declining water resources and/or rising water rates. Like many utilities across the  
596 country, NOLA's S&WB approved regular rate hikes in anticipation of water infrastructure repair needs-  
597 10% annually from 2013-2020 [68]. Yet, current water rates are already difficult for some NOLA residents  
598 to afford. An estimated 10% of FY 2015 NOLA customers were 30 or more days late in payment; and 19%  
599 of customer accounts were shut off for being unable to pay their bills [68]. NOLA's monthly residential  
600 water utility rate for FY 2015 was \$0.01 per gallon of water used or \$69.20 per month (assuming an  
601 average monthly water usage of 9.24 hundred cubic feet or 6,920 gallons)[67]. To put this into context the  
602 average FW 2015 water rate for customers of public utilities in the U.S. was \$0.005 per gallon or \$36.39  
603 for the same monthly water usage [68]. The same rate for Flint, Michigan, which has been touted as one  
604 of the highest water rates in the U.S., was \$0.0167 per gallon or \$115.56 for the same monthly water usage  
605 [69].

606 In the cases where flushing could be effective for remediating high WLLs, such as after PLSLRs,  
607 current flush practices (i.e., one-time 15 minute high velocity flush) may not be effective for maintaining  
608 low WLLs over a long period of time. Utilities are not always required to promote flushing, such as after  
609 PLSLRs in LCR-compliant cities; and flushing messaging is not always consistent. It is widely  
610 acknowledged that sites with PLSLRs may have higher WLLs; and may require more rigorous and  
611 regular flushing than normal-use residential sites under typical conditions. [38, 70]. As stated previously,  
612 NOLA has been undergoing extensive road work, including thousands of PLSLRs [48]. But the LCR only  
613 requires education of citizens about the risks of PLSLRs and benefits of flushing to reduce PLSLR-related  
614 Pb spikes when the utility exceeds the LCR's AL requirements [3]. When PLSLRs are conducted in LCR-  
615 compliant cities, educating consumers about flushing is only required once a year, in the utility's annual  
616 CCR. For homes undergoing PLSLRs, NOLA officials recommend on their Roadwork website, that  
617 residents "Run cold water at a high flow at all of your faucets for at least 5 minutes each, one at a time,  
618 starting with the faucet closest to your water meter"; clean faucets aerators; and continue to flush for at  
619 least a month before using the water [71]. At the start of this study, this information was not consistently  
620 communicated nor readily available to NOLA residents undergoing roadwork [72]. However, the  
621 persistent elevation in WLLs we observed days after the line replacements indicates that care should be  
622 taken to flush systems rigorously and regularly after line replacements (**Table 5**). It was only after the  
623 preliminary release of our results in 2016 that S&WB revised their risk messaging and increased their  
624 flush guidelines to "30 seconds to 5 minutes"; however elsewhere in the same material, the messaging  
625 remained "30 seconds to 2 minutes" [73] (**Figure S1, Supplementary Material**). The EPA's Science  
626 Advisory Board (SAB) stated that "the lack of mandatory water lead testing and homeowner education  
627 associated with voluntarily PLSLR suggests that in practice, voluntary replacement might be associated  
628 with greater exposure of the public to lead" [38]. The SAB recommends that utilities test the water and  
629 tell consumers to flush the lines "over a period of months" after a PLSLR; but concluded that while "line  
630 flushing appears to provide some benefit, the ... time to realize the benefit (up to several weeks of  
631 flushing in the reviewed studies) likely precludes any practical implementation of this technique" [38].

632 Despite the general knowledge about the ineffectiveness and potential danger that PLSLRs pose, they are  
633 still required by the LCR when certain compliance conditions have not been met [3].

634 More research is needed to evaluate how frequently flushing would need to be conducted to  
635 maintain low WLLs after a PLSLR. One study simulated PLSLRs in NOLA, and observed that  
636 intermittent flushing over a two week period was not long enough to stabilize WLLs [19]. In keeping,  
637 previous studies suggest several weeks, months, or maybe years may be required to remediate increased  
638 WLL exposure after PLSLRs [38, 74]. These facts do not discount the benefits of more rigorous flushing  
639 protocols as an effective Pb remediation method for some systems when high WLLs are present.  
640 Improved remediation has been observed with higher velocity flushing (full open tap); continuous  
641 flushing (as opposed to intermittent flushing); increased flushing frequency and duration; and flushing  
642 at multiple taps [9, 11-12, 19, 24].

643 However, residents should be alerted that when conditions are severe enough to warrant more  
644 rigorous flushing protocols, as observed here after PLSLRs, exposures to high WLLs are always a  
645 possibility. Flushing can mobilize particulate-bound Pb throughout the plumbing system, which can then  
646 serve as a long-term source of acute Pb exposure. Even after flushing water for 10-25 minutes, some Flint  
647 homes still had high WLLs [14]- at least one Flint tap still contained WLLs exceeding 15 ppb (217-13,200  
648 ppb) after a 26 minute flush [75]. This was likely due to the presence of highly unstable lead scales and  
649 the continuous sloughing of particulate lead during the time in which corrosion control was not used by  
650 Flint officials. Factors associated with maintaining low WLLs under such conditions, such as flushing  
651 frequency, must be determined on a case by case basis.

652

#### 653 *4.2 Regulatory implications*

654

655 Results underscore the importance of critically evaluating existing regulations in terms of their  
656 impact on reducing WLLs and Pb exposures. Mounting evidence, and US EPA assertions, also suggest  
657 that meeting the LCR does not always guarantee public health protection [4, 10, 39-40, 74, 76-77]. One  
658 critical step in addressing a risk, is to identify the location of the hazard. The EPA recognized a decade  
659 ago the need to identify where LSLs were installed, and henceforth required water systems to conduct  
660 audits of their service line materials. However, the cost and burden of this endeavor has resulted in a  
661 tolerated neglect of this responsibility by regulatory officials. Weaknesses are also evident in LCR  
662 compliance sampling requirements. For example, there are no stated requirements to include special-  
663 use sites like schools or homes with LSL replacements from LCR compliance sampling, as the intent of  
664 the LCR is to evaluate worst-case WLLs under normal residential water use patterns. However, in line  
665 with many cities experiencing water infrastructure breakdowns, NOLA has been conducting an  
666 unprecedented level of line replacements throughout the city, making these conditions and their  
667 associated risks more common. When such replacements were undertaken across the City of Flint, MI,  
668 all residents were notified of the risks and were provided free filters to remove lead for at least 6 months  
669 after replacements occurred [78]. Similar education and preventative measures are not required in LCR-  
670 compliant cities. But even when cities meet LCR AL requirements, other weaknesses inherent in the  
671 regulation, that is the requirements to collect only first draw samples, could impact LCR compliance

672 status, as the highest WLLs in NOLA water did not appear until after a 30-second or 2-minute flush at  
673 most sites. While this change in sampling protocol would not have affected NOLA's LCR compliance  
674 status, the difference we observed between FD and F30S samples in terms of the percent of samples  
675 exceeding the Pb AL (~2%) may be enough to impact compliance status for borderline systems with  
676 LSLs. Whether cities are compliant or not, there is always a risk of Pb exposure, especially in cities with  
677 LSLs, thus LCR communication requirements should be revised to require regular consumer education  
678 on more evidence-based technologies for reducing exposures. Finally, over the years, health-based  
679 standards for Pb in blood have declined, but the Pb AL for drinking water has never received a similarly  
680 critical re-evaluation. As over one quarter of all samples collected from the nine NOLA schools tested  
681 (n=67) exceeded AAP's recommended WLL for schools (1 ppb)(Table 8), the Pb AL should be  
682 reconsidered in light of low dose Pb impacts on vulnerable population; or a health-based trigger level  
683 should be developed. I

684

685

#### 686 4.3 Public health and risk communication implications

687

688 Infants, children and pregnant and lactating women are the most vulnerable populations. For these  
689 populations, the U.S. CDC [62, 79] and National Toxicology Program (NTP) [1] have asserted that there  
690 is no safe level of Pb exposure. The neurotoxicity of very low BLLs on the developing fetal and neonatal  
691 brain have been widely acknowledged to be associated with adverse behavioral and cognitive effects [1].  
692 Drinking water however, has frequently been overlooked as a potential source of Pb exposure in  
693 investigations of lead poisoning cases; despite the fact that EPA models indicate it can be the main  
694 contributor to infant BLLs [63], and it has been associated with BLL impacts at population-level [80-81].  
695 Yet, despite these facts and the weaknesses in the LCR [76-77], the CDC still recommends no water  
696 testing is needed in the homes of a lead-poisoned child if other sources of high Pb were found in the  
697 home, if residents are not on private well water, and if the city's water meets LCR AL requirements [79].  
698 As such, public health officials may not have not been monitoring WLLs in the homes of lead-  
699 poisoned children, or educating impacted families about lead in water issues. This can be a cause for  
700 concern, as in the case of LCR-compliant NOLA, residential WLLs as high as 58 ppb were measured.  
701 Model estimates (IEUBK) suggest that WLLs this high, if sustained, could result in a 5% increase in  
702 the probability of a child having an elevated BLL above the CDC's current reference value (5 µg/dL),  
703 just by water exposure alone [63]. When other sources are considered, the proportion of samples with  
704 WLLs exceeding just 3.8 ppb, a level the EPA estimates could raise the BLLs of a formula-fed infant and  
705 child above 3.5 µg/dL, CDC's proposed Pb reference value [62], ranged from 18% in FD samples, to 22%  
706 in F30S samples. While the cumulative impact of low-dose chronic waterborne Pb exposure on fetuses,  
707 infants, children and pregnant women is uncertain, one study found that for every 1 µg/L increase in  
708 WLLs, childhood BLLs may increase by 35% after 150 days of exposure [7]. Given the fact that these low  
709 dose levels of Pb are widespread in NOLA water [60% of all samples exceeded 1 ppb (n=1497)], a large  
710 proportion of the city's population of pregnant women and children may be at potential risk if they drink

711 or cook with unfiltered tap water on a regular basis. Survey responses indicate that consumption of  
712 unfiltered tap water either through drinking or cooking is not uncommon.

713 Changes in public health policies could be made to address ensure that CDC goals for preventing  
714 childhood Pb exposures are met [82]. One critical change would be to encourage WLL testing in the  
715 homes of lead-poisoned children. Environmental monitoring of WLLs for the purpose of exposure  
716 assessment could also be targeted to homes in cities with LSLs- especially older or low-occupancy homes,  
717 risk factors which have been identified in this and prior studies [55-56]. Older homes are commonly  
718 identified as most likely to have LSLs based on nationwide utility information [68]; and homes with low  
719 occupancy are hypothesized to have lower water use rates, more water stagnation, less buildup of  
720 corrosion control scale, less flushing out of particulates, and higher WLLs [55-56]. And until better site-  
721 specific evidence-based flush recommendations can be developed, public health officials, educators,  
722 water engineers and utility operators should work together to design communication strategies and  
723 consistent risk reduction messaging that promote evidence-based solutions; are transparent about  
724 uncertainties; and translate current science about low dose Pb impacts on child and reproductive health  
725 to motivate proactive health-protective behaviors. Homogenized remediation guidelines are always  
726 susceptible to error, given the wide variability that can exist between buildings, e.g., in pipe age, lengths,  
727 materials, and diameters; scale buildup; and home occupancy and water use. Promotion of these  
728 practices need to be reconsidered as other more effective, evidence-based, low-cost technologies, such as  
729 NSF-certified faucet mount filtration devices, are now widely [83]. In acknowledgement of this issue, the  
730 US EPA's LCR Working Group recommended to US EPA officials in 2015, that the CCR be revised to  
731 exclude the currently required messaging: "When your water has been sitting for several hours, you can  
732 minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using  
733 water for drinking or cooking" [84]. Rather than promoting one-size-fits-all flush guidelines, greater  
734 effort should be expended on motivating and enabling proactive evidence-based solutions. Officials  
735 should explain health risks related to low dose Pb exposures to child-bearing women and health care  
736 providers to motivate proactive behaviors; and instruct residents in the correct selection, implementation  
737 and maintenance of NSF-certified filters. More research is needed to field test cost-effective household  
738 water filtration systems; evaluate these interventions' likelihood for reducing chronic exposures to low  
739 dose waterborne Pb and associated BLLs; and measure the short- and long-term health impacts of chronic  
740 cumulative exposure to low dose waterborne Pb. If the intention is to prevent lead exposure, empowering  
741 individuals with the knowledge needed to motivate and support implementation of evidence-based  
742 household water treatment technologies should be paramount.

743

#### 744 *4.4 Study Limitations*

745

746 This study could not answer the questions of what factors are critical to the efficacy of flushing (i.e.,  
747 what impacts do water quality conditions or plumbing components have on flushing efficacy); and what  
748 are optimal flush conditions (flush time and frequency) under different water quality and plumbing  
749 scenarios. Specific conditions that could increase the risk of random Pb spikes, in particular, the presence  
750 of LSLs, could not be evaluated given the lack of resident knowledge and utility information on plumbing

751 materials. This information gap also prevented us from targeting the highest risk homes as required  
752 under the LCR (sites with LSLs, or copper with Pb solder); which in turn prevented us from evaluating  
753 LCR-compliance. However, this study does highlight the fact that flushing can be an inconsistently  
754 effective lead exposure prevention measure even in LCR-compliant cities, if the purpose of the flushing  
755 is not to remediate high WLLs, but rather to prevent chronic exposures to low level lead in vulnerable  
756 populations.

757 There were some weaknesses in the study design which could limit the generalizability of results.  
758 Sampling was conducted in only one city, yet each community water system has a unique set of water  
759 quality parameters which may have led to different conclusions. Sampling was also conducted on a small  
760 subset of NOLA homes, and as demonstrated here, there can be significant variability in WLLs between  
761 sites within the same city. However, this fact also supports the conclusion of this study, which is that, in  
762 the absence of site-specific information on factors that can influence WLLs, a one-size-fits-all optimal  
763 flush time for sites within a city may be an unreliable exposure prevention measure. Sampling was also  
764 conducted at only one point in time, limiting our ability to evaluate the efficacy of a one-time flush for  
765 maintaining low WLLs throughout the day,

766 Convenience sampling may have introduced bias into both the WLL and survey results. NOLA is  
767 comprised of a large proportion of minorities (59% African-Americans); and residents with low  
768 household incomes (38% make < \$25,000); and only 36% have a college education or higher [84].  
769 However, study participants were primarily Caucasian (75%), with incomes  $\geq$ \$75,000 (53%), and with  
770 college or graduate level educations (90%) (**Table S2, Supplementary Materials**). Samples were also  
771 collected by study participants, with no way to verify that samples were collected properly. Given the  
772 logistical difficulty in collecting post-stagnation water samples, utility compliance samples are also  
773 collected by residents. This may have resulted in some misclassification, but it also provided the  
774 advantage of generating samples from a large number of sites. Finally, as this study presents  
775 environmental monitoring data for waterborne lead levels that were collected from each site at only one  
776 point in time; it did not provide a complete characterization of personal exposures to lead in water for  
777 the study participants. A prospective study engaged in the ongoing collection of biological data, as well  
778 as collection of data on other environmental lead hazards (e.g., soil, dust, paint, food, etc.) is essential to  
779 characterize true exposures and associated adverse health outcomes.

780

781

## 782 5. Conclusions

783

- 784 • Overall NOLA WLLs were typically low ( $\leq$  5 ppb); however, low-dose detectable waterborne Pb is  
785 widespread across the city, and was observed to reach as high as 58 ppb.
- 786 • The sustained low WLLs throughout the NOLA water system, the lack of strong correlations between  
787 WLLs and other metals, and the occurrence of peak WLLs in flushed samples, may indicate that LSLs  
788 are a major contributor to NOLA WLLs.
- 789 • Older homes (pre-1950) and low occupancy homes had significantly higher WLLs; and should be  
790 prioritized for outreach, monitoring and intervention, when LSLs are present.



- 791 • While flushing according to prevailing guidelines that are promoted by water utilities and public  
792 health officials (flushing taps for 30 seconds to 2 minutes) may reduce WLLs for some homes,  
793 flushing did not consistently decrease Pb when used for the purpose of preventing exposure.  
794 • Significant declines in WLLs were only seen after extended flushing (6 minutes), but these changes  
795 were not substantial (< 1 ppb); and over half of these extended flush samples had detectable lead.  
796 • While flushing was not a widespread practice, the majority of those who do flush only flush for two  
797 minutes or less. Over half of these individuals had peak WLLs after flushing between 30 seconds and  
798 2 minutes; thus, these recommendations may inadvertently increase Pb exposure.  
799 • When flushing is used to remediate high WLLs after line replacements, extended and more rigorous  
800 flushing protocols may need to be repeated regularly for an indeterminate time period.  
801 • The majority of residential sites (>50%) exceeded health-based standards for children. Health  
802 standard exceedances are a concern as just over nine out of ten survey respondents reported either  
803 drinking or cooking with unfiltered tap water at some point in time. If the aim is to prevent childhood  
804 Pb exposure, NOLA may require more proactive interventions to meet this goal.  
805

806

807 **Supplementary Materials:** The following are available online at [www.mdpi.com/xxx/s1](http://www.mdpi.com/xxx/s1), Information on S&WB's  
808 water treatment system, Figure S1: "Tips for reducing lead exposure from drinking water" (Source: NOLA S&WB's  
809 2016 Consumer Confidence Report), Figure S2: Percent of survey respondents by reported length of premise  
810 plumbing + service line measurements (meters)(n=80), Table S1: New Orleans 2015 water quality data for finished  
811 water (after purification), Table S2: Participant and household characteristics of respondents, Survey for homes: Lead  
812 exposure assessment for drinking water study.  
813

814

815 **Author Contributions:** Conceptualization, Adrienne Katner and Marc Edwards; Methodology, Marc Edwards and  
816 Adrienne Katner; Software, Komal Brown, Kelsey Pieper, Hui-Yi Lin and Xinnan Wang; Validation, Jeffrey Parks,  
817 Kelsey Pieper, Komal Brown and Hui-Yi Lin.; Formal Analysis, Hui-Yi Lin, Komal Brown, Xinnan Wang, Kelsey  
818 Pieper; Investigation, Komal Brown, Jeffrey Parks, Adrienne Katner, Chih-yang Hu; Resources, Adrienne Katner,  
819 Marc Edwards, Jeffrey Parks, Hui-Yi Lin; Data Curation, Komal Brown, Xinnan Wang, Hui-Yi Lin, Komal Brown,  
820 Adrienne Katner; Writing-Original Draft Preparation, Adrienne Katner, Kelsey Pieper and Komal Brown; Writing-  
821 Review & Editing, Adrienne Katner, Kelsey Pieper, Komal Brown, Hui-Yi Lin, Marc Edwards, Sheldon Masters,  
822 Jeffrey Parks, Chih-yang Hu and Howard Mielke; Visualization, Adrienne Katner, Komal Brown, Kelsey Pieper,  
823 Hui-Yi Lin and Xinnan Wang; Supervision, Adrienne Katner; Project Administration, Adrienne Katner; Funding  
824 Acquisition, Adrienne Katner.

825

826 **Funding:** This research was supported in part through the Louisiana Board of Regents (LBOR) Pilot Funding for  
827 New Research Pilot Funding Program (PFund)(LEQSF-EPS(2015)-PFUND-406), and the Experimental Program to  
828 Stimulate Competitive Research (EPSCoR), which is funded by the National Science Foundation (NSF)(Contract #  
829 LEQSF(2015-18)-RD-A-13); the Louisiana State University Health Sciences Center (LSUHSC), School of Public Health  
830 Pilot Grant Award Program; and the National Institute of General Medical Sciences of the National Institutes of  
831 Health (NIH), which funds the Louisiana Clinical and Translational Science Center (LACATS)(1 U54 GM104940).  
832 The content is solely the responsibility of the authors and does not necessarily represent the official views of LBOR,  
833 NSF, LSUHSC, or NIH.

834

835 **Acknowledgements:** Marie Hurt of A Community Voice and Beth Butler of Southern United Neighborhoods  
836 provided substantial support in community outreach, study recruitment, water sample collection, study and  
837 outreach material design, and communication of study results. Marc Edwards of Virginia tech provided considerable  
838 technical support and reduced price services for laboratory analyses. Gail Fendley of Lead Safe Louisiana and Joseph  
839 Clavijo of Episcopal Diocese of Louisiana supported efforts to recruit study participants and communicate study  
839 results. John Ludlam, Pavolo Iosipiv, and Emilie Taylor in the Tulane School of Architecture's The Albert and Tina

840 Small Center for Collaborative Design provided support in the design of study and outreach materials, study  
841 recruitment and communication of study results. Anne Johnson Bludsaw of the Louisiana Department of Health  
842 Healthy Homes and Lead Poisoning Prevention Program provided support in study recruitment. Miguel del Toral  
843 of the US EPA provided advice on the LCR and waterborne lead on an as-needed basis. Joye Pate, Lizzie Huval,  
844 Joseph Quintana, Corey Cole, and Jack and Caroline Galliano in the Louisiana State University Health Science Center  
845 Summer Research Internship Program for support in biokinetic modeling, water quality data mining, historical  
846 document reviews and general study support.

847  
848 **Conflicts of Interest:** The authors declare they have no actual or potential competing financial interests. The  
849 founding sponsors had no role in the design of the study; in the collection, analyses, or interpretation of data; in the  
850 writing of the manuscript, and in the decision to publish the results.

851  
852

## 853 References

854

- 855 1. National Toxicology Program, (NTP). Health Effects of Low -Level Lead. NTP Monograph. NTP: Research  
856 Triangle Park, NC, USA, 2012.
- 857 2. Levin, R.; Brown, M.J.; Kashtock, M.E.; Jacobs, D. E.; Whelan, E.A.; Rodman, J; Schock, M.R.; Padilla, A.; Sinks,  
858 T. Lead Exposures in US Children, 2008: Implications for Prevention. *Environ. Health Perspect.* **2008**, *116*(10), 1285-  
859 1293, Doi: 10.1289/ehp.11241.
- 860 3. U.S. Environmental Protection Agency (US EPA). Safe Drinking Water Act Lead and Copper Rule (LCR). *Fed.*  
861 *Reg.* **1991**, *56*, 26460–26564.
- 862 4. U.S. Environmental Protection Agency (US EPA). Lead and Copper Rule: Monitoring and Reporting Guidance  
863 for Public Water Systems. US EPA: Washington D.C.: USA, 2010.
- 864 5. Deshommes, E.; Prévost, M.; Levallois, P.; Lemieux, F.; Nour, S. Application of lead monitoring results to predict  
865 0–7 year old children's exposure at the tap. *Water Res.* **2013**, *47*(7), 2409–2420, Doi: 10.1016/j.watres.2013.02.010
- 866 6. Triantafyllidou, S.; Gallagher, D.; Edwards, M. Assessing risk with increasingly stringent public health goals:  
867 the case of water lead and blood lead in children." *J Water and Health* **2014**, *12*(1), 57–68. Doi: 10.2166/wh.2013.067
- 868 7. Ngueta, G.; Abdous, B.; Tardif, R.; St-Laurent, J.; Levallois, P. Use of a cumulative exposure index to estimate  
869 the impact of tap water lead concentration on blood lead levels in 1-to 5-year-old children (Montreal, Canada).  
870 *Environ. Health Persp.* **2016**, *124*(3), 388–395. Doi: 10.1289/ehp.1409144.
- 871 8. National Drinking Water Advisory Council (NDWAC). LCR Long-Term Revisions White Paper. NDWAC:  
872 Washington D.C., USA, 2015.
- 873 9. Sandvig, A.; Kwan, P.; Kirmeyer, G.; Maynard, B.; Mast, R.; Rhodes, R.T. Contribution of Service Line and  
874 Plumbing Fixtures to Lead and Copper Rule Compliance Issues: AWAARF Report 91229. Int. Water Assn.:  
875 Denver, CO, USA, 2008.
- 876 10. Triantafyllidou, S.; Edwards, M. Lead (Pb) in Tap water and in blood: implications for lead exposure in the  
877 United States. *Crit. Rev. Environ. Sci. Technol.* **2012**, *42*, 13, 1297–1352. Doi: 10.1080/10643389.2011.55655
- 878 11. Clark, B.; Masters, S.; Edwards, M. Profile sampling to characterize particulate lead risks in potable  
879 water. *Environ. Sci. Technol.* **2014**, *48*, 6836–6843.
- 880 12. Brown, R. A.; Cornwell, D. A. High-velocity household and service line flushing following LSL replacement. *J*  
881 *AWWA* **2015**, *107*, E140–151. Doi: 10.5942/jawwa.2015.107.0012.
- 882 13. Commons, C. Effect of partial lead service line replacement on total lead at the tap in Cranston, Rhode Island. *J*  
883 *New Eng Water Works Assn.* **2012** *126*, 128.

- 884 14. Pieper, K. J.; Krometis, L.; Gallagher, D.; Benham, B.; Edwards, M. Profiling private water systems to identify  
885 patterns of waterborne lead exposure. *Environ. Sci. Technol.* **2015**, *49* (21): 12697-12704.
- 886 15. Triantafyllidou, S.; Parks, J.; Edwards, M. Lead particles in potable water. *J AWWA*. **2007**, *99*, 107-117.  
887 10.1002/j.1551-8833.2007.tb07959.x.
- 888 16. Vasile G.G.; Catrangiu .; Cruceru L.V. A field study on overnight stagnation of drinking water in domestic  
889 distribution system. In: 14th International Multidisciplinary Scientific Geoconference and EXPO, 17-26 June  
890 2014, Albena, Bulgaria. S.G.E.M. 2014, 1(3):11-18.
- 891 17. U.S. Environmental Protection Agency (US EPA). 40 CFR Parts 141 and 142 National Primary Drinking Water  
892 Regulations for Lead and Copper: Short-term regulatory revisions and clarifications; Final Rule. *Fed. Reg.*, **2007**,  
893 *62* (195). <https://www.gpo.gov/fdsys/pkg/FR-2007-10-10/pdf/E7-19432.pdf>. (accessed on 25 May 2018).
- 894 18. Edwards, M., Abhijeet, D. Role of chlorine and chloramine in corrosion of lead-bearing plumbing materials. *J*  
895 *AWWA* **2004**. 96[10]: 69-81. Doi: 10.1002/j.1551-8833.2004.tb10724.x.
- 896 19. Boyd, G. R.; Shetty, P.; Sandvig, A.M.; Pierson, G.L. Pb in tap water following simulated partial lead pipe  
897 replacements. *J. Environ. Engin.* **2004**, *130*, 1188-1197.
- 898 20. Schock, M. R. Causes of temporal variability of lead in domestic plumbing systems. *Environ. Monit. Assess.* **1990**,  
899 *15* (1): 59-82. Doi: 10.1007/BF00454749.
- 900 21. Imran S.; Dietz J.; Mutoti G.; Taylor J.; Randall A. Modified Larsons ratio incorporating temperature, water age,  
901 and electroneutrality effects on red water release. *J Environ Engin* **2005**, *131*(11):1514-1520.
- 902 22. Masters S.; Edwards M.A. Increased lead in water associated with iron corrosion. *Environ Engin Sci*, **2015**,  
903 *32*(5):361-369. Doi: 10.1089/ees.2014.0400.
- 904 23. Mutoti G.; Dietz J.D.; Arevalo J.; Taylor JS. Combined chlorine dissipation: pipe material, water quality, and  
905 hydraulic effects. *J AWWA* **2007**, *99*(10):96-106. Doi: 10.1002/j.1551-8833.2007.tb08060.x.
- 906 24. Masters S.; Parks J.; Atassi A.; Edwards M. Inherent variability in lead and copper collected during standardized  
907 sampling. *Environ. Monit. Assess.* **2016**, *188*(177): 1-15. doi: 10.1007/s10661-016-5182-x.
- 908 25. Edwards M.A.; Powers K.; Hidmi L.; Schock MR. The role of pipe aging in copper corrosion by-product release.  
909 *Water Sci and Technol: Water Supply* **2001** *1*(3):25-32.
- 910 26. Grace S.; Lytle D.A.; Goltz M.N. Control of new copper corrosion in high-alkalinity drinking water. *J AWWA*  
911 **2012**, *104*(1):39-40. Doi: 10.5942/jawwa.2012.104.0002.
- 912 27. Lagos G.E.; Cuadrado C.A.; Letelier M.V. Aging of copper pipes by drinking water. *J AWWA* **2001**, *93*(11):94-  
913 103.
- 914 28. Rajaratnam G.; Winder C.; An M. Metals in drinking water from new housing estates in the Sydney area. *Environ*  
915 *Res* **2001**, *89*(2):165-170. Doi: 10.1006/enrs.2002.4356.
- 916 29. Schock M.R.; Wagner I.; Oliphant R. Corrosion and solubility of lead in drinking water. Chapter 4 in *Internal*  
917 *Corrosion of Water Distribution Systems*. 2nd ed. AWWA Research Foundation, Denver, USA, 1996.
- 918 30. St. Clair, J.; Cartier, C.; Triantafyllidou, S.; Clark B.; Edwards, M. Long-term behavior of simulated partial lead  
919 service line replacements. *Environ. Engin. Sci* **2016**, *33*(1), 53-64.
- 920 31. Del Toral M.A.; Porter A.; Schock M.R. Detection and evaluation of elevated lead release from service lines: a  
921 field study. *Environ Sci Technol* **2013**, *47*(16):9300-9307.
- 922 32. Al-Jasser A.O. Chlorine decay in drinking-water transmission and distribution systems: pipe service age effect.  
923 *Water Res* **2007**, *4*(2): 2387-396.

- 924 33. Crozes G.F.; Cushing R.S. Evaluating biological regrowth in distribution systems. AWWA Research Foundation  
925 and American Water Works Association: Denver, CO, USA, 2000.
- 926 34. DiGiano F.A.; Zhang W.D.; Travaglia A. Calculation of the mean residence time in distribution systems from  
927 tracer studies and models. *J Water Supply: Research and Technology- Aqua* **2005**, *54*(1):1-14.
- 928 35. Kerneis A.; Nakoche F.; Deguin A.; Feinberg M. The effects of water resident time on biological quality in a  
929 distribution network. *Water Res* **1995**, *29*(7):1719-1727.
- 930 36. Lu C.; Biswas P.; Clark R. Simultaneous transport of substrates, disinfectants and microorganisms. *Water Res*  
931 **1995**, *29*(3):881-894. Doi: 10.1016/0043-1354(94)00202-I.
- 932 37. Masters S.; Parks J.; Atassi A.; Edwards M.A. Distribution system water age can create premise plumbing  
933 corrosion hotspots. *Environ Monit Assess* **2015**, *187*, 1-18. Doi:10.1007/s10661-015-4747-4.
- 934 38. U.S. Environmental Protection Agency Science Advisory Board (US EPA SAB). 2011. Evaluation of the  
935 effectiveness of partial service line replacements. EPA-SAB-11-015. Washington DC, USA.
- 936 39. U.S. Environmental Protection Agency (US EPA). 2008a. Implementing the lead public education provision of  
937 the Lead and Copper Rule: A Guide for Community Water Systems. EPA 816-R-08-007. Rev. June 2008. Office  
938 of Water, US EPA, Washington DC. Available:  
939 <https://nepis.epa.gov/Exe/ZyPDF.cgi/60001I4N.PDF?Dockey=60001I4N.PDF> [accessed 1 May 2008].
- 940 40. U.S. Environmental Protection Agency (US EPA). 2008b. Lead and Copper Rule: Public Education and Other  
941 Public Information Requirements for Community Water Systems. EPA 816-F-08-019. EPA Office of Water,  
942 Washington DC. USA.
- 943 41. Sewerage and Water Board of New Orleans (S&WB). 2015. Water Quality 2014 Report. Available:  
944 <https://www.swbno.org/docs.asp>. [accessed: 28 August 2017].
- 945 42. Agency for Toxic Substances and Disease Registry (ATSDR) ND. ATSDR Toxzone: Lead. Available:  
946 [https://www.atsdr.cdc.gov/sites/toxzine/docs/lead\\_toxzine.pdf](https://www.atsdr.cdc.gov/sites/toxzine/docs/lead_toxzine.pdf). [accessed: 23 May 2017].
- 947 43. U.S. Centers for Disease Control and Prevention (US CDC). 2015. Learn How to Prevent Children's  
948 Exposure to Lead. Available: <http://www.cdc.gov/features/leadpoisoning/> [accessed: 28 August 2017].
- 949 44. U.S. Environmental Protection Agency (US EPA). 1993. Lead in your drinking water- actions you can take to  
950 reduce lead in drinking water. EPA/810-F-93-001. 1993. EPA Office of Water, Washington DC, USA.
- 951 45. American Water Works Association (AWWA). 1996. Water://Stats 1996 Distribution Survey. Denver, CO:  
952 AWWA.
- 953 46. Sewerage and Water Board of New Orleans (S&WB). 2009. Water Quality 2008 Report. Available:  
954 <https://www.swbno.org/docs.asp>. [accessed: 28 August 2017].
- 955 47. Black and Veatch. 2006. Report on current and future needs: 2006. Prepared for the Sewerage and Water Board  
956 of New Orleans.
- 957 48. Black and Veatch. 2016. Report on operations for 2015: Black and Veatch Project No. 192043. Prepared for the  
958 Sewerage and Water Board of New Orleans. Available: <https://www.swbno.org/docs.asp> [accessed: 8 June 2017].
- 959 49. Deshommes E.; Bannier A.; Laroche L.; Nour S. Prevost M. Monitoring-based framework to detect and manage  
960 lead service lines. *J AWWA* **2016**, *108*(11):E555-E5570
- 961 50. Welter G. Typical Kitchen faucet-use flow rates: Implications for lead concentration sampling.  
962 *J AWWA* **2016**, *108*(7), E374-E380. doi:10.5942/jawwa.2016.108.0085.

- 963 51. American Public Health Association (APHA), American Water Works Association (AWWA), and Water  
964 Environment Federation (WEF). 1998. Standard Methods for Examination of Water and Wastewater, 20th ed.  
965 APHA: Washington, D.C. USA.
- 966 52. American Academy of Pediatrics (AAP) Council on Environmental Health. 2016. Prevention of childhood lead  
967 toxicity. *Pediatrics*. 138(1):e20161493. Available:  
968 <http://pediatrics.aappublications.org/content/pediatrics/138/1/e20161493.full.pdf>. [accessed: 28 May 2017].
- 969 53. Department of Health and Human Services (US)(DHHS), Food and Drug Administration(FDA). 1995. Bottled  
970 water. F21CFR165.110. Rev. 2017. Available:  
971 <https://www.accessdata.fda.gov/scripts/cdrh/cfdocs/cfcfr/CFRSearch.cfm?fr=165.110> [accessed: 25 August  
972 2017].
- 973 54. World Health Organization (WHO). 2011. Lead in drinking water: Background document for development of  
974 WHO Guidelines for Drinking-water Quality. WHO: Geneva, Switzerland. Available:  
975 [http://www.who.int/water\\_sanitation\\_health/dwq/chemicals/lead.pdf](http://www.who.int/water_sanitation_health/dwq/chemicals/lead.pdf) [accessed: 6 June 2017].
- 976 55. Arnold R.B.; Edwards M. Potential reversal and the effects of flow pattern on galvanic corrosion of lead. *Environ*  
977 *Sci and Technol* 2012. 46, 10941-10947.
- 978 56. Elfland C.; Scardina P.; Edwards M. Lead-contaminated water from brass plumbing devices in new buildings. *J*  
979 *AWWA* 2010, 102(11):2-18.
- 980 57. Cartier C., Bannier, A., Piroj, M.J., Nour, S., Prevost, M. A rapid method for lead service line detection. *J AWWA*  
981 2012, 104(11):E596=E607. doi: 10.5942/jawwa.2012.104.0143
- 982 58. Agency for Toxic Substances and Disease Registry (ATSDR) 1988. The nature and extent of lead poisoning in  
983 children in the United States: a report to Congress. Agency for Toxic Substances and Disease Registry:  
984 Washington, DC.
- 985 59. Mauss E.A.; Kass A.R.; Warren J.M. 1991. The Lead Contamination Control Act a study in non-compliance.  
986 Natural Resources Defense Council: Washington, DC, USA.
- 987 60. World Health Organization (WHO). 2017. Guidelines for drinking-water quality: 4th edition incorporating the  
988 first addendum. WHO: Geneva, Switzerland. License: CC BY-NC-SA 3.0 IGO. Available:  
989 [http://apps.who.int/iris/bitstream/handle/10665/254637/9789241549950-](http://apps.who.int/iris/bitstream/handle/10665/254637/9789241549950-eng.pdf;jsessionid=07E0E7A995A08EFAFC3CDAE257E1A6C3?sequence=1)  
990 [eng.pdf;jsessionid=07E0E7A995A08EFAFC3CDAE257E1A6C3?sequence=1](http://apps.who.int/iris/bitstream/handle/10665/254637/9789241549950-eng.pdf;jsessionid=07E0E7A995A08EFAFC3CDAE257E1A6C3?sequence=1) [accessed: 1 May 2019].
- 991 61. California Environmental Protection Agency (Cal-EPA) Office of Environmental Health Hazard Assessment  
992 (OEHHA). 2009. Public health goals for chemicals in drinking water: Lead. Available:  
993 [https://oehha.ca.gov/media/downloads/water/chemicals/phg/leadfinalphg042409\\_0.pdf](https://oehha.ca.gov/media/downloads/water/chemicals/phg/leadfinalphg042409_0.pdf) [accessed: 28 August  
994 2017].
- 995 62. Agency for Toxic Substances and Disease Registry (ATSDR) 2016. Meeting of the Lead Poisoning Prevention  
996 Subcommittee of the NCEH/ATSDR Board of Scientific Counselors. Atlanta GA: Agency for Toxic Substances  
997 and Disease Registry. Available:  
998 [https://www.atsdr.cdc.gov/science/lpp/docs/lead\\_subcommittee\\_minutes\\_9\\_19\\_2016\\_508.pdf](https://www.atsdr.cdc.gov/science/lpp/docs/lead_subcommittee_minutes_9_19_2016_508.pdf) [accessed: 21  
999 May 2018].
- 1000 63. U.S. Environmental Protection Agency (US EPA). 2017. Proposed modeling approaches for a health-based  
1001 benchmark for lead in drinking water. EPA-OGWDW. US EPA, Available:  
1002 <https://www.epa.gov/sites/production/files/2017->

- 1003 01/documents/report\_proposed\_modeling\_approaches\_for\_a\_health\_based\_benchmark\_for\_lead\_in\_drinking  
1004 \_water\_final\_0.pdf [accessed: 21 May 2018].
- 1005 64. Patch S.C.; Maas R.P.; Pope J.P. Lead leaching from faucet fixtures under residential conditions. *J*  
1006 *Environ Health* **1998**, *61*:18-21.
- 1007 65. Clark, B., Masters, S.V., Edwards, M. Lead released to drinking water from galvanized steel pipe coatings. *Env.*  
1008 *Engin. Sci.* **2015**, *32*(8):713-721. doi: 10.1089/ees.2015.0073.
- 1009 66. Dore E.; Deshommès E.; Andrews R.C.; Nour S. Sampling in schools and large institutional buildings:  
1010 Implications for regulations, exposure and management of lead and copper. *Water Res.* **2018**, *140*:110-122.
- 1011 67. Murphy E. Effectiveness of flushing on reducing lead and copper levels in school drinking water. *Environ. Health*  
1012 *Perspect.* **1993**, *101*(3): 240-241.
- 1013 68. U. S. Government Accountability Office (US GAO). 2016. Water infrastructure: Information on selected midsize  
1014 and large cities with declining populations. GAO-16-785. Available: <http://www.gao.gov/assets/680/679783.pdf>  
1015 [accessed 23 May 2017].
- 1016 69. State of Michigan, Department of Treasury. 2016. Flint Water Rate Analysis: Final Report. Available:  
1017 [http://www.michigan.gov/documents/snyder/Flint\\_Rate\\_Analysis\\_Final\\_Raftelis\\_Report\\_May\\_13\\_2016\\_52446](http://www.michigan.gov/documents/snyder/Flint_Rate_Analysis_Final_Raftelis_Report_May_13_2016_524463_7.pdf)  
1018 [3\\_7.pdf](http://www.michigan.gov/documents/snyder/Flint_Rate_Analysis_Final_Raftelis_Report_May_13_2016_524463_7.pdf) [accessed: 10 September 2017].
- 1019 70. Edwards M.; Lambrinidou Y.; Schott R.; Schwartz P. 2009b. Gaps in the EPA Lead and Copper Rule that can  
1020 allow for gaming of compliance: DC WASA 2003-2009. Available: [https://democrats-](https://democrats-oversight.house.gov/sites/democrats.oversight.house.gov/files/documents/Edwards-VA%20Tech%20Statement%203-15%20Flint%20Water%20II.pdf)  
1021 [oversight.house.gov/sites/democrats.oversight.house.gov/files/documents/Edwards-](https://democrats-oversight.house.gov/sites/democrats.oversight.house.gov/files/documents/Edwards-VA%20Tech%20Statement%203-15%20Flint%20Water%20II.pdf)  
1022 [VA%20Tech%20Statement%203-15%20Flint%20Water%20II.pdf](https://democrats-oversight.house.gov/sites/democrats.oversight.house.gov/files/documents/Edwards-VA%20Tech%20Statement%203-15%20Flint%20Water%20II.pdf). [accessed: 28 August 2017].
- 1023 71. City of New Orleans (n.d.) Roadwork: Frequently Asked Questions. Retrieved from Road Work website:  
1024 <https://roadwork.nola.gov/faq/>
- 1025 72. New Orleans Office of Inspector General (NO OIG). 2017. Lead Exposure and Infrastructure  
1026 Reconstruction. Available:  
1027 [http://www.nolaoig.gov/index.php?option=com\\_mtree&task=att\\_download&link\\_id=171&cf\\_id=37](http://www.nolaoig.gov/index.php?option=com_mtree&task=att_download&link_id=171&cf_id=37)  
1028 [accessed: 1 September 2017].
- 1029 73. Sewerage and Water Board of New Orleans (S&WB). 2017. Water Quality 2016 Report. Available:  
1030 <https://www.swbno.org/docs.asp>. [accessed: 28 August 2017].
- 1031 74. Desmarais, E., Laroche, L., Deveau, D., Nour, S., Prevost, M. Short- and long-term release after partial lead  
1032 service line replacements in a metropolitan water distribution system. *Environ. Sci. Technol.* **2015**, *51*(7): 9507-  
1033 9515.
- 1034 75. Pieper K.J.; Tang M.; Edwards M.A. Flint water crisis caused by interrupted corrosion control:  
1035 Investigating “Ground Zero” home. *Environ Sci Technol* **2017**. *51*(4):2007-2014
- 1036 76. Katner A.; Pieper K.; Lambrinidou Y.; Edwards M.; Brown K.; Hu C.; Mielke H. Weaknesses in  
1037 drinking water regulations and public health policies that may impede lead poisoning prevention and  
1038 environmental justice. *J Environ. Justice* **2016**, *9*(4):109-117.
- 1039 77. Russell, C.; Brandhuber, P.; Lytle, D. Lead in drinking water: Past, present, and future. *Opflow* **2017**, *43*(12), 10-  
1040 15.
- 1041 78. Taking Action on Flint. State of Michigan. 2018. Available: <https://www.michigan.gov/flintwater/> [accessed: 26  
1042 May 2019].

- 1043 79. U.S. Centers for Disease Control and Prevention (US CDC). 2002. Managing elevated blood lead levels among  
1044 young children: recommendations from the Advisory Committee on Childhood Lead Poisoning Prevention of  
1045 the US CDC. Available: [http://www.cdc.gov/nceh/lead/CaseManagement/caseManage\\_main.htm](http://www.cdc.gov/nceh/lead/CaseManagement/caseManage_main.htm) [accessed 4  
1046 June 2017].
- 1047 80. Edwards, M. Fetal death and reduced birth rates associated with exposure to lead-contaminated drinking water.  
1048 *Environ. Sci. and Technol.* **2014** *48*(1), 739-746. DOI: 10.1021/es4034952
- 1049 81. Hanna-Attisha, M.; LaChance, J.; Sadler, R.C.; Champney Schnepf, A. Elevated blood lead levels in children  
1050 associated with the Flint drinking water crisis: A spatial analysis of risk and public health response. *Am. J Public*  
1051 *Health* **2016**, *106*(2), 283-90. Doi: doi: 10.2105/AJPH.2015.303003.
- 1052 82. U.S. Centers for Disease Control and Prevention (US CDC). 2012. Low level lead exposure harms children: A  
1053 renewed call for primary prevention, from the Advisory Committee on Childhood Lead Poisoning Prevention  
1054 of the US CDC. Available: [https://www.cdc.gov/nceh/lead/acclpp/final\\_document\\_030712.pdf](https://www.cdc.gov/nceh/lead/acclpp/final_document_030712.pdf) [accessed 10  
1055 September 2017].
- 1056 83. Deshommes E.; Zhang Y.; Gendron K.; Sauve S.; Edwards M.; Nour S; Prevost M. Lead removal from tap water  
1057 using POU devices. *J AWWA* **2010**. *102*(10):91-105
- 1058 84. Lead and Copper Rule Working Group (LCRWG). 2015. Report of the Lead and Copper Rule Working  
1059 Group to the National Drinking Water Advisory Council: Final. Aug. 25, 2015. Available:  
1060 <https://www.epa.gov/sites/production/files/2016-01/documents/ndwacrlwgfinaug2015.pdf>  
1061 [accessed: 28 August 2017].
- 1062 85. United States Census Bureau (US Census). 2015. American Community Survey data (5-year estimates, 2010  
1063 through 2014) and decennial census data. Available: <https://www.census.gov/programs-surveys/acs/> [accessed:  
1064 28 August 2017].
- 1065 86. Sewerage and Water Board of New Orleans (S&WB). 2016. Water Quality 2015 Report. Available:  
1066 <https://www.swbno.org/docs.asp>. [accessed: 28 August 2017].  
1067  
1068