

**Removal Characteristics of *N*-Nitrosamines and Their Precursors  
by Pilot-Scale Integrated Membrane Systems for Water Reuse**

Haruka Takeuchi <sup>a,\*</sup>, Naoyuki Yamashita <sup>a</sup>, Norihide Nakada <sup>a</sup>, Hiroaki Tanaka <sup>a</sup>

<sup>a</sup>*Research Center for Environmental Quality Management,  
Kyoto University, Shiga 520-0811, Japan*

**SUPPLEMENTARY INFORMATION**

---

\* Corresponding author: Haruka Takeuchi, Email: [t\\_haruka76@yahoo.co.jp](mailto:t_haruka76@yahoo.co.jp), Ph +81 077 527 6220

**Table S1.** Limit of detection (LOD) and limit of quantification (LOQ) for eight *N*-nitrosamines.


	NDMA	NMEA	NPYR	NDEA	NPIP	NMOR	NDPA	NDBA
LOD (ng/L)	0.1	0.4	0.4	1.0	0.5	1.0	0.9	0.9
LOQ (ng/L)	0.4	1.3	1.3	3.2	1.5	3.3	2.9	2.9

**Table S2.** Concentration of disinfectant across the water reclamation trains of plant A and plant B.


Plant A					
Sampling campaign	Disinfectant	Concentration (mg/L)			
		NF perm.	NF conc.	RO perm.	RO conc.
1st	Chlorine	<0.02	0.07	0.13	0.03
	Chloramine	0.33	0.29	0.20	0.31
2nd	Chlorine	0.04	0.07	0.07	0.07
	Chloramine	1.18	1.15	1.18	1.20
3rd	Chlorine	<0.02	0.02	0.02	<0.02
	Chloramine	0.03	0.09	<0.02	0.02


Plant B								
Sampling campaign	Disinfectant	Concentration (mg/L)						
		Sand filter effluent	1st RO perm.	1st RO conc.	2nd RO perm.	2nd RO conc.	3rd RO perm.	3rd RO conc.
1st	Chlorine	1.17	<0.02	<0.02	0.12	<0.02	0.03	0.08
	Chloramine	1.03	0.41	0.65	0.30	0.81	0.38	0.81
2nd	Chlorine	0.04	0.01	0.03	0.03	0.03	<0.02	0.04
	Chloramine	0.98	0.19	0.35	<0.02	0.40	<0.02	0.46
3rd	Chlorine	0.16	0.25	0.05	<0.02	0.03	<0.02	0.03
	Chloramine	3.24	0.42	0.67	0.21	0.39	0.13	0.33



**Figure S1.** Formation rates of (a) NDMA and (b) NMOR across the membrane treatment at plant A.



**Figure S2.** Feed water characteristics of each RO process stage at plant B.



**Figure S3.** Operating conditions and feed water characteristics at each sampling campaign at plant C. N.A.: not available.