

Article

Ghost beam suppression in deep frequency modulation interferometry for compact on-axis optical heads

Oliver Gerberding^{1,*} and Katharina-Sophie Isleif^{2,*}

¹ Institute of Experimental Physics, University of Hamburg, Luruper Chaussee 149, D-22761 Hamburg, Germany

² Deutsches Elektronen-Synchrotron DESY, Notkestraße 85, D-22607 Hamburg, Germany

* Correspondence: oliver.gerberding@physik.uni-hamburg.de; katharina-sophie.isleif@desy.de

Abstract: We present a compact optical head design for wide-range and low noise displacement sensing using deep frequency modulation interferometry. The on-axis beam topology is realised in a quasi-monolithic component and relies on cube beamsplitters and beam transmission through perpendicular surfaces to keep angular alignment constant when operating in air or vacuum, which leads to the generation of ghost beams that can limit the phase readout linearity. We investigate the coupling of these beams into the non-linear phase readout scheme of DFMI and demonstrate adjustments of the phase estimation algorithm to reduce this effect. This is done through a combination of balanced detection and the inherent orthogonality of beat signals with different relative time-delays in deep frequency modulation interferometry that is a unique feature not available for heterodyne, quadrature or homodyne interferometry.

Keywords: laser interferometry; displacement sensing; ghost beams

1. Introduction

Laser interferometric displacement sensing is a central tool in precision metrology, inertial sensing, quantum technologies and, prominently, gravitational wave detection experiments [1]. Different flavours of such sensors are being studied, with dynamic range, sensitivity, bandwidth and linearity as major characteristics. Displacement sensors with multi-fringe dynamic and operational range and sensitivities below 10^{-12} m/ $\sqrt{\text{Hz}}$ at frequencies from 100 Hz down to < 1 mHz are studied for future space-based instruments, such as gradiometers [2] and gravitational wave detectors [3], and for the readout of low-frequency inertial sensors [4–7] and test masses in future ground-based gravitational wave detectors [8,9]. Deep-frequency modulation interferometry (DFMI) is one of the techniques that is being developed and studied for these applications [10–13].

DFMI can be used to implement multiple displacement (and tilt) sensors with minimal complexity of the ultra stable optics, the so called optical heads. Its major feature is the multi-fringe dynamic range phase readout with single-beam, unequal-arm-length interferometer topologies, which are enabled by creating a deep phase-modulation like interferogram from which the desired phase information can be extracted in real time [14]. An important second feature is the ability to reduce the effect of in-band laser frequency noise by using a fixed length, ultra-stable interferometer, or optical head, as frequency reference to implement either an active stabilisation or a noise-subtraction algorithm [10–12]. The latter approach is made possible by a third feature, an additional readout of the macroscopic arm-length difference, or, to be more precise, delay difference, from the interferogram that provides absolute ranging information.




Figure 1. Conceptual schematic of multiple displacement and tilt sensors implemented using deep-frequency modulation interferometry and the here discussed on-axis optical heads. The light from a laser, modulated sinusoidal in frequency, is split into fibers that provide light into several optical heads and a single, stable reference interferometer (here we depict an interferometer used in previous studies [12,15]). The currents from each photodiode, or photodiode segment (when using quadrant detectors to enable differential wavefront sensing [16]) are converted into voltages by trans-impedance amplifiers (TIAs), digitised and then fed into several demodulation pipelines that extract the complex amplitudes at N harmonics of the modulation frequency f_m [17]. Afterwards these complex amplitudes are fed into a fit algorithm to extract four parameters that should fully describe the interferogram.

A schematic of a DFMI multi-sensor displacement and tilt readout system is shown in Figure 1. Each optical head variant has an unequal arm length Mach-Zehnder or Michelson interferometer topology with one of the nominal beams E_S propagating through a stable, short arm and another beam E_L propagating towards the object of interest, or test mass, through a long arm. After beam recombination the optical power sensed on the two complementary photodetectors can be approximated to

$$P^{\pm} \propto (E_S + E_L)^2 = \frac{E_S^2}{2} + \frac{E_L^2}{2} \pm E_L E_S \cos(\phi + m \cos(\omega_m t + \psi)). \quad (1)$$

The modulation index $m = 2\pi\Delta f\tau$ depends on the differential delay between long and short arm τ and on the depth of the frequency modulation Δf . The interferometric phase encodes distance changes δL in the long arm $\phi = 2\delta L \cdot (2\pi/\lambda)$ via the laser wavelength λ . The underlying approximations are that the photodetector acts as a low-pass for the sum-frequencies and that the differential delay τ is much smaller than the period T_m of the modulation frequency. Typical values are a modulation frequency of $f_m = 1$ kHz, a frequency modulation depth of $\Delta f = 3.3$ GHz and an arm-length delay of $\tau = 0.1$ m/c = 0.3 ns, leading to an effective modulation depth of $m \approx 7$. To implement the phase extraction the nominal signal from Equation 1 is rewritten using the Bessel functions of the first kind:

$$P^{\pm} \propto \frac{E_S^2}{2} + \frac{E_L^2}{2} \pm E_L E_S \left[J_0(m) \cos(\phi) + 2 \sum_{n=1}^{\infty} J_n(m) \cos\left(\phi + n\frac{\pi}{2}\right) \cos(n(\omega_m t + \psi)) \right] \quad (2)$$

As first demonstrated by Heinzl et al. [14] one can now decompose the measured signal into a corresponding set of complex amplitudes using a discrete Fourier transform, or an IQ-demodulation, and then apply a Levenberg-Marquardt fit to extract the desired modulation parameters. The fit function is

$$P_{\text{fit}}(n) = P_f J_n(m_f) \cos\left[\phi_f + n\frac{\pi}{2}\right] (\cos(n\psi_f) - i \sin(n\psi_f)) \quad \text{for } n = N_l \dots N_h \quad (3)$$

with P_f , m_f , ϕ_f and ψ_f as estimated parameters and N_l as lowest and N_h as highest harmonic used for the analysis. Heinzel et al. found, that for $N_h = 10$ one can achieve reasonable small residuals when operating with modulation index values between $m = 6$ and 9 and this approach has been used in various experimental demonstrations since. Real-time implementations of both the IQ demodulation and the fit algorithm have so far been demonstrated with estimation rates of up to 100 Hz [12,17]. Non-linearities in the phase readout were found to be caused by: 1) amplitude noise, which can be partly suppressed using fast feedback stabilisation, 2) non-linear laser frequency modulation in the laser [11], 3) amplitude and frequency dependence of the photodiode current detection chain, which can be accounted for by compensating the corresponding transferfunction [14]. Active stabilisation of the modulation phase to $\psi \approx 0$ rad has also been implemented and can reduce fit complexity by excluding the complex share of the harmonic amplitudes.

Related techniques using a similar laser modulation scheme with different readout algorithms have also been developed, one prominently with additional, range-resolved multiplexing capability that is enabled by using stronger modulation indices and windowed signal extraction [18]. Multiplexing is realised with strong laser frequency modulations because the resulting beat signals become orthogonal for sufficiently large relative delay, a similar principle to the pseudo-random noise phase modulations that are used in digitally enhanced interferometer techniques to artificially reduce the coherence length [19].

DFMI is capable to perform displacement sensing with sub-picometer level displacement noise using small, single-component interferometers as optical heads [12] and configurations that incorporate the reference interferometer into the same optic are also being studied [13]. The use of single-component, off-axis optical heads in previous and ongoing studies is in general motivated by the following advantages:

- Avoidance of ghost beams generated at points of transmission between inner and outer medium
- Avoidance of back-reflections into the fiber and resulting parasitic beams
- Minimal assembly (bonding) efforts
- Avoidance of polarisation optics and/or major optical power losses

The presence of ghost beams is well known to cause non-linear, cyclic phase noise in heterodyne and homodyne interferometers and this especially includes parasitic reflections from fibers, which often have significantly higher phase dynamics than ghost beams generated within the often ultra-stable optical heads [20]. Reducing assembly efforts is also crucial when aiming for optimal performance at very low readout frequencies, which often implies the use of quasi-monolithic mounting structures. Off-axis designs can also be associated with the following disadvantages:

- Limited longitudinal operating range due to an inherent lateral beam-shift
- Angular alignment change between air and vacuum operation leading to increased alignment efforts with required pointing prediction
- Angular coupling of refractive index fluctuations when operated in air

The limited longitudinal range of operation is not a major factor for applications with a very limited macroscopic length change, such as test mass readout in satellite gradiometers [21], but it can be limiting in applications where objects move more than several millimeters and hence also the absolute ranging information is of higher interest. The change of beam angles, while deterministic, can greatly influence adjustment strategies if one aims to operate the interferometers at optimal working points. For the prism-based design the angular deviation between air and vacuum was on the order of 1 mrad [12]. We consider manufacturing tolerances to be neither an advantage or disadvantage for either off or on-axis designs and argue that the associated effort is greatly dependent on each individual design and the underlying requirements.

To avoid some of the off-axis design disadvantages we study here an on-axis design of a compact, quasi-monolithic, single-component optical head. In the following section we present the conceptual design of the optical head, discuss beam propagation, manufacturability, and thermal effects and we

show the simulated dependence of the interferometer signals on different test mass alignments. In the third section we then focus on the parasitic ghost beams that are unavoidable in our design and analyse how the DFMI readout algorithm can be adapted to reduce their influence on readout linearity by taking into account the orthogonality of beat signals with different effective modulation depth.

2. On-axis optical head design

A top view schematic of the on-axis optical head design is shown in Figure 2. The core is a quasi-monolithic component (QMC), in which two cube beamsplitters are joined via a quarter waveplate. The incoming beam from a fiber collimator enters the component from the left through surface 1 with p-polarisation and is transmitted through the polarisation selective coating at surface 5. From there the nominal beam propagates through the waveplate, which is aligned such that the beam entering the second cube has a circular polarisation. The next coating on surface 10 with a reflectance of 50% then creates an unequal arm-length Michelson interferometer with the short north arm, N, and the long east arm, E. Beam N is reflected at a highly reflective coating at surface 7 and beam E is reflected at the test mass, or object under test. Both beams recombine at surface 10 and the two resulting interfered beams leave either directly through surface 9 or via a second transmission through the waveplate and then at surface 4. The outer length of each cube is 5 mm and we assume a waveplate thickness of 1 mm (this might include an additional optical window for mechanical stability). All outer surfaces of the cubes are also coated with an anti-reflective coating to minimise the power of ghost beams.

The usage of polarisation elements has been studied for the LISA optical bench and test mass readout [22] and compact quadrature interferometers also rely on using different polarisation states and cube beamsplitters to decode the interferometric phase [5]. Other interferometer studies for LISA have also shown that it is beneficial to clean the polarisation delivered into displacement interferometers [23]. In the here presented topology the polarising surface and the waveplate have three nominal functions. 1) Any residual s-polarisation from the input beam is filtered out. 2) The indirect interference beam is not reflected back into the fiber and can be probed. 3) Reflections of the indirect interference beam at surfaces 3 and 4 can not interfere at surface 10, because they have an orthogonal circular polarisation. Leakage of polarisation will be caused by either the waveplate, due to imperfect rotational alignment and deviations from its nominal thickness, or mismatches in reflectivity at surface 10 between s and p polarisation components.

We assume that the minimal distance L to the test mass is 5 cm. The path of the two nominal beams is largely common mode within the cube, with the propagation of the long arm towards the test mass being the major difference between them. Temperature induced thermal expansion and changes of refractive index will cancel to a large degree for the component internal beam path, leaving only the long-arm length change due to thermal expansion of the component as first order coupling. This effect is of course dependent on the mounting strategy of the interferometer and on the expansion of the spacer that defines the distance to the test mass, two effects which can partly cancel each other if materials with suitable coefficients of thermal expansion are used. For a characteristic length of 5 mm and a CTE of $\alpha = 5 \cdot 10^{-6}$ the uncompensated temperature coupling is on the order of $2.5 \cdot 10^{-8}$ m/K.

The dimensions of the optical head are compatible with a beam-diameter of about 1 mm, taking into account chamfers and that coatings typically do not extend into the corners on each surface. Compared to previous off-axis designs this leads to a further reduction of component volume and size, giving even more prominence to the fiber collimator dimensions in the design of the optical head.

All parts that are used for constructing the component are standard items and available with low tolerances. The dimensional tolerance is uncritical for our design. Angular tolerances as well as matching the pathlength between surface 10 and surface 7 and 8 are the most critical to achieve minimal coupling of thermal and refractive index effects. The macroscopic alignment of the input beam and the resulting output beams is mainly driven by the need to avoid beam clipping and with typical tolerances of the used components and an absolute beam positioning of about 100 μm this




Figure 2. Sketch of the here proposed on-axis optical head design. The core of the design is a quasi-monolithic component (QMC), which consists of a polarisation beam splitter (PBS) cube, a quarter waveplate (QWP) and a beam splitting cube (BSC) with 50% reflectivity at the diagonal surface. Nominal dimensions are given in units of 1 mm. The two setups A and B on the lower left indicate two variants for light detection on photodiodes that are simulated below, one (A) with diodes mounted directly onto the component and the other one (B) with distant photodiodes and focusing lenses in between. The upper sketch shows the overall dimensions of the optical head when a fiber collimator is included. The QWP glass parts can be assembled using silicate bonding or optical adhesives after applying the specified coatings.

requirement should be fulfilled. The major fine adjustment needed is to ensure matching points of beam splitting and beam interference at the critical diagonal surface 5, which is the condition for maximum longitudinal range with a zero-angle of incidence on the test mass. This can be achieved by tuning the tip and tilt angles of the input beam and test mass, or of the optical head relative to the test mass as alternative to the latter. In case of angular misalignment between the critical surfaces the splitting and recombination point can still be matched, if input beam and test mass alignment (or again optical head orientation) are adjusted accordingly. Angular misalignment of surfaces transmitted by the input beam can be compensated in this process.




Figure 3. Simulated signals at the direct output port for setups A and B (see Figure 2) under in-plane test mass rotation. The input beam parameters for both setups are 0.5 mm waist size radius and 15 mm waist position. The beam origin is 5 mm away from the PBS. The wavelength is 1550 nm. The distance between BSC and photodiode is 0.1 mm in Setup A. The distance to the lens is 0.1 mm in Setup B, with a distance between lens and photodiode of 9.0 mm.

We studied the influence of test mass tilts on the interferometer signals using the IfoCAD software library [24]. We assumed a Gaussian input beam with a waist diameter of 1.0 mm and a waist position at surface 5. We calculate signals for large (3 mm diameter) photodiodes that are mounted directly on the outer surfaces of the interferometer (setup A) and for smaller (1 mm diameter) photodiodes that are placed further away with some focusing lenses in between (setup B). Neglecting ghost beams we derive interferometer contrast, tilt-to-length coupling and its slope. For a tilt-sensitive readout with quadrant photodiodes we also compute the expected differential wavefront sensing, its derivative,

and differential power sensing signals. We limit the analysis to a maximum tilt of about ± 0.4 mrad to ensure beam clipping effects are negligible. The results of our simulation are shown in Figure 3.

Interferometric contrast within the analysed range of tilt stays above 60% and we find a slightly angle dependent differential wavefront sensing coupling factor of about 3750 rad/rad, comparable to the prism interferometer design. The position of the focusing lens in setup B was fixed and not optimised further and we find that the tilt-to-length coupling in this case is less linear. For both setups we also calculate the coupling after a linearization with post-processing corrections that use the DWS readout for correcting the tilt-to-length coupling. Interestingly this simple linearization is more effective for setup A. These results show that the on-axis optical head has a comparable angle-dependency to similar compact interferometers and that one can at least consider to mount the photodiodes directly next to, or onto, the component to further reduce the footprint of the overall assembly.

3. Ghost beam analysis for deep frequency modulation interferometry

In an idealised set-up, with perfect alignment and anti-reflective coatings, all light sent into the optical head is used for the readout, no light is reflected back into the fiber, only the nominal polarisation is present, and no parasitic ghost beams are generated. Since anti-reflective coatings and bonding interfaces have some residual reflection in any real device and polarisation leakage also occurs we have to assume that non-negligible ghost beams are generated at various surfaces in our design. These parasitic beams will lead to additional interference signals that can limit the phase readout noise and linearity. Estimating the coupling of these parasitic beams into the phase readout is non-trivial for DFMI, because the effective modulation depth of each interference beat signal depends on the relative propagation delays between any two beams. This effect not only complicates the analysis, it also provides opportunities to adapt the phase estimation algorithm to reduce the influence of parasitic beams. For large differences in effective modulation depth the resulting signals become orthogonal, a fact that is used in other interferometer techniques to implement multiplexing capabilities. In the following analysis we use this fact to reduce the influence of parasitic ghost beams that are caused by parasitic surface reflections.

Another technique we apply is prominently used in heterodyne interferometers to reduce the influence of ghost beams, the so-called balanced detection. It uses the two complementary output port signals of the interferometer from which amplitude and phase are extracted and then combined in the complex plane to null the additional optical interference terms [20]. Application of this technique requires the phase readout to be sufficiently linear for the coupling of the respective ghost beam beat signals, which we analyse in the following.

Before we begin the analysis we introduce some simplifications to make the equations more readable. In the following we will write interference signals without considering the constant DC terms ($P_x \propto E_x^2$), we set the units of the electric fields and of the resulting interference signals to 1 ($[P] = [E_x^2] = 1$), we set the values of the two nominal beams in the north and east arms to unity ($E_N = E_E = 1$), and we assume that all parasitic reflections are smaller than 0.25% ($r_p \leq 0.05$) leading to negligible degradation of the nominal beam amplitude ($t_p \approx 1$). We also include the assumption that the reflectivity of surface 10 is $r_{10} = 1/\sqrt{2}$, which corresponds to an input power of $P_{in} = 2$. For ghost beam analysis only the relative beam amplitudes are important and we neglect here other noise sources such as shot noise, readout noise and digitisation noise.

To deduce the DFMI signals we assume the typical approximations when calculating the beat signals. We set the propagation delay of the short north arm at the point of interference and its phase to zero ($\tau_N = 0$ s, $\phi_N = 0$ rad) and also set the modulation phase to zero ($\psi = 0$ rad). Finally, we use $c(t) = \cos(\omega_m t)$. In this notation the nominal beat signal for the two complementary output ports become

$$P_{N,E}^{\pm} = \pm E_N E_E \cos[\phi_E + m_E \cos(\omega_m t)] = \pm 1 \cos[\phi_E + m_E c(t)], \quad (4)$$




Figure 4. Propagation of individual, parasitic ghost beams generated by zero-angle transmission at internal and external surfaces of the QMC. Beams 1 to 4 lead to parasitic beat signals with the highest amplitudes, while beams 5 and 6 are somewhat suppressed by the polarisation optics.

with a modulation depth $m_E = 2\pi\Delta f\tau_E = 2\pi\Delta f(\tau_L + \tau_1) \approx 2\pi\Delta f(2L)/c$ and the desired interferometric phase $\phi_E = \phi_L + \phi_1 = 2\delta L/\lambda \cdot 2\pi + \phi_1$. Here c is the speed of light, λ is the laser wavelength and ϕ_1 is an additional, almost constant phase that accounts for slight differences τ_1 between both arms within the cube. Since both beams are interfered at surface 10 the associated phase shifts leads to the opposite sign for each output port, which is the basis for the above mentioned balanced detection scheme. We assume a minimal distance to the test mass of $L \geq 5$ cm.

Now we include the first parasitic reflection into our analysis, the internal reflection at surface 8, as shown in inset (a) of Figure 4. It generates an additional beam E_1 with an amplitude $|E_1| = 0.05$, a delay that is very similar to the one in the north arm, $\tau_1 \approx 0$, and a random phase ϕ_1 that varies only very slowly and with negligible dynamics (due to the low CTE and assumed temperature stability). The resulting output power now contains three effective beat signals¹:

$$P_{N,E,1}^{\pm} = \pm E_N E_E \cos[\phi_L + \phi_1 + m_E c(t)] \quad (5)$$

$$\pm E_N E_1 \cos[\phi_1 + m_1 c(t)] \quad (6)$$

$$+ E_E E_1 \cos[\phi_L + (m_E - m_1)c(t)] \quad (7)$$

$$= \pm 1 \cos[\phi_E + m_E c(t)] \quad (8)$$

$$\pm 0.05 \cos[\phi_1 + m_1 c(t)] \quad (9)$$

$$+ 0.05 \cos[\phi_E - \phi_1 + (m_E - m_1)c(t)] \quad (10)$$

Please note that this results is not physical, it defies energy conservation because of the unitary transmission for the nominal beams. However, this description is sufficient to demonstrate our ability to effectively cancel all of the here listed parasitic contributions.

To probe the effect of this signal onto the phase estimation we expand the three beat notes using the Bessel-functions of the first kind and then we add their contributions to the injected harmonic amplitudes of the modulation frequency for each output port in a numerical simulation. Then we use a non-linear Levenberg-Marquardt fit operating on the harmonics N_l to N_h to estimate two sets of the three desired signal parameters, the amplitude P_f , the modulation depth m_f and the interferometric phase ϕ_f . The fit function we use is

$$P_{\text{fit}}(n) = P_f J_n(m_f) \cos\left[\phi_f + n \frac{\pi}{2}\right] \quad \text{for } n = N_l \dots N_h \quad (11)$$

¹ $m_E = m_L + m_1$ and $\phi_E = \phi_L + \phi_1$




Figure 5. Simulated, worst-case deviations from nominal and estimated phase and modulation index for signals according to $P_{N,E,1}^{\pm}$ and fit P_{fit} for $m_L = 7.0$, $\phi = \pi/4$. The error reduction due to balanced detection and exclusion of the first harmonic are clearly visible.

We also make the following assumptions: The pathlength difference corresponding to τ_1 is smaller than $100 \mu\text{m}$, from which we estimate that $m_1 = \tau_1/\tau_L \cdot m_L \leq 0.001 \cdot m_L$ and with $m_L \approx 7$ this leads to $m_1 \leq 0.007$.

Using $N_l = 1$ and $N_h = 10$ we find an expected non-linear behavior of the difference between the two estimated and injected phases that depends on the phase difference $\phi_\delta = \phi_1 - \phi_L$ and the absolute value of ϕ_1 . The strongest phase estimation error $\Delta\phi = \phi_E - \phi_f$ is shown as red line in Figure 5. We derive the maximum strength of the unit-less non-linear coupling as

$$\delta = \left| \frac{\Delta\phi}{\phi_\delta} \right|. \quad (12)$$

Since we assume that ϕ_1 is a slowly changing quantity, largely driven by temperature effects, its phase dynamics will be below our desired phase noise levels in the order of $1 \mu\text{rad}/\sqrt{\text{Hz}}$ and this means that we can evaluate the effect of the ghost beams on our readout purely with regards to the phase dynamics of the actual phase ϕ_L , which is the test mass motion in combination with the average laser frequency variation, though the latter can be stabilised also to negligible values. This is true for the analysis of all other ghost beams discussed below as well and we argue that ghost beams occurring in our optical head are fully negligible for the readout of phase variations in applications with very low signal dynamics. To improve on the non-linearity of $\delta < 0.05$ we then apply a balanced detection correction by computing the vector difference between the two output signals, effectively negating the influence of the $E_E E_1$ beat. Results of this approach are shown as solid blue line in Figure 5, reducing the non-linear coupling to $\delta < 5 \cdot 10^{-6}$. Errors in modulation depth estimation are plotted as well with $\Delta m = m_f - m_E$. The additional correction only suppresses the $E_N E_1$ beat, because it has the same sign in both output ports. Finally, we recognise that the modulation depth of m_1 is very small and that the $E_E E_1$ contributions are largely contained in the first harmonic $N = 1$. Since this one is often contaminated by amplitude noise due to the laser modulation we adapted the fit algorithm to operate only on the amplitudes of $N_l = 2$ to $N_h = 10$ and achieve the dashed, blue line results in Figure 5. This principle also works for other values of m_L , but at a value of $m_L = 7$ we expect a minimal reduction in signal-to-noise ratio, because $J_0(m = 7) \approx 0$, meaning the fit will ideally not evaluate this harmonic amplitude anyhow. As one can see from the right side of Figure 5 the estimation of the modulation index also significantly improves when excluding the first harmonic. So far we have used balanced detection as a dedicated post-processing step, but we recognise that the separate fitting of two complementary output ports could be integrated into a single fit routine that also takes the presence of

a parasitic ghost beam beat-note at the same modulation depth into account. Since the fit is inherently non-linear we also hope to increase robustness when making the fit function more physical for later experiments. We adapted our fit to operate on two sets of harmonics, with the indirect output port harmonics having a negative sign in their index, n , and we extend the fit function with two parameters, a ghost beam phase $\phi_{f,g}$ and amplitude $P_{f,g}$,

$$P_{\text{fit,BD}}(n) = J_{|n|}(m_f) \left[\text{sgn}(n)P_f \cos\left(\phi_f + |n|\frac{\pi}{2}\right) + P_{f,g} \cos\left(\phi_{f,g} + |n|\frac{\pi}{2}\right) \right] \quad (13)$$

$$\text{for } n = -N_h, \dots, -N_1, N_1, \dots, N_h \quad (14)$$

The fit with included balanced detection achieves the same linearity results in our simulation, it increases computation times by up to a factor of two and reduces the parameter error standard deviations by a factor of $\sqrt{2}$, which indicated a higher robustness.

In the next step of our analysis we include the second parasitic reflection from surface 8, as shown in inset (b) of Figure 4. This reflection occurs when the long arm beam is transmitted back into the component, creating a second round-trip beam E_2 with an amplitude $|E_2| = 0.05$, a delay that is twice the one of the long arm, $\tau_2 \approx 2 \cdot \tau_L + \tau_1$, and a phase $\phi_2 = 2 \cdot \phi_L + \phi_1$. When we now calculate the resulting output powers we have a total of six beat signals²:

$$P_{N,E,1,2}^{\pm} = \pm E_N E_E \cos[\phi_E + m_E c(t)] \quad (15)$$

$$\pm E_N E_1 \cos[\phi_1 + m_1 c(t)] \quad (16)$$

$$\pm E_N E_2 \cos[2\phi_L + \phi_1 + (2m_L + m_1)c(t)] \quad (17)$$

$$+ E_E E_1 \cos[\phi_L + m_L c(t)] \quad (18)$$

$$+ E_E E_2 \cos[\phi_L + m_L c(t)] \quad (19)$$

$$+ E_1 E_2 \cos[2\phi_L + 2m_L c(t)] \quad (20)$$

$$= \pm 1 \cos[\phi_E + m_E c(t)] \quad (21)$$

$$\pm 0.05 \cos[\phi_1 + m_1 c(t)] \quad (22)$$

$$\pm 0.05 \cos[2\phi_E - \phi_1 + (2m_L + m_1)c(t)] \quad (23)$$

$$+ 0.05 \cos[\phi_E - \phi_1 + m_L c(t)] \quad (24)$$

$$+ 0.05 \cos[\phi_E - \phi_1 + m_L c(t)] \quad (25)$$

$$+ 0.0025 \cos[2\phi_E - 2\phi_1 + 2m_L c(t)] \quad (26)$$

The second beat has already successfully been suppressed by excluding the first, $N_1 = 1$, harmonic from the fit. Beat signals four and five can again be suppressed using balanced detection. The third and sixth beat signal however can not be canceled with the previous fit but the sixth beat is already significantly smaller in amplitude. We analysed the phase and modulation index error when probing $P_{N,E,1,2}^{\pm}$ with the fit function $P_{\text{fit,BD}}$ and the results are shown in the upper plots in Figure 6 for different values of m and for the worst-case value of ϕ_1 . The non-linearity is below $\delta < 1.6 \cdot 10^{-2}$, already an improvement against the nominal beat amplitude of 0.05 due to the higher modulation index of this disturbance.

Since the third beat signal has twice the effective modulation depth we can use the orthogonality to expand our fit algorithm such, that it searches for two additional parameters, the power of the

² $\phi_L = \phi_E - \phi_1$




Figure 6. Simulated, worst-case deviations from nominal and estimated phase and modulation index for signals according to $P_{N,E,1,2}^{\pm}$ and fit $P_{fit,BD}$ for different value of modulation index m_L . The maximal non-linearity was found for $m_L = 7.5$ with $\delta < 1.6 \cdot 10^{-2}$.




Figure 7. Simulated, worst-case deviations from nominal and estimated phase and modulation index for signals according to $P_{N,E,1,2}^{\pm}$ and fit $P_{fit,BD,2m}$ for different value of modulation index m_L . The maximal non-linearity was found for $m_L = 6.5$ with $\delta < 1.3 \cdot 10^{-4}$. Error and non-linearity for phase and modulation index improved by more than two orders of magnitude in comparison to results shown in Figure 6.

second tone $P_{f,2m}$ and its phase $\phi_{f,2m}$. Now we are estimating a total of seven parameters and the fit function is

$$P_{fit,BD,2m}(n) = J_{|n|}(m_f) \left[\text{sgn}(n) P_f \cos\left(\phi_f + |n| \frac{\pi}{2}\right) + P_{f,g} \cos\left(\phi_{f,g} + |n| \frac{\pi}{2}\right) \right] \quad (27)$$

$$+ \text{sgn}(n) P_{f,2m} J_{|n|}(2m_f) \cos\left[\phi_{f,2m} + |n| \frac{\pi}{2}\right] \quad (28)$$

$$\text{for } n = -N_h, \dots, -N_l, N_l, \dots, N_h. \quad (29)$$

The results using this fit are shown in the lower plots of Figure 6 for different values of m and for the worst-case value of ϕ_1 . With the inclusion of the second harmonic fit we reduce the phase readout linearity to $\delta < 1.3 \cdot 10^{-4}$ and the error in modulation depth estimation to $|\Delta m| < 3 \cdot 10^{-4}$. The remaining non-linearities are understood to be dominated by the sixth beat signal. But its effect is not only suppressed by its smaller amplitude, but also by its inherent orthogonality. A further extension of the fit to also account for the last beat is of course possible, but we don't explore this here.

So far we have shown that we can adapt the DFMI readout algorithm to account for parasitic reflections occurring at surface 8 of our design in such a way, that non-linearity can be reduced




Figure 8. Shown are sketches of an alternative QMC design that employs intentional wedge angles to reduce the influence of ghost beams 3, 4, 5 and 6, as depicted in Figure 4. The wedges can either be realised by machining more complex shapes than right angle prisms or by including additional wedged windows with matching refractive index that are bonded at the marked surfaces with very low transmissivity contacts. a) shows the propagation of the nominal beams. b) shows the deflection achieved for ghost beams 3 and 4. c) Shows the deviation achieved for ghost beams 5 and 6. An optimised design would need to take the optimal birefringence of the waveplate and the changing refractive indices into account.

to levels below 0.1%. We have not studied the influence of a possible third round-trip signal, but expect it to be even less relevant, due to its even smaller amplitude and higher delay. Handling ghost beams generated at surface 8 under zero degree transmission is the most crucial aspect to achieve our goals of an on-axis design with no alignment change between air and vacuum and further experimental exploration of linearity will first have to deal with other non-linearities from, for example, the laser frequency modulation. A maximum error $\Delta m = 5 \cdot 10^{-4}$ for the extracted modulation depth corresponds to an error in absolute ranging of less than $4 \mu\text{m}$ for $m_L = 7$ and $L = 5 \text{ cm}$, excluding additional errors due to calibration and noise.

As shown in the two lower sketches of Figure 4 the design is, however, sensitive to additional ghost beams generated at other surfaces. Especially the reflections 3 and 4 can lead to relevant non-linearities as discussed below. Reflections 5 and 6 are to some degree suppressed, because they would enter the right cube with an orthogonal circular polarisation. All of these zero degree reflections not happening at surface 8 are not required to enable an on-axis design and could be suppressed with additional modifications and more complex topologies of the quasi-monolithic component. A variant that retains the on-axis design but is specifically adjusted to reduce the influence of reflections 3,4,5 and 6 is sketched in Figure 8. The parasitic beams have an intentional angle deviation and a significantly reduced interferometric beat signal amplitude should they end up on the photodetector.

To complete the analysis for the design based on perpendicular external surfaces we analyse the effect of ghost beam 3 (beam 4 would behave very similar, but its power depends on the refractive index mismatch and the bonding technique). To simplify the description we assume from here on that the differential delay is negligible $\tau_1 = 0$, we define a characteristic optical path length $d = 2 \cdot 5 \text{ mm} \cdot n_{\text{glass}} \approx 15 \text{ mm}$ for beams that bounce through the cube once and we discard any secondary ghost beams. If the already interfered signal is reflected back into the interferometer we have to add a total of four additional beams to our analysis. We name these beams according to their travel path, for example the beam E_{NN}^3 is the original beam E_N , reflected at surface 9, then split at surface 10 and reflected back at surface 7 to the interference point. The effective delay for this beam in our notation is $\tau_{\text{NN}} = \tau_N + \tau_d = 0 + d/c$, with c as the speed of light, and the amplitude is $|E_{\text{NN}}^3| = |E_N| \cdot r/2 = 0.025$. The interference between all 8 relevant beams will consist of 28 beat signals. The matrix in Table 1 lists the effective modulation depth for each beat signal and the values below the diagonal include a negative sign if the beat has a phaseshift of π at the indirect output.

With the previous analysis we covered all signals of the upper left quadrant of this matrix. The lower right quadrant produces beat signals at the same modulation depth as covered by our fit algorithm, their phases should be largely coherent and the corresponding beat amplitudes are on the order of 0.1%. Critical additions are the in cyan highlighted beat signals that contain a delay

m_x	E_N	E_E	E_1	E_2	E_{NN}^3	E_{NE}^3	E_{EN}^3	E_{EE}^3
E_N		L	0	2L	d	$d+L$	$d+L$	$d+2L$
E_E	-L		L	L	$(L-d)$	d	d	$d+L$
E_1	0	L		2L	d	$d+L$	$d+L$	$d+2L$
E_2	-2L	L	2L		$2L-d$	$L-d$	$L-d$	d
E_{NN}^3	d	$-(L-d)$	$-d$	$-(2L-d)$		L	L	2L
E_{NE}^3	$-(d+L)$	d	$d+L$	$L-d$	-L		0	L
E_{EN}^3	$(d+L)$	$-d$	$-(d+L)$	$-(L-d)$	L	0		L
E_{EE}^3	$-(d+2L)$	$d+L$	$d+2L$	d	-2L	L	-L	

Table 1. Summary of all relevant beat signals when considering reflections 1, 2 and 3. Parasitic signals with an amplitude of r are highlighted in green, signals with an amplitude of $r/2$ are highlighted in cyan and all signals with an amplitude $\leq r^2$ are highlighted in gray. Signals with red font are not suppressed using balanced detection, because they have a different sign in the direct and indirect output port, just as the nominal signal.

x	E_{NN}^3	E_{NE}^3	E_{EN}^3	E_{EE}^3
E_N	d	$d+L$	$d+L$	$d+2L$
E_E	$(L-d)$	d	d	$d+L$
$m_L = 7$	E_{NN}	E_{NE}	E_{EN}	E_{EE}
E_N	1.05	8.05	8.05	15.05
E_E	5.95	1.05	1.05	8.05
$\delta_{m_L=7}$	E_{NN}	E_{NE}	E_{EN}	E_{EE}
E_N	$3.6 \cdot 10^{-5}$	$5.2 \cdot 10^{-4}$	$3.4 \cdot 10^{-4}$	$3.8 \cdot 10^{-4}$
E_E	$5.0 \cdot 10^{-4}$	$3.6 \cdot 10^{-5}$	$5.6 \cdot 10^{-5}$	$3.4 \cdot 10^{-4}$

Table 2. Parasitic beat signals from reflection 3 with an amplitude of $r/2$, those with red font are not suppressed using balanced detection. The modulation depth of each beat is shown together with the maximum non-linearity factor extracted applying the fit function $P_{\text{fit,BD},2m}$.

corresponding to the characteristic length d , which computes to $m_d = m_L \cdot d / (2L) \approx 0.15m_L$ for a long arm length of $L = 5$ cm. For $m_L = 7$ this gives $m_d = 1.05$. Since the phase of each of these eight critical beat signals might have some additional, relatively constant phase contribution we evaluate their impact individually, adding only one of them add a time to $P_{S,L,1,2}^{\pm}$ and measuring the non-linearity for different additional phase values and values of $m_L = 6$ to 8. The maximal δ determined for each beat signal is shown in Table 2, together with the effective modulation depth values for $m_L = 7$.

As expected from our previous analysis the beat signals further away in modulation depth contribute less and the tones that are suppressible via balanced detection also have a slightly weaker influence when compared to other signals at the same modulation depth. Figure 9 shows the $N_1 = 1$ to $N_h = 10$ Bessel functions of the first kind together with vertical lines indicating the modulation depth of the relevant beat signals. Luckily, even beat signals close to the nominal modulation depth ($\pm m_d$) are already to some degree orthogonal. By adding the effect from each of these eight parasitic beat signals we arrive at a conservative, total non-linearity of $\delta < 0.0027$ (for $m_L = 6.5$, the worst case), which is roughly an order of magnitude below the amplitude of each of these beats of $r/2 = 0.025$.

Since the ratio of d and L can be adjusted one could study other combinations that might be less or more susceptible to these couplings. Applying even more complex fit algorithms is of course




Figure 9. Shown are the Bessel functions of the first kind for the first 10 harmonics. The vertical lines indicate the modulation depth values that correspond to the major parasitic beat signals present when considering ghost beams 1, 2 and 3 for $m_L = 7$.

also possible, but the number of extracted parameters (7 for $P_{\text{fit,BD},2m}$) should generally not exceed the number of analysed harmonics (18 for $P_{\text{fit,BD},2m}$), so an overall increase of modulation depth and analysed harmonics might be required. Future iterations and extension of the fit could also make use of more correlations within the signal, for example fixed amplitude and phase relations, to effectively reduce the number of fit parameters.

Estimating the coupling of ghost beams that are caused by polarisation leakage requires a different analysis not covered here and will also depend strongly on the quality of the optics, coatings, and the alignment. The most dominant polarisation ghost beams will create beats at the nominal modulation depth, making them non-suppressible by extending the fit. Since such beats will follow the nominal phase to first order their coupling is expected to be, at most, a second order effect. An experimental study of a similar combination of a polarising beam splitter and a quarter waveplate for LISA has found no measurable non-linearity within their sensitivity [22]. Comparing this to the QMC is, however, not straight-forward because the interferometer topology is more complex, with the Michelson beams splitter (surface 10) as crucial difference. Practically speaking one can try to add additional optics to clean the output beams if polarisation leakage should become a dominating effect.

For actual implementations we recommend to operate the optical head first in a calibration mode, in which the long arm beam is dumped. In this mode only beat signals between E_N , E_1 and E_{NN} will be present, providing access to the modulation depth m_1 , m_d and to the corresponding electric field amplitudes.

4. Conclusion and Outlook

Realising on-axis optical heads for DFMI is an interesting approach to realise picometer-level displacement and nano-radian tilt sensing and micrometer-accuracy absolute ranging that can be realised using compact QMCs. Major advantages are the extended longitudinal measurement range and fixed beam-angles, which will simplify alignment strategies, especially if several sensors are to be used to probe a single test mass. One expected disadvantage of our design, non-linearity due to zero-angle generation of ghost beams, can be suppressed by extending the readout algorithm of DFMI. Balanced detection and fitting of higher modulation depth signals are shown to be effective extensions that reduce ghost-beam induced non-linearity to levels below 0.3 % for a straightforward and below

0.01 % for an extended design when several parasitic signals with a relative amplitude of $\approx 5\%$ are present.

The complexity and orthogonality of DFMI beat signals also provides opportunities for other multiplexing and ghost beam suppression schemes, as well as reducing non-linearities due to the laser modulation [11]. The reduction in optical head size and its other benefits are bought by increasing the phase extraction complexity and computational effort. The increase in computation time between the initial fit P_{fit} and the final fit, $P_{\text{fit,BD,2m}}$ is less than four in our simulations. Laboratory tests of such sensors and real-time algorithm implementations will reveal the compatibility of such approaches for any given application, they will give insight into effects caused by polarisation leakage, and further improvements in the signal processing and phase estimation might compensate the computational effort as well. It is worthwhile to conclude with the fact that any real DFMI interferogram contains a multitude of information, which makes optimal phase extraction an arithmetic and numerical challenge that is, however, rewarded with additional information that could not be extracted in homodyne or heterodyne interferometers.

Author Contributions: Both authors contributed equally to this work

Funding: This research is funded by the Deutsche Forschungsgemeinschaft (DFG, German Research Foundation) under Germany's Excellence Strategy – EXC 2121 „Quantum Universe“ – 390833306 and by the German Federal Ministry of Education and Research (BMBF, Project 05A20GU5).

Conflicts of Interest: The authors declare no conflict of interest.

References

1. Abbott, B.P. et al. GW150914: The Advanced LIGO Detectors in the Era of First Discoveries. *Phys. Rev. Lett.* **2016**, *116*, 131103. doi:10.1103/PhysRevLett.116.131103.
2. Knabe, A.; Douch, K.; Müller, J. The Potential of Satellite Gradiometry to Recover the Time-Variable Gravity Field. *IUGG*; , 2019; p. 1.
3. eLISA Consortium The Gravitational Universe. *arXiv:1305.5720 [astro-ph, physics:gr-qc]* **2013**, [arXiv:astro-ph, physics:gr-qc/1305.5720].
4. Mow-Lowry, C.M.; Martynov, D. A 6D Interferometric Inertial Isolation System. *Classical and Quantum Gravity* **2019**, *36*, 245006. doi:10.1088/1361-6382/ab4e01.
5. Cooper, S.J.; Collins, C.J.; Green, A.C.; Hoyland, D.; Speake, C.C.; Freise, A.; Mow-Lowry, C.M. A Compact, Large-Range Interferometer for Precision Measurement and Inertial Sensing. *Classical and Quantum Gravity* **2018**, *35*, 095007. doi:10.1088/1361-6382/aab2e9.
6. Watchi, J.; Cooper, S.; Ding, B.; Mow-Lowry, C.M.; Collette, C. Contributed Review: A Review of Compact Interferometers. *Review of Scientific Instruments* **2018**, *89*, 121501. doi:10.1063/1.5052042.
7. Zhao, G.; Ding, B.; Watchi, J.; Deraemaeker, A.; Collette, C. Experimental Study on Active Seismic Isolation Using Interferometric Inertial Sensors. *Mechanical Systems and Signal Processing* **2020**, *145*, 106959. doi:10.1016/j.ymssp.2020.106959.
8. Carbone, L.; Aston, S.M.; Cutler, R.M.; Freise, A.; Greenhalgh, J.; Heefner, J.; Hoyland, D.; Lockerbie, N.A.; Lodhia, D.; Robertson, N.A.; Speake, C.C.; Strain, K.A.; Vecchio, A. Sensors and Actuators for the Advanced LIGO Mirror Suspensions. *Classical and Quantum Gravity* **2012**, *29*, 115005.
9. Akutsu, T.; Peña Arellano, F.E.; Shoda, A.; Fujii, Y.; Okutomi, K.; Barton, M.A.; Takahashi, R.; Komori, K.; Aritomi, N.; Shimoda, T.; Takano, S.; Takeda, H.; Tapia San Martin, E.N.; Kozu, R.; Ikenoue, B.; Obuchi, Y.; Fukushima, M.; Aso, Y.; Michimura, Y.; Miyakawa, O.; Kamiizumi, M. Compact Integrated Optical Sensors and Electromagnetic Actuators for Vibration Isolation Systems in the Gravitational-Wave Detector KAGRA. *Review of Scientific Instruments* **2020**, *91*, 115001. doi:10.1063/5.0022242.
10. Gerberding, O. Deep Frequency Modulation Interferometry. *Optics Express* **2015**, *23*, 14753–14762.
11. Isleif, K.S.; Gerberding, O.; Schwarze, T.S.; Mehmet, M.; Heinzl, G.; Cervantes, F.G. Experimental Demonstration of Deep Frequency Modulation Interferometry. *Opt. Express* **2016**, *24*, 1676–1684. doi:10.1364/OE.24.001676.
12. Isleif, K.S.; Heinzl, G.; Mehmet, M.; Gerberding, O. Compact Multifringe Interferometry with Subpicometer Precision. *Physical Review Applied* **2019**, *12*, 034025. doi:10.1103/PhysRevApplied.12.034025.

13. Yang, Y.; Yamamoto, K.; Huarcaya, V.; Vorndamme, C.; Penkert, D.; Fernández Barranco, G.; Schwarze, T.S.; Mehmet, M.; Esteban Delgado, J.J.; Jia, J.; Heinzl, G.; Dovale Álvarez, M. Single-Element Dual-Interferometer for Precision Inertial Sensing. *Sensors* **2020**, *20*, 4986. doi:10.3390/s20174986.
14. Heinzl, G.; Guzmán Cervantes, F.; García Marin, A.F.; Kullmann, J.; Feng, W.; Danzmann, K. Deep Phase Modulation Interferometry. *Opt. Express* **2010**, *18*, 19076–19086.
15. Gerberding, O.; Isleif, K.S.; Mehmet, M.; Danzmann, K.; Heinzl, G. Laser-Frequency Stabilization via a Quasimonolithic Mach-Zehnder Interferometer with Arms of Unequal Length and Balanced Dc Readout. *Phys. Rev. Applied* **2017**, *7*, 024027. doi:10.1103/PhysRevApplied.7.024027.
16. Heinzl, G.; Wand, V.; Garcia, A.; Jennrich, O.; Braxmaier, C.; Robertson, D.; Middleton, K.; Hoyland, D.; Rüdiger, A.; Schilling, R.; others. The LTP Interferometer and Phasemeter. *Classical and Quantum Gravity* **2004**, *21*, S581.
17. Schwarze, T.S.; Gerberding, O.; Cervantes, F.G.; Heinzl, G.; Danzmann, K. Advanced Phasemeter for Deep Phase Modulation Interferometry. *Opt. Express* **2014**, *22*, 18214–18223.
18. Kissinger, T.; Charrett, T.O.; Tatam, R.P. Range-Resolved Interferometric Signal Processing Using Sinusoidal Optical Frequency Modulation. *Opt. Express* **2015**, *23*, 9415–9431.
19. Shaddock, D.A. Digitally Enhanced Heterodyne Interferometry. *Optics letters* **2007**, *32*, 3355–3357.
20. Fleddermann, R.; Diekmann, C.; Steier, F.; Tröbs, M.; Heinzl, G.; Danzmann, K. Sub-pm/ $\sqrt{\text{Hz}}$ Non-Reciprocal Noise in the LISA Backlink Fiber. *Classical and Quantum Gravity* **2018**, *35*, 075007. doi:10.1088/1361-6382/aaa276.
21. Armano, M. et al. Sub-Femto-g Free Fall for Space-Based Gravitational Wave Observatories: LISA Pathfinder Results. *Phys. Rev. Lett.* **2016**, *116*, 231101. doi:10.1103/PhysRevLett.116.231101.
22. Dehne, M.; Tröbs, M.; Heinzl, G.; Danzmann, K. Verification of Polarising Optics for the LISA Optical Bench. *Opt. Express* **2012**, *20*, 27273–27287.
23. Schwarze, T.S.; Barranco, G.F.; Penkert, D.; Kaufer, M.; Gerberding, O.; Heinzl, G. Picometer-Stable Hexagonal Optical Bench to Verify LISA Phase Extraction Linearity and Precision. *Physical Review Letters* **2019**, *122*, 081104.
24. Kochkina, E.; Heinzl, G.; Wanner, G.; Müller, V.; Mahrtdt, C.; Sheard, B.; Schuster, S.; Danzmann, K. Simulating and Optimizing Laser Interferometers. *ASP Conf. Ser.* **2013**, *467*, 291.